

August 25, 1992

Docket No. 50-341

Mr. William S. Orser
Senior Vice President - Nuclear
Operations
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

Dear Mr. Orser:

SUBJECT: ERRATA FOR AMENDMENT NOS. 84 AND 85 TO FACILITY OPERATING LICENSE
NO. NPF-43 FOR THE FERMI-2 FACILITY (TAC NOS. M82717 AND M82790)

Due to a mailing error you indicated that the subject license amendments which were issued July 31, 1992, were not received until August 13, 1992. You had requested 30 days for full implementation of these amendments or until August 30, 1992. Due to the mailing error, you indicated that you would be unable to fully implement by the date specified and requested an extension. Additionally, you noted a text error on Technical Specification (TS) page 3/4 7-16 issued with License Amendment No. 84. Enclosed are (1) a replacement TS page 3/4 7-16 for License Amendment No. 84, and (2) corrected Amendment No. 84 and 85 pages with the corrected implementation dates. We regret any inconvenience the mailing error has caused you. The enclosed errata to the TS page 3/4 7-16 should replace the page previously transmitted.

Sincerely,

Original signed by

Timothy G. Colburn, Sr. Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

1. Replacement TS page 3/4 7-16 for License Amendment No. 84
2. Corrected Amendment Nos. 84 and 85 pages with the corrected implementation dates

NRC FILE CENTER COPY

cc w/enclosures:

See next page

OFFICE	LA:PD31	PM:PD31	D:PD31 <i>AM</i>
NAME	MShuttleworth <i>MKA</i>	TColburn: jkd <i>Tec</i>	LMarsh
DATE	<i>8/24/92</i>	<i>8/24/92</i>	<i>8/24/92</i>

OFFICIAL RECORD COPY - FILENAME: C:\WP\WPDOCS\FERMI\FE282717.AMC

9208310297 920825
PDR ADOCK 05000341
P PDR

*DF01
11*

CP-1

Mr. William Orser
Detroit Edison Company

Fermi-2

cc:

John Flynn, Esquire
Senior Attorney
Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3423 N. Logan Street
P. O. Box 30195
Lansing, Michigan 48909

Mr. Stan Stasek
U.S. Nuclear Regulatory Commission
Resident Inspector Office
6450 W. Dixie Highway
Newport, Michigan 48166

Monroe County Office of Civil
Preparedness
963 South Raisinville
Monroe, Michigan 48161

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. A. Cecil Settles
Director - Nuclear Licensing
Detroit Edison Company
Fermi 2
6400 North Dixie Highway
Newport, Michigan 48166

DATED: August 25, 1992

AMENDMENT NO. 84 TO FACILITY OPERATING LICENSE NO. NPF-43-FERMI-2
AMENDMENT NO. 85 TO FACILITY OPERATING LICENSE NO. NPF-43-FERMI-2

Docket File

NRC & Local PDRs
PDIII-1 Reading
Fermi Plant File
B. Boger
J. Zwolinski
L. Marsh
M. Shuttleworth
T. Colburn
OGC-WF
D. Hagan, 3302 MNBB
G. Hill (4), P-137
Wanda Jones, MNBB-7103
C. Grimes, 11/F/23
R. Jones 8/E/23
ACRS (10)
GPA/PA
OC/LFMB
W. Shafer, R-III

cc: Plant Service list



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DETROIT EDISON COMPANY

FERMI-2

DOCKET NO. 50-341

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 85
License No. NPF-43

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Detroit Edison Company (the licensee) dated January 30, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-43 is hereby amended to read as follows:

Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 85, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. DECo shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

9208310304 920825
PDR ADOCK 05000341
P PDR

3. This license amendment is effective as of the date of its issuance with full implementation within 45 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Ledyard B. Marsh, Director
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 25, 1992



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DETROIT EDISON COMPANY

FERMI-2

DOCKET NO. 50-341

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 84
License No. NPF-43

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Detroit Edison Company (the licensee) dated January 28, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-43 is hereby amended to read as follows:

Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 84, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. DECo shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance with full implementation within 45 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Ledyard B. Marsh, Director
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 25, 1992

PLANT SYSTEMS

3/4.7.5 SNUBBERS

LIMITING CONDITION FOR OPERATION

3.7.5 All* hydraulic and mechanical snubbers shall be OPERABLE.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3. OPERATIONAL CONDITIONS 4 and 5 for snubbers located on systems required OPERABLE in those OPERATIONAL CONDITIONS.

ACTION:

With one or more snubbers inoperable on any system, within 72 hours replace or restore the inoperable snubber(s) to OPERABLE status and perform an engineering evaluation per Specification 4.7.5g on the attached component or declare the attached system inoperable and follow the appropriate ACTION statement for that system.

SURVEILLANCE REQUIREMENTS

4.7.5 Each snubber shall be demonstrated OPERABLE by performance of the following augmented inservice inspection program in addition to the requirements of Specification 4.0.5.

a. Inspection Types

As used in this specification, type of snubber shall mean snubbers of the same design and manufacturer, irrespective of capacity.

b. Visual Inspections

Snubbers are categorized as inaccessible or accessible during reactor operation. Each of these categories (inaccessible and accessible) may be inspected independently according to the schedule determined by Table 4.7.5-1. The visual inspection interval for each category of snubber shall be determined based upon the criteria provided in Table 4.7.5-1. The first inspection interval determined using this criteria shall be based upon the previous inspection interval as established by the requirements in effect before Amendment 84.

*As described in the bases.