

June 11, 1999

Mr. Douglas R. Gipson
Senior Vice President
Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, MI 48166

SUBJECT: FERMI 2 - CORRECTION OF TYPOGRAPHICAL ERRORS IN AMENDMENT
NO. 133, RECIRCULATION PUMP DISCHARGE VALVE SURVEILLANCE
REQUIREMENT (TAC NO. MA5118)

Dear Mr. Gipson:

The Commission issued the subject amendment on May 25, 1999. On June 7, 1999, Mr. Rodney Johnson of your staff contacted us and informed us that two typographical errors had been introduced on page 3/4 4-1. This was an overleaf page that was not affected by the changes proposed in the amendment.

The specific errors were:

1. In Action c., the third word should have been "reactor." In the amendment this word appeared as "factor."
2. The page number at the bottom of the page should have been 3/4 4-1. In the amendment the page number appeared as 3/4 4.1.

These errors were introduced when the NRC created an electronic version of this page for the amendment package. A corrected copy of the page (i.e., as it appeared prior to the amendment) is enclosed. The NRC apologizes for any inconvenience caused by these errors.

Sincerely,

Original signed by:

Andrew J. Kugler, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-341

Enclosure: Corrected page 3/4 4-1

NRC FILE CENTER COPY

cc w/encl: See next page

DOCUMENT NAME: G:\PDIII-1\FERMI\tra5118.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PD3-1	E	LA:PD3-1	E	SC:PD3-1	<input checked="" type="checkbox"/>
NAME	AKugler: <i>AK</i>		CMoore		CCraig <i>CC</i>	
DATE	06/11/99		06/11/99		06/11/99	

OFFICIAL RECORD COPY

9906150137 990611
PDR ADOCK 05000341
P PDR

250017

//
DFol

CP1

June 11, 1999

Mr. Douglas R. Gipson
Senior Vice President
Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, MI 48166

SUBJECT: FERMI 2 - CORRECTION OF TYPOGRAPHICAL ERRORS IN AMENDMENT
NO. 133, RECIRCULATION PUMP DISCHARGE VALVE SURVEILLANCE
REQUIREMENT (TAC NO. MA5118)

Dear Mr. Gipson:

The Commission issued the subject amendment on May 25, 1999. On June 7, 1999, Mr. Rodney Johnson of your staff contacted us and informed us that two typographical errors had been introduced on page 3/4 4-1. This was an overleaf page that was not affected by the changes proposed in the amendment.

The specific errors were:

1. In Action c., the third word should have been "reactor." In the amendment this word appeared as "factor."
2. The page number at the bottom of the page should have been 3/4 4-1. In the amendment the page number appeared as 3/4 4.1.

These errors were introduced when the NRC created an electronic version of this page for the amendment package. A corrected copy of the page (i.e., as it appeared prior to the amendment) is enclosed. The NRC apologizes for any inconvenience caused by these errors.

Sincerely,

Original signed by:

Andrew J. Kugler, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-341

Enclosure: Corrected page 3/4 4-1

cc w/encl: See next page

DOCUMENT NAME: G:\PDIII-1\FERMI\tra5118.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PD3-1	E	LA:PD3-1	E	SC:PD3-1	<input checked="" type="checkbox"/>
NAME	AKugler: <i>AKugler</i>		CMoore		CCraig <i>CCraig</i>	
DATE	06/ 11 /99		06/ 11 /99		06/ 11 /99	

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 11, 1999

Mr. Douglas R. Gipson
Senior Vice President
Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, MI 48166

SUBJECT: FERMI 2 - CORRECTION OF TYPOGRAPHICAL ERRORS IN AMENDMENT
NO. 133, RECIRCULATION PUMP DISCHARGE VALVE SURVEILLANCE
REQUIREMENT (TAC NO. MA5118)

Dear Mr. Gipson:

The Commission issued the subject amendment on May 25, 1999. On June 7, 1999, Mr. Rodney Johnson of your staff contacted us and informed us that two typographical errors had been introduced on page 3/4 4-1. This was an overleaf page that was not affected by the changes proposed by you in the amendment.

The specific errors were:

1. In Action c., the third word should have been "reactor." In the amendment this word appeared as "factor."
2. The page number at the bottom of the page should have been 3/4 4-1. In the amendment the page number appeared as 3/4 4.1.

These errors were introduced when the NRC created an electronic version of this page for the amendment package. A corrected copy of the page (i.e., as it appeared prior to the amendment) is enclosed. The NRC apologizes for any inconvenience caused by these errors.

Sincerely,

A handwritten signature in black ink, appearing to read "Andrew J. Kugler".

Andrew J. Kugler, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-341

Enclosure: Corrected page 3/4 4-1

cc w/encl: See next page

DATED: June 11, 1995

FERMI 2 - CORRECTION OF TYPOGRAPHICAL ERRORS IN AMENDMENT NO. 133

Docket File (50-341)

PUBLIC

PD3-1 r/f

J. Zwolinski/S. Black

C. Thomas/C. Craig

C. Moore

A. Kugler (2)

OGC

G. Hill (2)

W. Beckner

J. Wermiel

E. Imbro

ACRS

A. Vogel, RIII

Mr. Douglas R. Gipson
Detroit Edison Company

Fermi 2

cc:

John Flynn, Esquire
Senior Attorney
Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Drinking Water and Radiological
Protection Division
Michigan Department of
Environmental Quality
3423 N. Martin Luther King Jr Blvd
P. O. Box 30630 CPH Mailroom
Lansing, Michigan 48909-8130

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
6450 W. Dixie Highway
Newport, Michigan 48166

Monroe County Emergency Management
Division
963 South Raisinville
Monroe, Michigan 48161

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Norman K. Peterson
Director, Nuclear Licensing
Detroit Edison Company
Fermi 2 - 280 TAC
6400 North Dixie Highway
Newport, Michigan 48166

3/4.4 REACTOR COOLANT SYSTEM
3/4.4.1 RECIRCULATION SYSTEM
RECIRCULATION LOOPS
LIMITING CONDITION FOR OPERATION

3.4.1.1 Two reactor coolant system recirculation loops shall be in operation.

APPLICABILITY: OPERATIONAL CONDITIONS 1 and 2*.

ACTION:

- a. With one reactor coolant system recirculation loop not in operation:
 1. Within 4 hours:
 - a) Place the individual recirculation pump flow controller for the operating recirculation pump in the Manual mode.
 - b) Reduce THERMAL POWER to less than or equal to 67.2% of RATED THERMAL POWER.
 - c) Limit the speed of the operating recirculation pump to less than or equal to 75% of rated pump speed.
 - d) Increase the MINIMUM CRITICAL POWER RATIO (MCPR) Safety Limit to the value for single loop operation required by Specification 2.1.2.
 - e) Change the Average Power Range Monitor (APRM) Simulated Thermal Power - Upscale Flow Biased Scram and Rod Block Trip Setpoints and Allowable Values to those applicable for single recirculation loop operation per Specifications 2.2.1 and 3.3.6.
 - f) Perform Surveillance Requirement 4.4.1.1.4 if THERMAL POWER is less than or equal to 30% of RATED THERMAL POWER or the recirculation loop flow in the operating loop is less than or equal to 50% of rated loop flow.
 2. Otherwise, be in at least HOT SHUTDOWN within the next 12 hours.
- b. With no reactor coolant system recirculation loop in operation while in OPERATIONAL CONDITION 1, immediately place the Reactor Mode Switch in the SHUTDOWN position.
- c. With no reactor coolant system recirculation loops in operation, while in OPERATIONAL CONDITION 2, initiate measures to place the unit in at least HOT SHUTDOWN within the next 6 hours.

*See Special Test Exception 3.10.4.

9906150154 990611
PDR ADOCK 05000341
PDR