Tennessee Valley Authority Browns Ferry Nuclear Plant Alternative Source Term Implementation

TVA/NRC Meeting

Nuclear Reactor Regulation - Rockville MD

January 16, 2002

Agenda



- Introduction/Meeting Objectives
- Schedule
- ◆ Background
- Analysis Approach
- Analysis Attributes
- Submittal Contents
- Summary and Open Discussion




Introduction/Meeting Objectives

- Introduction
- Previous Meeting Extended Power Uprate
- Meeting Objectives
 - Discuss the BFN Approach
 - Discuss Submittal Content and Depth of Information
 - Obtain NRC Concurrence of TVA's Proposed Methodology
 - Gain NRC Insights From Other Alternative Source Term
 Submittals

IW

Schedule



Steve Austin

Background



- BFN Design Features
 - BWR 4
 - Mark I Containment
 - Inerted Primary Containment
 - Secondary Containment Common to Units 1, 2, and 3
 - Three Trains of Standby Gas Treatment
 - 600 Foot Stack
 - Units 1, 2, and 3 Control Rooms Have a Common Control Room Emergency Ventilation (CREV) System
- 2000 NRC Safety Evaluation For Increased Main Steam Isolation Valve Leakage
 - Implemented Main Steam Ruggedness
 - Completed Implementation March 2001



Background (Cont.)

- Current Radiological Analysis Approach
 - ORIGEN Source Terms
 - Traditional Regulatory Methods
 - Atmospheric Dispersion Coefficients
 - Used in MSIV Increased Leakage Submittal and Associated NRC SER
 - UFSAR Amendment 19
 - Use Existing Values For AST
 - ECCS Leakage



Analysis Approach

- Requirements of 10 CFR 50.67, Revised Accident Source
 Term
- Follow Reg Guide 1.183, "Alternative Radiological Source Terms for Evaluating Design Basis Accidents As Nuclear Power Reactors"
- Full Implementation
- Reran ORIGEN Source Term at EPU Conditions
- Suppression Pool Water pH Control
- Filtration Efficiencies
- No Plant Modifications Anticipated

Analysis Attributes



- Based on Design Basis Accidents
 - Loss of Coolant Accident
 - Main Steam Line Break
 - Control Rod Drop Accident
 - Fuel Handling Accident
- NUREG 0737 Mission Doses
- Expressed in Terms of Times and Rates of Appearance of Radioactive Fission Products Released Into Containment
- Types and Quantities of the Radioactive Species Released
- Chemical Forms of Iodine Released

Drywell Sprays



- Safety Related Redundant Mode of RHR
- Credit for Drywell Sprays (Loss of Coolant Accident)
 - Boiling Water Reactor Sprays Already Credited for AST
 - Perry
 - Grand Gulf
 - Manual Actuation
 - Drywell Congestion
 - Reduced Spray Being Credited for BFN
 - Reduced Fall Height Being Credited for BFN
 - Standard Review Plan 6.5.2 Used for Spray Removal Rate



Main Steam Line Break (MSLB) X/Q

Outside Containment

- Current Analysis Approach
 - Turbine Building Remains Intact
 - No Credit for Deposition
 - ARCON96 Steady-State Plume X/Q
 - Release Over 2 Hour Time Period
 - Release Through Unit 1 Turbine Building Exhaust (Highest X/Q)
 - Includes Consideration for Dual CREV Intake





Outside Containment

- + RG 1.183 MSLB X/Q Scenario
 - Puff Release Directly to Environment
 - Puff X/Q Used
 - Immediate Release Assumed
 - No Credit for Deposition
 - Rising Puff Credited
 - NRC Puff Model in Draft Regulatory Guide 1111, "Atmospheric Relative Concentrations for Control Radiological Habitability Assessments at Nuclear Power Plants" Will be Considered

Henry Jones



Use of AEB-98-03

- Use of AEB-98-03 Approach With DW Spray Credit and Multiple Steam Line/Condenser Volumes in Series
 - TVA Plans to Use AEB-98-03 but With DW Sprays and Multiple Steam Line/Condenser Control Volumes in Series
 - DW Sprays Remove Large, Dense Particles
 - Multiple Steam Line/Condenser Volumes in Series
 Decreases the Sedimentation Velocity Distribution in
 Downstream Control Volumes



Submittal Contents

- Previous Submittals
 - Duane Arnold
 - Columbia
- Review and Incorporate Applicable AST RAIs
- Describe Changes
- Identify the Computer Codes Utilized
- Identify Inputs and Assumptions
- Describe the AST Results
- Identify Affected UFSAR Sections



Summary and Open Discussion

- Evaluations and Acceptance Criteria Will be Consistent
 With Those Required by 10 CFR 50.67 and Reg Guide 1.183
- Evaluate Design Bases Accidents
 - Acceptable Radiological Analysis Methods and Assumptions
- Update the Design/Licensing Bases for BFN
 - Technical Specifications
 - FSAR
 - Calculations
- Open Discussion