

JUL 26 1974

Docket No. 50-305

Wisconsin Public Service Corporation
ATTN: Mr. E. W. James
Senior Vice President
P. O. Box 1200
Green Bay, Wisconsin 54305

Amendment No. 2
License No. DPR-43

Gentlemen:

Reference is made to our letter of April 19, 1974, transmitting Change No. 2 to the Technical Specifications for the Kewaunee Nuclear Power Plant.

Change No. 2 granted temporary relief to the requirements for control room staffing pending award of reactor operator licenses to additional individuals. These additional licenses were awarded on June 11, 1974. The temporary relief granted by Change No. 2 thus is no longer needed and the Technical Specifications for control room staffing are being returned to their original form. A copy of the staff safety evaluation is enclosed.

A copy of a related notice which has been forwarded to the Office of the Federal Register for filing and publication also is enclosed.

Sincerely,

Original signed by
Voss A. Moore

Voss A. Moore, Assistant Director
for Light Water Reactors, Group 2
Directorate of Licensing

Enclosures:
As stated

ccs:
Listed on page 2

OFFICE	LWR 2-2	LWR 2-2	LWR 2-2	DOCKET	AD/LWRs	ADDP
SURNAME	MS:nlg	LPCrocker	KKniel	Gallo	VAM606	ADDP
DATE	7/23/74	7/23/74	7/24/74	7/26/74	7/29/74	7/24

Wisconsin Public Service Corporation -2-

cc:

**Mr. Carl Giesler
Superintendent of Nuclear Power
Wisconsin Public Service Corporation
P. O. Box 1200
Green Bay, Wisconsin 54305**

**Steven E. Keane, Esquire
Foley, Sammand and Lardner
735 North Water Street
Milwaukee, Wisconsin 53202**

**Bruce W. Churchill, Esquire
Shaw, Pittman, Potts & Trowbridge
910 17th Street, NW
Washington, D. C. 20006**

**Mr. William F. Eich, Chairman
Public Service Commission of Wisconsin
Hill Farms State Office Building
Madison, Wisconsin 53702**

**Mr. Arden Koehler
Chairman, Town of Carlton
Route 1
Kewaunee, Wisconsin 54216**

**Mr. Donald E. Quistorff
Chairman, Kewaunee County Board
Kewaunee County Courthouse
Kewaunee, Wisconsin 54216**

**Mr. Hans L. Hamester
ATTN: Joan Sause
Office of Radiation Programs
Environmental Protection Agency
4th & M Streets, SW
Washington, D. C. 20460**

**Mr. Gary Williams
Federal Activities Branch
Environmental Protection Agency
1 North Wacker Drive
Chicago, Illinois 60602**

DISTRIBUTION:

AEC PDR
Local PDR
Docket
LWR 2-2
OGC (Seiffert)
RO (3)
NDube
MJinks (w/2 encl)
VMoore
DSkovholt
DEisenhut
RKlecker
RVollmer
WMiller, DR:AO
LCrocker
MService
ACRS (16)
BScharf

bcc:

JRBuchanam, ORNL
TBAbernathy, DTIE
ARosenthal, ASLAB
NHGoodrich, ASLBP

OFFICE ➤						
SURNAME ➤						
DATE ➤						

WISCONSIN PUBLIC SERVICE CORPORATION

WISCONSIN POWER AND LIGHT COMPANY

MADISON GAS AND ELECTRIC COMPANY

DOCKET NO. 50-305

KEWAUNEE NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 2
License No. DPR-43

1. The Atomic Energy Commission (the Commission) having found that:
 - A. The temporary change to the Technical Specifications granted by Change No. 2, dated April 19, 1974, is no longer required and that revision of the Technical Specifications to their original form complies with the standards and requirements of the Atomic Energy Act of 1954, as amended, and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the license, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. Prior public notice of this amendment is not required since the amendment does not involve a significant hazards consideration.
2. Accordingly, Paragraph 2.C. (2) of Facility License DPR-43 is hereby amended to include the following:

"(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, attached to Facility Operating License No. DPR-43 are revised as indicated in the attachment to this license amendment. The Technical Specifications, as revised, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications, as revised."

3. This license amendment is effective as of the date of its issuance.

FOR THE ATOMIC ENERGY COMMISSION:

Voss A. Moore
Voss A. Moore, Assistant Director
for Light Water Reactors, Group 2
Directorate of Licensing

Attachment:
Change No. 4 to Appendix A
Technical Specifications

Date of Issuance:

JUL 26 1974

UNITED STATES ATOMIC ENERGY COMMISSION

DOCKET NO. 50-305

WISCONSIN PUBLIC SERVICE CORPORATION

WISCONSIN POWER AND LIGHT COMPANY

MADISON GAS AND ELECTRIC COMPANY

NOTICE OF ISSUANCE OF FACILITY LICENSE AMENDMENT

Notice is hereby given that the U.S. Atomic Energy Commission (the Commission) has issued Amendment No. 2 to Facility Operating License No. DPR-43, issued to Wisconsin Public Service Corporation, Wisconsin Power and Light Company, and Madison Gas and Electric Company, which revised Technical Specifications for operation of the Kewaunee Nuclear Power Plant, located in Kewaunee County, Wisconsin. The amendment is effective as of its date of issuance.

The amendment deletes paragraph 6.1.b.5 of the Technical Specifications which was added to the Technical Specifications by Change No. 2 on April 19, 1974. Paragraph 6.1.b.5 granted temporary relief for control room staffing pending issuance of licenses to additional control room operators.

The Commission has made appropriate findings as required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations in 10 CFR Chapter 1, which are set forth in the license amendment.

For further details with respect to this action, see (1) Amendment No. 2 to License No. DPR-43, with attachments, and (2) the Commission's related Safety Evaluation. These are available for public inspection at the Commission's Public Document Room, 1717 H Street, NW, Washington, D. C., and at the Kewaunee County Library, Kewaunee, Wisconsin.

A copy of items (1) and (2) may be obtained upon request addressed to the United States Atomic Energy Commission, Washington, D. C. 20545, Attention: Deputy Director for Reactor Projects, Directorate of Licensing - Regulation.

Dated at Bethesda, Maryland, this ^{26th} day of July, 1974

FOR THE ATOMIC ENERGY COMMISSION



Karl Knief, Chief
Light Water Reactors Branch 2-2
Directorate of Licensing

SAFETY EVALUATION BY THE DIRECTORATE OF LICENSING
SUPPORTING AMENDMENT NO. 2 TO DPR-43
CHANGE NO. 4 TO APPENDIX A OF TECHNICAL SPECIFICATIONS
WISCONSIN PUBLIC SERVICE CORPORATION
WISCONSIN POWER AND LIGHT COMPANY
MADISON GAS AND ELECTRIC COMPANY
KEWAUNEE NUCLEAR POWER PLANT
DOCKET NO. 50-305

Introduction

On April 19, 1974, Change No. 2 to the Technical Specifications for License No. DPR-43 was issued. Change No. 2 added a paragraph 6.1.b.5 to the Technical Specifications which granted temporary relief to the licensee on the requirements for control room staffing. Specifically, the paragraph allowed the licensee to use a trained but not yet licensed individual on each shift as one of the two required reactor operators pending award of reactor operator licenses by the AEC to the additional individuals then under training.

Discussion

Reactor Operator licenses were issued to an additional eight individuals on June 11, 1974, bringing the total number of licensed operators to fourteen. The facility thus has an ample number of licensed operators to man the operating shifts and there is no longer a need for the temporary relief granted by Change No. 2.

Accordingly, the Commission now proposes to delete paragraph 6.1.b.5 from the Technical Specifications, thus returning the requirements for control room staffing to those originally established by the Technical Specifications.

Evaluation

The temporary relief granted by Change No. 2 expired on June 11, 1974, when additional reactor operators licenses were issued. This Change No. 4 deletes Change No. 2 and restores the Technical Specifications for control room staffing to their original form.

On the basis of our review of this change to the Technical Specifications, we conclude that it does not involve significant hazards considerations and that there is reasonable assurance that the health and safety of the public will not be endangered.



L. P. Crocker
Senior Project Manager
Light Water Reactors Branch 2-2
Directorate of Licensing



Karl Kniel, Chief
Light Water Reactors Branch 2-2
Directorate of Licensing

JUL 26 1974

3. The shift complement shall consist of at least one Shift Supervisor holding a senior Reactor operator's license, two licensed reactor operators, one auxiliary operator, and one equipment operator.
4. In the event that one of the shift members becomes incapacitated due to illness or injury, the reactor may continue to be operated for up to two hours with the reduced complement until his replacement arrives.

(Paragraph 6.1.b.5 deleted)

4