

REGULATORY DOCKET FILE COPY

8005080093

APRIL 18 1980

Docket No. 50-305

Mr. Eugene R. Mathews, Vice President
Power Supply and Engineering
Wisconsin Public Service Corporation
Post Office Box 1200
Green Bay, Wisconsin 54305

Dear Mr. Mathews:

By our letter dated January 25, 1978 we transmitted to you Amendment No. 19 to Facility Operating License No. DPR-43 for the Kewaunee Nuclear Power Plant. During a routine check of the Kewaunee Technical Specifications, we have found that the Revised Technical Specifications associated with that Amendment did not include page TS 6-17. Enclosed is page 6-17 for inclusion in your copy.

Sincerely,

Original signed by

A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors

Enclosure:
Technical Specification
Page TS 6-17

cc: See next page

OFFICE	DOR:ORB#1	DOR:ORB#1	DOR:ORB#1			
SURNAME	CSParrish:ph	ASchwencer	RLicciardo			
DATE	04/18/80	04/18/80	04/18/80			

Mr. Eugene R. Mathews
Wisconsin Public Service Corporation

cc: Steven E. Keane, Esquire
Foley and Lardner
777 East Wisconsin Avenue
Milwaukee, Wisconsin 53202

Kewaunee Public Library
822 Juneau Street
Kewaunee, Wisconsin 54216

Stanley LaCrosse, Chairman
Town of Carlton
Route 1
Kewaunee, Wisconsin 54216

Mr. Donald L. Quistroff, Chairman
Kewaunee County Board
Kewaunee County Courthouse
Kewaunee, Wisconsin 54216

Chairman
Public Service Commission of Wisconsin
Hill Farms State Office Building
Madison, Wisconsin 53702

Mr. Patrick Walsh
Assistant Attorney General
114 East, State Capitol
Madison, Wisconsin 53702

Ms. Sandra Bast
1112 North 11th Street
Manitowoc, Wisconsin 54220

Director, Technical Assessment Division
Office of Radiation Programs (AW-459)
U. S. Environmental Protection Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: EIS COORDINATOR
230 South Dearborn Street
Chicago, Illinois 60604

steady state conditions greater than or equal to \$1.00; a calculated reactivity balance indicating a shutdown margin less conservative than specified in the technical specifications; short-term reactivity increases that correspond to a reactor period of less than 5 seconds or, if subcritical, an unplanned reactivity insertion of more than 50¢; or occurrence of any unplanned criticality.

- (5) Failure or malfunction of one or more components which prevents or could prevent, by itself, the fulfillment of the functional requirements of system(s) used to cope with accidents analyzed in the SAR.
- (6) Personnel error or procedural inadequacy which prevents or could prevent, by itself, the fulfillment of the functional requirements of systems required to cope with accidents analyzed in the SAR.

Note: For items 6.9.2.a(5) and 6.9.2.a(6) reduced redundancy that does not result in a loss of system function need not be reported under this section but may be reportable under items 6.9.2.b(2) and 6.9.2.b(3) below.

- (7) Conditions arising from natural or man-made events that, as a direct result of the event require plant shutdown, operation of safety systems, or other protective measures required by technical specifications.
- (8) Errors discovered in the transient or accident analyses or in the methods used for such analyses as described in the safety analysis report or in the bases for the technical specifications