

REGULATOR DOCKET FILE COPY

8005090079
P

DISTRIB. ON:
Docket 50-305
NRC PDR
Local PDR
ORB#1 Rdg
NRR Rdg
DEisenhut
BGrimes
WGammill
ASchwencer
Licciardo
CParrish
Attorney, OELD
I&E (5)
BJones
Buchanan, NSIC
TERA
DBrinkman
ACRS (16)

APR 11 1980

Docket No. 50-305

Mr. Eugene R. Mathews, Vice President
Power Supply and Engineering
Wisconsin Public Service Corporation
Post Office Box 1200
Green Bay, Wisconsin 54305

Dear Mr. Mathews:

By our letter dated January 25, 1978 we transmitted to you Amendment No. 19 to Facility Operating License No. DPR-43 for the Kewaunee Nuclear Power Plant. During a routine check of the Kewaunee Technical Specifications, we have found that the Revised Technical Specifications associated with that Amendment did not include page TS 6-17. Enclosed is page TS 6-17 for inclusion in your copy.

Sincerely,

Original Signed By
A Schwencer

A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors

Enclosure:
Technical Specification
Page TS 6-17

cc: See next page

BD

APP
3

OFFICE	DOR:ORB#1 CP	DOR:ORB#1	DOR:ORB#1			
SURNAME	CParrish:ph	RLicciardo	ASchwencer			
DATE	04/10/80	04/11/80	04/11/80			

steady state conditions greater than or equal to \$1.00; a calculated reactivity balance indicating a shutdown margin less conservative than specified in the technical specifications; short-term reactivity increases that correspond to a reactor period of less than 5 seconds or, if subcritical, an unplanned reactivity insertion of more than 50¢; or occurrence of any unplanned criticality.

- (5) Failure or malfunction of one or more components which prevents or could prevent, by itself, the fulfillment of the functional requirements of system(s) used to cope with accidents analyzed in the SAR.
- (6) Personnel error or procedural inadequacy which prevents or could prevent, by itself, the fulfillment of the functional requirements of systems required to cope with accidents analyzed in the SAR.

Note: For items 6.9.2.a(5) and 6.9.2.a(6) reduced redundancy that does not result in a loss of system function need not be reported under this section but may be reportable under items 6.9.2.b(2) and 6.9.2.b(3) below.

- (7) Conditions arising from natural or man-made events that, as a direct result of the event require plant shutdown, operation of safety systems, or other protective measures required by technical specifications.
- (8) Errors discovered in the transient or accident analyses or in the methods used for such analyses as described in the safety analysis report or in the bases for the technical specifications