

3/22/91

Docket No. 50-255

DISTRIBUTION

Docket Files ✓
NRC & Local PDRs
PD31 R/F
JCalvo
ACRS (10)
DHagan
BHolian
OGC

JZwolinski
GHill(4)
Wanda Jones
PShuttleworth
EJordan
ARM/LFMB
GPA/PA

Mr. Gerald B. Slade
Plant General Manager
Palisades Plant
Consumers Power Company
27780 Blue Star Memorial Highway
Covert, Michigan 49043

Dear Mr. Slade:

SUBJECT: AMENDMENT NO. TO PROVISIONAL OPERATING LICENSE NO. DPR-20:
(TAC NO. 77566)

The Commission has issued the enclosed Amendment No. to Provisional Operating License No. DPR-20 for the Palisades Plant. This amendment consists of changes to the Technical Specifications in response to your application dated August 21, 1990.

This amendment revises Palisades Plant Technical Specifications Table 2.3.1, Reactor Protective System Trip Setting Limits, to delete wording descriptive of the steam generator low water level trip limit that does not apply to the replacement steam generators.

A copy of our Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Brian Holian, Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. to License No. DPR-20
- 2. Safety Evaluation

cc w/enclosures:
See next page

RECORDED COPY
56836 325

LA/PD31:DRP345
PShuttleworth
2/17/91 *MMA*

PE/PD31:DRP345
CCarpenter *ccc*
2/17/91

PM/PD31:DRP345
BHolian *sel*
2/17/91

D/PD31:DRP345
LMansfield *LM*
2/21/91

OGC *gfb*
EHOLLER
2/11/91

~~9103010062~~

EXACT COPY

PALISADES AMEND 77566

270031

CP/w

February 22, 1991

Docket No. 50-255

Mr. Gerald B. Slade
Plant General Manager
Palisades Plant
Consumers Power Company
27780 Blue Star Memorial Highway
Covert, Michigan 49043

DISTRIBUTION

<u>Docket Files</u>	JZwolinski
NRC & Local PDRs	GHill(4)
PD31 R/F	Wanda Jones
JCalvo	PShuttleworth
ACRS (10)	EJordan
DHagan	ARM/LFMB
BHolian	GPA/PA
OGC	

SUBJECT: AMENDMENT NO. 138 TO FACILITY OPERATING LICENSE NO. DPR-20:
(TAC NO. 77566)

The Commission has issued the enclosed Amendment No. 138 to Facility Operating License No. DPR-20 for the Palisades Plant. This amendment consists of changes to the Technical Specifications in response to your application dated August 21, 1990.

This amendment revises Palisades Plant Technical Specifications Table 2.3.1, Reactor Protective System Trip Setting Limits, to delete wording descriptive of the steam generator low water level trip limit that does not apply to the replacement steam generators.

A copy of our Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/

Brian Holian, Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 138 to License No. DPR-20
2. Safety Evaluation

cc w/enclosures:
See next page

*See previous concurrence

*LA/PD31:DRP345	*PE/PD31:DRP345	PM/PD31:DRP345	*D/PD31:DRP345	*OGC
PShuttleworth	CCarpenter	BHolian	LMarsh	
02/07/91	02/07/91	2/22/91	02/21/91	02/11/91

PALISADES AMEND 77566



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

February 22, 1991

Docket No. 50-255

Mr. Gerald B. Slade
Plant General Manager
Palisades Plant
Consumers Power Company
27780 Blue Star Memorial Highway
Covert, Michigan 49043

Dear Mr. Slade:

SUBJECT: AMENDMENT NO. 138 TO FACILITY OPERATING LICENSE NO. DPR-20:
(TAC NO. 77566)

The Commission has issued the enclosed Amendment No. 138 to Facility Operating License No. DPR-20 for the Palisades Plant. This amendment consists of changes to the Technical Specifications in response to your application dated August 21, 1990.

This amendment revises Palisades Plant Technical Specifications Table 2.3.1, Reactor Protective System Trip Setting Limits, to delete wording descriptive of the steam generator low water level trip limit that does not apply to the replacement steam generators.

A copy of our Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in black ink, appearing to read "Brian Holian".

Brian Holian, Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 138 to
License No. DPR-20
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. Gerald B. Slade
Consumers Power Company

Palisades Plant

cc:

M. I. Miller, Esquire
Sidley & Austin
54th Floor
One First National Plaza
Chicago, Illinois 60603

Mr. Thomas A. McNish, Secretary
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Judd L. Bacon, Esquire
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Jerry Sarno
Township Supervisor
Covert Township
36197 M-140 Highway
Covert, Michigan 49043

Office of the Governor
Room 1 - Capitol Building
Lansing, Michigan 48913

Mr. David J. Vandewalle
Director, Safety and Licensing
Palisades Plant
27780 Blue Star Memorial Hwy.
Covert, Michigan 49043

Resident Inspector
c/o U.S. Nuclear Regulatory Commission
Palisades Plant
27782 Blue Star Memorial Hwy.
Covert, Michigan 49043

Nuclear Facilities and
Environmental Monitoring
Section Office
Division of Radiological
Health
P.O. Box 30035
Lansing, Michigan 48909

Gerald Charnoff, P.C.
Shaw, Pittman, Potts &
Trowbridge
2300 N. Street, N.W.
Washington, D.C. 20037

Mr. David L. Brannen
Vice President
Palisades Generating Plant
c/o Bechtel Power Corporation
15740 Shady Grove Road
Gaithersburg, Maryland 20877



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

CONSUMERS POWER COMPANY

PALISADES PLANT

DOCKET NO. 50-255

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 138
License No. DPR-20

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Consumers Power Company (the licensee) dated August 21, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public; and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 3.B. of Facility Operating License No. DPR-20 is hereby amended to read as follows:


9103010067

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 138, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



J. B. Marsh, Director
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 22, 1991

ATTACHMENT TO LICENSE AMENDMENT NO. 138

FACILITY OPERATING LICENSE NO. DPR-20

DOCKET NO. 50-255

Revise Appendix A Technical Specifications by removing the page identified below and inserting the attached page. The revised page is identified by the amendment number and contains marginal lines indicating the area of change.

REMOVE

2-5

INSERT

2-5

TABLE 2.3.1

Reactor Protective System Trip Setting Limits

	<u>Four Primary Coolant Pumps Operating</u>	<u>Three Primary Coolant Pumps Operating (4)</u>
1. Variable High Power (1)	≤10% above core power, with a minimum setpoint of ≤30% of rated power and a maximum of ≤106.5% of rated power	≤10% above core power with a minimum setpoint of ≤15% rated power and a maximum of ≤49% of rated power
2. Primary Coolant Flow (2)	≥95% of Primary Coolant Flow With Four Pumps Operating	≥60% of Primary Coolant Flow With Four Pumps Operating
3. High Pressure Pressurizer	≤2255 Psia	≤2255 Psia
4. Thermal Margin/Low Pressure (2,3)	$P_{trip} \geq$ Applicable Limits	Replaced by Variable High Power Trip and 1750 Psia Minimum Low-Pressure Setting
5. Steam Generator Low Water Level	Not Lower Than the Center Line of Feed-Water Ring	Not Lower Than the Center Line of Feed-Water Ring
6. Steam Generator Low Pressure (2)	≥500 Psia	≥500 Psia
7. Containment High Pressure	≤3.70 Psig	≤3.70 Psig

- (1) The VHPT can be 30% of rated power for power levels ≤ 20% of rated power.
- (2) May be bypassed below 10⁻⁴% of rated power provided auto bypass removal circuitry is operable. For low power physics tests, thermal margin/low pressure, primary coolant flow and low steam generator pressure trips may be bypassed until their react points are reached (approximately 1750 psia and 500 psia, respectively), provided automatic bypass removal circuitry at 10⁻¹% rated power is operable.
- (3) Minimum trip setting shall be 1750 psia.
- (4) Operation with three pumps for a maximum of 12 hours is permitted to provide a limited time for repair/pump restart, to provide for an orderly shutdown or to provide for the conduct of reactor internals noise monitoring test measurements.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 138 TO FACILITY OPERATING LICENSE NO. DPR-20

CONSUMERS POWER COMPANY

PALISADES PLANT

DOCKET NO. 50-255

1.0 INTRODUCTION

By letter dated, August 21, 1990, Consumers Power Company (the licensee) requested an amendment to the Technical Specifications (TS) appended to Facility Operating License No. DPR-20 for the Palisades Plant. The proposed amendment would change Palisades Plant TS Table 2.3.1, Reactor Protective System Trip Setting Limits, to delete wording descriptive of the set point for the original steam generator low water level trip limit. This descriptive wording does not apply to the replacement steam generators.

2.0 EVALUATION

The licensee proposes to change Palisades Plant TS Table 2.3.1, Reactor Protective System Trip Setting Limits.

As written, the TS describes the minimum trip set point for the steam generator water level as "Not Lower Than The Center Line of Feedwater Ring which is located 6'-0" below normal water level." The requested change would delete the words "...which is located 6'-0" below normal water level" since this wording does not apply to the replacement steam generators. There will be no change in the actual reactor trip set point on steam generator low water level.

The normal water level is maintained in the replacement steam generator at approximately 2'-0" below the steam separator support platform. This is the same location it was maintained in the original steam generators; however, for the replacement steam generators this location is approximately 5'-8" above the center line of the feedwater ring vice the 6'-0" for the original steam generators.

The replacement steam generators have greater secondary inventory than did the original steam generators. This, coupled with the fact that the low water level reactor trip has not been changed leads to the conclusion that loss of feedwater flow events are not adversely affected by removing the TS wording relating the trip set point to normal water level. Additionally, the feedwater ring is permanently attached to the steam generator and, therefore, provides a ready reference point from which to measure the reactor trip level, making further descriptive wording superfluous. As such, this change is considered acceptable.

~~9103010069~~

3.0 ENVIRONMENTAL CONSIDERATION

This amendment involves a change in a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such findings. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR Section 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

4.0 CONCLUSION

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: C. E. Carpenter, Jr.

Dated: February 22, 1991