

November 13, 1992

Docket No. 50-255

Mr. Gerald B. Slade
Plant General Manager
Palisades Plant
Consumers Power Company
27780 Blue Star Memorial Highway
Covert, Michigan 49043

*Correction to Amdt 152
to DPR-20*

Dear Mr. Slade:

SUBJECT: PALISADES PLANT - ERRATA FOR AMENDMENT NO. 152 TO FACILITY OPERATING
LICENSE NO. DPR-20 (TAC NO. M73819)

The changes to the plant Technical Specification (TS) implemented by License Amendment No. 152, which were transmitted to you by letter dated August 21, 1992, have been found to contain text errors on page 4-15, as follows: Item 9 on Table 4.2.2 was incorrectly shown on page 4-15. A corrected page 4-15 is attached and should replace the page previously transmitted.

/S/
Sincerely,

Armando Masciantonio, Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
Corrected TS page

cc w/enclosure:
See next page

OFFICE	LA:PDIII-1	PM:PDIII-1 <i>am</i>	PD:PDIII-1 <i>am</i>
NAME	MShuttleworth <i>MS</i>	AMasciantonio	LMarsh
DATE	11/10/92	11/12/92	11/13/92

OFFICIAL RECORD COPY
FILENAME: G:\WPDOCS\PALISADE\PAL73819.ERA

9211240242 921113
PDR ADOCK 0500255
P PDR

*CP
DFE*

Mr. Gerald B. Slade
Consumers Power Company

Palisades Plant

cc:

M. I. Miller, Esquire
Sidley & Austin
54th Floor
One First National Plaza
Chicago, Illinois 60603

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3423 N. Logan Street
P. O. Box 30195
Lansing, Michigan 48909

Mr. Thomas A. McNish, Secretary
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N. W.
Washington DC 20037

Judd L. Bacon, Esquire
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Mr. David L. Brannen, Vice President
Palisades Generating Company
c/o Bechtel Power Corporation
P. O. Box 2166
Houston, Texas, 77252-2166

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Roy W. Jones, Manager
Strategic Program Development
Westinghouse Electric Corporation
4350 Northern Pike
Monroeville, Pennsylvania 15146

Jerry Sarno
Township Supervisor
Covert Township
36197 M-140 Highway
Covert, Michigan 49043

Alora Davis
Commitment Tracking System
Coordinator
Palisades Plant
27780 Blue Star Memorial Hwy.
Covert, Michigan 49043-9530

Office of the Governor
Room 1 - Capitol Building
Lansing, Michigan 48913

Mr. Patrick M. Donnelly, Director
Safety and Licensing
Palisades Plant
27780 Blue Star Memorial Highway
Covert, Michigan 49043

U.S. Nuclear Regulatory Commission
Resident Inspector Office
Palisades Plant
27782 Blue Star Memorial Highway
Covert, Michigan 49043

Table 4.2.2

Minimum Frequencies for Equipment Tests

	<u>Test</u>	<u>Frequency</u>	<u>FSAR Section Reference</u>
1.	Control Rods Drop Times of All Full- Length Rods	Each Refueling Shutdown	7.4.1.3
2.	Control Rods Partial Movement of All Rods (Minimum of 6 In)	Every Two Weeks	7.4.1.3
3.	Pressurizer Safety Valves Set Point	One Each Refueling Shutdown	7.3.7
4.	Main Steam Safety Valves Set Point	Five Each Refueling Shutdown	4.3.4
5.	Refueling System Interlocks Functioning	Prior to Refueling Operations	9.11.3
6.	Service Water System Valve Actuation (SIS-CHP) Functioning	Each Refueling Operation	9.1.2
7.	Primary System Leakage Evaluate	Daily	4 Amend 15, Ques 4.3.7
8.	Diesel Fuel Supply Fuel Inventory	Daily	8.4.1

DATED: November 13, 1992

AMENDMENT NO. TO FACILITY OPERATING LICENSE NO. DPR-20-PALISADES

Docket File
NRC & Local PDRs
PDIII-1 Reading
Palisades Plant File
J. Roe
J. Zwolinski
L. Marsh
M. Shuttleworth
A. Masciantonio
IOGC-WF
D. Hagan, 3302 MNBB
G. Hill (4), P-137
Wanda Jones, MNBB-7103
C. Grimes, 11/F/23
ACRS (10)
GPA/PA
OC/LFMB
W. Shafer, R-III

cc: Plant Service list