

March 22, 2002

MEMORANDUM TO: Mark A. Cunningham, Chief **/RA/**
Probabilistic Risk Analysis Branch
Division of Risk Analysis & Applications
Office of Nuclear Regulatory Research

THRU: Mary T. Drouin, Section Leader **ASK for MTD /RA/**
Probabilistic Risk Analysis Branch
Division of Risk Analysis & Applications
Office of Nuclear Regulatory Research

FROM: Dean Overland **/RA/**
Probabilistic Risk Analysis Branch
Division of Risk Analysis & Applications
Office of Nuclear Regulatory Research

SUBJECT: SUMMARY OF FEBRUARY 5, 2002, PUBLIC MEETING WITH
INTERESTED STAKEHOLDERS REGARDING PRA QUALITY
AND STANDARDS AND RISK-INFORMED CHANGES TO
10 CFR 50.46

On February 5, 2002, a public meeting was held at NRC headquarters with interested stakeholders to provide and solicit feedback on (1) the staff's current ideas on endorsement of PRA standards and other guidance documents and the update to Regulatory Guide (RG) 1.174, and (2) the staff's efforts on risk-informing the ECCS reliability requirements of 10 CFR 50.46, specifically General Design Criterion (GDC) 35. A summary of the discussions on each of these areas is provided below. The viewgraphs for the staff presentations are available under ADAMS accession number ML020430010. Attachment 1 contains the list of attendees.

The staff plans to include the update of RG 1.174 as part of a Commission paper to be submitted in March 2002. Also included with the March Commission paper will be a plan for developing a new RG which will provide guidance to licensees on using PRA standards or industry peer review programs to determine the level of confidence in PRA insights/results so that they are appropriately used by decision-makers. Supporting appendices will provide staff endorsement of specific PRA standards (e.g., ASME) or industry programs (e.g., NEI-00-02). Industry representatives indicated that the staff's plan to develop the new RG seemed reasonable, but that the more important consideration was the details that would be contained in the new RG. Industry requested, and the staff agreed, that there be additional public meetings as work progressed on the new RG.

With respect to risk-informed changes to 10 CFR 50.46/GDC 35, the staff described its intention to revise GDC 35 to provide an alternative to demonstrate that ECCS safety function can be reliably accomplished using a more general reliability requirement, as opposed to the prescriptive requirements currently contained in GDC 35 (i.e., the assumptions of a coincident loss of offsite power [LOOP] and single additional failure). Two approaches to this proposal are

being considered: a plant-specific approach and a generic approach. In late March, the NRC intends to hold a public meeting, in which it will provide the technical basis for the plant-specific approach as well as provide the status of the generic approach. In the plant-specific approach, NRC-specified risk criteria would be used to assure acceptable ECCS reliability. The criteria to be used would be adapted from the Option 3 framework document and RG 1.174. In the generic approach, all plants would be grouped based on their ECCS (and support system) configurations, and each plant group would be assigned a minimal set of equipment necessary to meet the reliability goal. The practicality of the generic approach depends on the extent to which the plants can be grouped together (i.e., whether the number of plant groups can be kept reasonably small).

Substantial discussion between the staff and industry occurred at the meeting with regard to how the proposed ECCS reliability requirements would affect the ECCS thermal-hydraulic (T-H) performance calculations. Industry representatives stated that the primary benefits they were anticipating as a result of the risk-informed alternative to GDC 35 would derive from changes to the current failure assumptions for the ECCS T-H calculations. The staff responded that while the topic of the current meeting was specifically on the approach for assuring adequate ECCS reliability, the staff was also currently in the process of determining how the risk-informed ECCS reliability approach would interface with the ECCS T-H calculations. It was agreed that additional meetings, both internal staff and public, are necessary to resolve this issue.

Two other issues were principal sources of discussion: (1) the estimation of LOCA frequencies, and (2) the estimation of the conditional probability of a LOOP following, and as the result of, a large LOCA. NUREG/CR-5750 (February 1999) is the most recent source of LOCA frequencies; however, recent operational experience has raised some concerns over the appropriateness of these frequencies for the LOCA-LOOP application. The staff stated its intention to hold a separate meeting in the near future which would focus on the concerns with the LOCA frequency estimation contained in NUREG/CR-5750. An industry representative noted that EPRI also has a LOCA frequency database, which provides frequencies as a function of the number of pipe segments involved. Since the staff needs LOCA frequencies to support its near-term activities related to risk-informing GDC 35, it related that it is considering the possibility of an expert elicitation process in order to obtain reasonable bounding LOCA frequencies. Industry expressed a desire to be involved if an expert elicitation process were to be pursued. Representatives from both the Westinghouse Owners' Group (WOG) and Babcock and Wilcox Owners' Group (BWOG) indicated that their top concern related to the staff's efforts on risk-informing the ECCS reliability requirements was staff progress on the issue of LOCA frequencies. It was also commented by industry that many licensees have already used the NUREG/CR-5750 LOCA frequency values for updating their probabilistic risk assessments (PRAs). At the conclusion of the discussion on LOCA frequencies, an NEI representative related that a petition for rulemaking would be forthcoming in the next few days to amend 10 CFR Part 50 to allow the use of an alternative to the currently required double-ended rupture of the largest pipe in the reactor coolant system in ECCS evaluation models.

The principal concern associated with the issue of conditional LOOP given a large LOCA is the lack of a robust data sample. Since there have been no large LOCAs in the nuclear industry, the staff has proposed using conditional LOOP following major ECCS actuations as a surrogate. The staff indicated that data on conditional LOOP following standard reactor trips (i.e., without coincident ECCS actuation) do not represent a suitable surrogate for data on conditional LOOP following a large LOCA since these events impose less severe electrical

challenges to the plant, particularly with regard to the probability that safety bus voltage will drop to the undervoltage trip setpoints. It was generally agreed that the conditional LOOP probability obtained using major ECCS actuation data (~7E-2) probably represents an upper bound to the true conditional LOOP probability following a large LOCA, and that the conditional LOOP probability obtained using all reactor trip data (~3E-3) represents a lower bound. One meeting participant suggested the use of international data on conditional LOOP in order to expand the data sample. However, an EPRI representative countered that such data would probably not be representative of plants in the U.S. due to differences in grid reliability between countries. Recognizing the limitations of existing data, industry indicated their intention to explore alternatives for estimating the probability of conditional LOOP following a large LOCA. It was agreed that a follow-up public conference call or meeting should be scheduled to specifically address this issue.

A final issue discussed at the meeting involved what and how credit should be given to non-ECCS systems in demonstrating ECCS functional reliability. Since it is envisioned that CDF and LERF thresholds would be used for demonstrating adequate ECCS reliability, and most PRAs include credit for non-ECCS systems, consideration needs to be given to whether some limit on the crediting of these systems should be established for this application, and/or how credit for such systems should be accounted for in the ECCS T-H performance calculations. The staff noted that it is only in the preliminary stages of exploring this issue, and would provide more discussion on this topic at the next public meeting.

Attachment: List of Attendees

Distribution: See following page

DOCUMENT NAME: g:\meeting notices\05Feb02 mtg sum.wpd
 OAR in ADAMS? (Y or N) Y ADAMS ACCESSION NO.: _____ TEMPLATE NO. NRC-001
 Publicly Available? (Y or N) Y DATE OF RELEASE TO PUBLIC Immediate SENSITIVE? N
 *Previously concurred

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	DRAA/PRAB		DRAA/PRAB		DRAA/PRAB			
NAME	*DOverland DHO		*MDrouin ASK for MTD		MCunningham MAC			
DATE	2/12/2002		3/1/2002		3/22/2002			

(RES File Code) RES _____

Distribution:Hard Copy

Central Files
PRAB r/f

ACRS (M. Markley)
OGC (G. Mizuno)

M. Cunningham
M. Drouin

A. Kuritzky
D. Overland

Email

RES:	S. Newberry	NRR:	G. Holahan	NRR:	M. Snodderly
	F. Eltawila		J. Strosnider		M. Cheok
	M. Mayfield		D. Matthews		R. Elliott
	J. Rosenthal		F. Gillespie		T. Reed
	N. Chokshi		C. Carpenter		J. Donoghue
	S. Bajorek		R. Barrett		P. Wen
	N. Lauben		J. Wermiel		F. Orr
	R. Meyer		K. Wichman		R. Caruso
	E. Hackett		M. Rubin		U. Shoop
	C. Fairbanks		F. Akstulewicz		G. Parry
	J. Vora		S. West		E. McKenna
	A. Notafrancesco		S. Lee (ssl)		
	S. Weerakkody		S. Magruder	NMSS:	L. Kokajko
	W. Raughley		J. Lazevnick		
	L. Abramson		G. Kelly		
	J. Lane		M. Mitchell		

G. Martinez-Guridi, BNL
J. Lehner, BNL

A. Camp, SNL
J. LaChance, SNL

E. Haskin, ERI
A. Heymer, NEI

OPA

LIST OF PARTICIPANTS PRA QUALITY AND STANDARDS AND RISK-INFORMED CHANGES TO 10 CFR 50.46 FEBRUARY 5, 2002			
Name	Title	Telephone	Organization
Lee Abramson	Sr. Res. Statistician	(301) 415-6180	NRC/RES/DRAA/PRAB
Biff Bradley	Sr. Project Manager	(202) 739-8083	NEI
Cindi Carpenter	Program Director	(301) 415-1282	NRC/NRR/DRIP/RGEB
Ralph Caruso	Section Chief	(301) 415-1813	NRC/NRR/DSSA/SRXB
Nancy Chapman	SERCH Manager	(301) 228-6025	SERCH/Bechtel
Mary Drouin	Section Chief	(301) 415-6675	NRC/RES/DRAA/PRAB
Carolyn Fairbanks	Materials Engineer	(301) 415-6719	NRC/RES/DET/MEB
David Finnicum	Risk Analyst	(860) 731-6440	Westinghouse
John Gaertner	Tech. Specialist	(704) 547-6169	EPRI
Adrian Heymer	Project Manager	(202) 739-8094	NEI
Rick Hill	Sr. Tech. Proj. Mgr.	(408) 925-5388	GE
Roger Huston	Principal	(703) 671-9738	Licensing Support Services
Glenn Kelly	Sr. Rel. and Risk Anal.	(301) 415-1075	NRC/NRR/DSSA/SPSB
Michael Knapik	Editor	(202) 383-2167	McGraw-Hill
Lawrence Kokajko	Section Chief	(301) 415-7275	NRC/NMSS/RTG
Alan Kuritzky	Sr. Rel. and Risk Eng.	(301) 415-6255	NRC/RES/DRAA/PRAB
John C. Lane	Sr. Rel. and Risk Eng.	(301) 415-6442	NRC/RES/DRAA/PRAB
Jim Lazevnick	Sr. Electrical Engineer	(301) 415-2782	NRC/NRR/DE/EEIB
Samuel Lee	Project Manager	(301) 415-1061	NRC/NRR/DRIP/RGEB
Stanley Levinson	Advisory Engineer	(434) 832-2768	Framatone ANP
Stu Magruder	Sr. Project Manager	(301) 415-3139	NRC/NRR/DRIP/RGEB
Mike Markley	Sr. Staff Engineer	(301) 415-6885	ACRS
Gerardo Martinez-Guridi	Research Engineer I	(631) 344-7907	Brookhaven National Laboratory

LIST OF PARTICIPANTS
PRA QUALITY AND STANDARDS AND RISK-INFORMED CHANGES TO 10 CFR 50.46
FEBRUARY 5, 2002

Name	Title	Telephone	Organization
Eileen McKenna	Sr. Reactor Engineer	(301) 415-2189	NRC/NRR/DRIP/RGEB
David Miskiewicz	PRA Engineer	(352) 795-6486	Progress Energy/BWOG
Matthew Mitchell	Sr. Materials Engineer	(301) 415-3303	NRC/NRR/DE/EMCB
Scott Newberry	Director	(301) 415-5790	NRC/RES/DRAA
Frank Orr	Engineer	(301) 415-1815	NRC/NRR/DSSA/SRXB
Bob Osterrieder	Supervisory Engineer	(412) 374-5173	WOG/Westinghouse
Dean Overland	Rel. and Risk Eng.	(301) 415-6702	NRC/RES/DRAA/PRAB
Gareth Parry	Sr. Advisor (PSA)	(301) 415-1464	NRC/NRR/DSSA
Terry Pickens	Mgr, Regulatory Services	(715) 377-3390	Nuclear Management Co.
Deann Raleigh	LIS, Client Manager	(301) 258-2551	LIS, Scientech
Terry Rieck	Senior Manager	(630) 657-2194	Exelon/BWROG
Mark Rubin	Section Chief	(301) 415-3234	NRC/NRR/DSSA/SPSB
Undine Shoop	Reactor Systems Eng.	(301) 415-2063	NRC/NRR/DSSA/SRXB
Barry Sloane	Supervisory Engineer	(412) 374-4047	Westinghouse
Doug True	Vice-President	(925) 943-7077	ERIN
Jared Wermiel	Branch Chief	(301) 415-2895	NRC/NRR/DSSA/SRXB
Steve West	Section Chief	(301) 415-1220	NRC/NRR/DRIP/RGEB
Yi Zeng	Risk Assessment Spec.	(613) 992-8329	CNSC