

April 12, 1989

Docket Nos. 50-454 and 50-455,  
50-465, and 50-457

Mr. Henry E. Bliss  
Nuclear Licensing Manager  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dear Mr. Bliss:

The Commission has filed the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing" with the Office of the Federal Register for publication. The notice relates to your request of March 17, 1989, to amend the Technical Specifications to Operating Licenses NPF-37 and NPF-66 for Byron Station, Units 1 and 2, and NPF-72 and NPF-77 for Braidwood Station, Units 1 and 2. The amendments would revise Technical Specification 4.5.2 to modify the surveillance requirements for venting of ECCS equipment.

151

Daniel R. Muller, Director  
Project Directorate III-2  
Division of Reactor Projects - III,  
IV, V and Special Projects

Enclosures:  
As stated

cc: w/enclosures:  
See next page

DISTRIBUTION

Docket File	PDIII-2 Rdg.
NRC & Local PDRs	LLuther
LOlshan	SSands
OGC-Rockville	DHagan
ACRS (10)	PDIII-2 Plant File

*m m.*

8904240217 890412  
PDR ADOCK 05000454  
PDC

PDIII-2:PM LOlshan: km 4/10/89	PDIII-2:PM for SSands 4/10/89
--------------------------------------	-------------------------------------

PDIII-2:LA  
LLuther  
4/12/89

PDIII-2:PD  
DMuller  
4/12/89

*[Handwritten signature]*  
DFOL  
111

April 12, 1989

Docket Nos. 50-454 and 50-455,  
50-465, and 50-457

Mr. Henry E. Bliss  
Nuclear Licensing Manager  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dear Mr. Bliss:

The Commission has filed the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing" with the Office of the Federal Register for publication. The notice relates to your request of March 17, 1989, to amend the Technical Specifications to Operating Licenses NPF-37 and NPF-66 for Byron Station, Units 1 and 2, and NPF-72 and NPF-77 for Braidwood Station, Units 1 and 2. The amendments would revise Technical Specification 4.5.2 to modify the surveillance requirements for venting of ECCS equipment.

151

Daniel R. Muller, Director  
Project Directorate III-2  
Division of Reactor Projects - III,  
IV, V and Special Projects

Enclosures:  
As stated

cc: w/enclosures:  
See next page

DISTRIBUTION


Docket File	PDIII-2 Rdg.
NRC & Local PDRs	LLuther
LOIshan	SSands
OGC-Rockville	DHagan
ACRS (10)	PDIII-2 Plant File

PDIII-2:PM  
LOIshan: km  
4/12/89

PDIII-2:PM  
SSands  
4/12/89

PDIII-2:LA  
LLuther  
4/12/89

PDIII-2:PD  
DMuller  
4/12/89





UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555  
April 12, 1989

Docket Nos. 50-454 and 50-455,  
50-465, and 50-457

Mr. Henry E. Bliss  
Nuclear Licensing Manager  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dear Mr. Bliss:

The Commission has filed the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing" with the Office of the Federal Register for publication. The notice relates to your request of March 17, 1989, to amend the Technical Specifications to Operating Licenses NPF-37 and NPF-66 for Byron Station, Units 1 and 2, and NPF-72 and NPF-77 for Braidwood Station, Units 1 and 2. The amendments would revise Technical Specification 4.5.2 to modify the surveillance requirements for venting of ECCS equipment.

A handwritten signature in cursive script that reads "Daniel R. Muller".

Daniel R. Muller, Director  
Project Directorate III-2  
Division of Reactor Projects - III,  
IV, V and Special Projects

Enclosures:  
As stated

cc: w/enclosures:  
See next page

UNITED STATES NUCLEAR REGULATORY COMMISSION  
COMMONWEALTH EDISON COMPANY  
DOCKET NOS. 50-454, 50-455, 50-456, AND 50-457  
NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT  
TO FACILITY OPERATING LICENSE AND  
OPPORTUNITY FOR HEARING

The U. S. Nuclear Regulatory Commission (Commission) is considering issuance of amendment to Facility Operating License Nos. NPF-37 and NPF-66, issued to the Commonwealth Edison (the licensee), for operation of the Byron Station, Units 1 and 2 located in Ogle County, Illinois, and Facility Operating License Nos. NPF-72 and NPF-77, issued to the licensee for operation of Braidwood Station, Units 1 and 2, located in Will County, Illinois.

The amendments would change Technical Specification 4.5.2 to modify the surveillance requirements for venting of Emergency Core Cooling System (ECCS) equipment.

Prior to issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulation.

By May 22, 1989, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and petitions for leave to intervene. Requests for a hearing and petitions for leave to intervene shall be filed in accordance with the

Commission's "Rules of Practices for Domestic Licensing Proceedings" in 10 CFR Part 2. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition, and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR §2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any other which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter, and the bases for each

contention set forth with reasonable specificity. Contentions shall be limited to matters within the scope of the amendment under consideration. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene shall be filed with the Secretary of the Commission, United States Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Branch, or may be delivered to the Commission's Public Document Room, Gelman Building, 2120 L Street, N.W., Washington, D.C., by the above date. Where petitions are filed during the last ten (10) days of the notice period, it is requested that the petitioner or representative for the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-800-325-6000 (in Missouri 1-800-342-6700). The Western Union operator should be given Datagram Identification Number 3737 and the following message addressed to Daniel R. Muller: petitioner's name and telephone number; date petition was mailed; plant name; and publication date and page number of this FEDERAL REGISTER notice. A copy of the petition should also be sent to the Office of General Counsel, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, and to Michael Miller, Esq., Sidley and Austin, One First National Plaza, Chicago, Illinois 60603, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or request for hearing will not be entertained absent a determination by the Commission, the presiding officer to the presiding Atomic Safety and Licensing Board, that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendment dated March 17, 1989, which is available for public inspection at the Commission's Public Document Room, Gelman Building, 2120 L Street, N.W., Washington, D.C. 20555, and at the Rockford Public Library, 215 N. Wyman Street, Rockford, Illinois 61101; and the Wilmington Township Public Library, 201 S. Kankakee Street, Wilmington, Illinois 60481.

Dated at Rockville Maryland this 12th day of April 1989.

FOR THE NUCLEAR REGULATORY COMMISSION



Daniel R. Muller, Director  
Project Directorate III-2  
Division of Reactor Projects - III,  
IV, V and Special Projects