

March 29, 2002

MEMORANDUM TO: Stuart A. Richards, Director
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

FROM: Jack Cushing, Project Manager, Section 2 **/RA/**
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: MEETING WITH WESTINGHOUSE ELECTRIC COMPANY (W) - OPEN
ITEMS FOR TOPICAL REPORT CENPD-396-P, "COMMON QUALIFIED
PLATFORM"

On February 6, 2002, a public meeting was held at the NRC Headquarters in Rockville, Maryland, between representatives from W and the NRC staff. The purpose of the meeting was to discuss the closeout of generic open items related to Westinghouse Topical Report (TR) CENPD-396-P, "Common Qualified Platform" (Common Q). A list of attendees is attached.

Mark Stofko started the formal presentations by giving an overview of the Common Q open items and current status. He also presented an overview of the status of the near-term Common Q applications, Palo Verde's core protection calculator and Calvert Cliffs post accident monitoring system. The NRC staff was in agreement that generic open items 7.1, 7.2, 7.3, 7.5 and 7.6 could be closed with completion and review of the equipment qualification (EQ) program.

Marty Ryan presented an overview of the Common Q equipment design and qualification testing activities that have taken place to address resolution of the generic open issues. The presentation included an in-depth discussion of new equipment designed to address the flat panel display system, power supply system and the new analog input module. Discussions on the equipments' reactions to the seismic, environmental and electro-magnetic interference (EMI) induced loads test were also addressed. He concluded his presentation by stating that the generic equipment qualification issues for Common Q have been successfully addressed and that Westinghouse would be providing a letter in the near future that would provide NRC a summary of the testing program. That letter would be the W basis for closure of the generic open items.

Denny Popp presented a proposed process for addressing changes on the Common Q TR. After considerable discussion on the issue, the NRC requested that all significant changes be identified to NRC for approval.

Project No. 700

Attachment: Meeting Attendees

cc w/att:

Mr. Charles B. Brinkman, Director
Washington Operations
Westinghouse Electric Company
12300 Twinbrook Parkway, Suite 330
Rockville, MD 20852

Mr. Philip W. Richardson, Manager
Windsor Nuclear Licensing
Westinghouse Electric Company
Mail Stop 126009 - 1901
2000 Day Hill Road
Windsor, CT 06095-0500

Denny Popp presented a proposed process for addressing changes on the Common Q TR. After considerable discussion on the issue, the NRC requested that all significant changes be identified to NRC for approval.

Project No. 700

Attachment: Meeting Attendees

cc w/att:

Mr. Charles B. Brinkman, Director
Washington Operations
Westinghouse Electric Company
12300 Twinbrook Parkway, Suite 330
Rockville, MD 20852

Mr. Philip W. Richardson, Manager
Windsor Nuclear Licensing
Westinghouse Electric Company
Mail Stop 126009 - 1901
2000 Day Hill Road
Windsor, CT 06095-0500

DISTRIBUTION:

PUBLIC
PDIV-2 R/F
RidsNrrDlpm (JZwolinski/TMarsh)
SDembek
JCushing (RidsNrrPMJCushing)
RidsNrrLAEPeyton
RidsOgcMailCenter
RidsAcrcAcnwMailCenter
MChiramal
CGraham
KMortensen
AMarinos

Meeting Notice: ML020240187

Package: ML020850064

Adams Accession No:

ML020850034

NRC-001

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	JCushing:as	EPeyton	S. Dembek
DATE	3/28/02	3/28/02	3/29/02

OFFICIAL RECORD COPY

ATTENDANCE LIST FOR

MEETING BETWEEN NRC AND WESTINGHOUSE ON COMMON QUALIFIED PLATFORM

FEBRUARY 6, 2002

WESTINGHOUSE

Marty Ryan
Mark Stofko
Dennis Popp

NRC

Jack Cushing
Keith Mortensen
Angelo Marinos
Matt Chiramal
Chris Graham