

From: Sunil Weerakkody ^{RES}
To: Patrick O'Reilly, ^{RES} Steven Long ^{NRR}
Date: 1/8/01 8:10AM
Subject: Re: Combination of IP2 LOSP and SGTR Events

Steve (Long):

As you have mentioned in your e-mail, I have assessed the significance of the degraded steam generator tube rupture when IP-2 lost power to its safety-related buses on August 31, 1999. I have concluded that the impact of the degraded tube on the CCDP was small compared to the CCDP of $6.4E-05$ of this event. (Please note my conclusion and its basis are still undergoing review per our ASP process).

As you have indicated in your e-mail, we do not calculate the CLERP in the ASP program.

-Sunil

CC: Dgm2, James Trapp, Richard Barrett, sem1

X/23