

Howard W. Bergendahl
Vice President - Nuclear419-321-8588
Fax: 419-321-8337

Docket Number 50-346

License Number NPF-3

Serial Number 2771

March 22, 2002

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555-0001Subject: Davis-Besse Nuclear Power Station Technical Specification 4.4.5.5a Report of Steam
Generator Tube Plugging

Ladies and Gentlemen:

This letter is submitted in accordance with the requirements of the Davis-Besse Nuclear Power Station (DBNPS) Unit Number 1, Operating License, Appendix A, Technical Specifications. Technical Specification 4.4.5.5a requires FirstEnergy Nuclear Operating Company (FENOC) to report to the Nuclear Regulatory Commission (NRC) the number of tubes plugged in each steam generator (SG) following each inservice inspection of steam generator tubes.

The Thirteenth Refueling Outage SG tube inservice inspection was completed on March 9, 2002. As a result of the inspection findings and outage activities, 57 tubes were plugged in SG 1-1 and 126 tubes were plugged in SG 1-2. There were 8 tube-to-tubesheet rerolls installed in the SG 1-1 upper tubesheet and 32 tube-to-tubesheet rerolls installed in the SG 1-2 upper tubesheet. No sleeves were installed.

Should you have any questions or require additional information, please contact Mr. David H. Lockwood, Manager - Regulatory Affairs, at (419) 321-8450.

Very truly yours,



MAR

A001

Docket Number 50-346
License Number NPF-3
Serial Number 2771
Page 2

Enclosure

cc: J. E. Dyer, Regional Administrator, NRC Region III
S. P. Sands, DB-1 NRC/NRR Project Manager
C. S. Thomas, DB-1 NRC Senior Resident Inspector
Utility Radiological Safety Board

Docket Number 50-346
License Number NPF-3
Serial Number 2771
Enclosure 1

COMMITMENT LIST

THE FOLLOWING LIST IDENTIFIES THOSE ACTIONS COMMITTED TO BY THE DAVIS-BESSE NUCLEAR POWER STATION (DBNPS) IN THIS DOCUMENT. ANY OTHER ACTIONS DISCUSSED IN THE SUBMITTAL REPRESENT INTENDED OR PLANNED ACTIONS BY THE DBNPS. THEY ARE DESCRIBED ONLY FOR INFORMATION AND ARE NOT REGULATORY COMMITMENTS. PLEASE NOTIFY THE MANAGER – REGULATORY AFFAIRS (419-321-8450) AT THE DBNPS OF ANY QUESTIONS REGARDING THIS DOCUMENT OR ANY ASSOCIATED REGULATORY COMMITMENTS.

Commitment

Due Date

None

N/A