

April 4, 2002

MEMORANDUM TO: Biweekly Notice Coordinator

FROM: Jon B. Hopkins, Senior Project Manager, Section 2 */RA/*  
Project Directorate III  
Division of Licensing Project Management

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE -  
NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY  
OPERATING LICENSE (TAC NO. MB2053)

AmerGen Energy Company, LLC, Docket No. 50-461, Clinton Power Station, Unit 1, DeWitt  
County, Illinois

Date of application for amendment: May 21, 2001

Brief description of amendment: The amendment revises the actions required if the refueling equipment interlocks become inoperable. The additional request in the application to revise the frequency of the refueling equipment interlock inputs channel functional test from 7 to 31 days is not included in the issued amendment and will be addressed by separate correspondence.

Date of issuance: April 4, 2002

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment No.: 148

Facility Operating License No. NPF-62: The amendment revised the Technical Specifications.

Date of initial notice in FEDERAL REGISTER: December 26, 2001 (66 FR 66463)

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 4, 2002.

No significant hazards consideration comments received: No.

April 4, 2002

MEMORANDUM TO: Biweekly Notice Coordinator

FROM: Jon B. Hopkins, Senior Project Manager, Section 2 /RA/  
Project Directorate III  
Division of Licensing Project Management

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE -  
NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY  
OPERATING LICENSE (TAC NO. MB2053)

AmerGen Energy Company, LLC, Docket No. 50-461, Clinton Power Station, Unit 1, DeWitt  
County, Illinois

Date of application for amendment: May 21, 2001

Brief description of amendment: The amendment revises the actions required if the  
refueling equipment interlocks become inoperable. The additional request in the application  
to revise the frequency of the refueling equipment interlock inputs channel functional test  
from 7 to 31 days is not included in the issued amendment and will be addressed by  
separate correspondence.

Date of issuance: April 4, 2002

Effective date: As of the date of issuance and shall be implemented within 30 days.

Amendment No.: 148

Facility Operating License No. NPF-62: The amendment revised the Technical  
Specifications.

Date of initial notice in FEDERAL REGISTER: December 26, 2001 (66 FR 66463)

The Commission's related evaluation of the amendment is contained in a Safety Evaluation  
dated April 4, 2002.

No significant hazards consideration comments received: No.

DISTRIBUTION:  
Non-Public  
PD3-2 R/F

**ADAMS ACCESSION NUMBER: ML020850588**

<b>OFFICE</b>	<b>PM:PD3-2</b>	<b>LA:PD3-2</b>	<b>OGC</b>	<b>SC:PD3-2</b>
<b>NAME</b>	<b>JHopkins</b>	<b>THarris</b>	<b>AHodgon</b>	<b>AMendiola</b>
<b>DATE</b>	<b>03/14/02</b>	<b>01/02/02</b>	<b>03/19/02</b>	<b>04/04/02</b>

OFFICIAL RECORD COPY