

June 30, 1994

Docket Nos. STN 50-454, STN 50-455
and STN 50-456, STN 50-457

Mr. D. L. Farrar
Manager, Nuclear Regulatory Services
Commonwealth Edison Company
Executive Towers West III, Suite 500
1400 OPUS Place
Downers Grove, Illinois 60515

DISTRIBUTION:
NRC & Local PDRs
J. Roe
R. Capra
R. Assa
OGC
G. Hill (8)
C. Grimes
OPA

PDIII-2 p/f
Docket File
J. Zwolinski
G. Dick
C. Hawes
D. Hagan
B. Clayton RIII
ACRS (10)
OC/LFDCB

Dear Mr. Farrar:

The Commission has issued the enclosed Amendment No. 62 to Facility Operating License No. NPF-37 and Amendment No. 62 to Facility Operating License No. NPF-66 for the Byron Station, Unit Nos. 1 and 2, respectively, and Amendment No. 52 to Facility Operating License No. NPF-72 and Amendment No. 52 to Facility Operating License No. NPF-77 for the Braidwood Station, Unit Nos. 1 and 2, respectively. The amendments are in response to your application dated March 7, 1994, as superseded by your submittal dated March 24, 1994.

The amendments change Technical Specification (TS) 4.6.1.2, "Containment Leakage," by removing the specific requirement that containment Type A leak testing be performed at 40 ± 10 month intervals. The revised TS now references Appendix J to 10 CFR 50 as governing the performance of Type A testing.

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by:

George F. Dick, Jr., Project Manager
Project Directorate III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

9407080216 940630
PDR ADOCK 05000454
P PDR

Enclosures:

1. Amendment No. 62 to NPF-37
2. Amendment No. 62 to NPF-66
3. Amendment No. 52 to NPF-72
4. Amendment No. 52 to NPF-77
5. Safety Evaluation

cc w/enclosures:
See next page

NRC FILE CENTER COPY

OFC	LA:PDIII-2	I:PDIII-2	PM:PDIII-2	PM:PDIII-2	D:SCSB	D:OTSB
NAME	CHAWES <i>cmh</i>	HAWSON <i>ASO</i>	GDICK <i>gdick</i>	RASSA <i>ra</i>	RBARRETT	CGRIMES
DATE	6/3/94	6/3/94	6/10/94	6/10/94	6/17/94	6/17/94
COPY	(YES/NO)	(YES/NO)	(YES/NO)	(YES/NO)	YES/NO	YES/NO
OFC	OGC <i>C. Marco</i>	D:PDIII-2				
NAME	<i>CLM</i>	RCAPRA <i>Roe</i>				
DATE	6/14/94	6/29/94	1/94	1/94	1/94	1/94
COPY	YES/NO	(YES/NO)	YES/NO	YES/NO	YES/NO	YES/NO

DFD 2-1

Mr. D. L. Farrar
Commonwealth Edison Company

cc:

Mr. William P. Poirier
Westinghouse Electric Corporation
Energy Systems Business Unit
Post Office Box 355, Bay 236 West
Pittsburgh, Pennsylvania 15230

Joseph Gallo
Gallo & Ross
1250 Eye St., N.W., Suite 302
Washington, D.C. 20005

Regional Administrator
U. S. NRC, Region III
801 Warrenville Road
Lisle, Illinois 6013

Ms. Bridget Little Rorem
Appleseed Coordinator
117 North Linden Street
Essex, Illinois 60935

Mr. Edward R. Crass
Nuclear Safeguards and Licensing
Division
Sargent & Lundy Engineers
55 East Monroe Street
Chicago, Illinois 60603

U. S. Nuclear Regulatory Commission
Resident Inspectors Office
Rural Route #1, Box 79
Braceville, Illinois 60407

Mr. Ron Stephens
Illinois Emergency Services
and Disaster Agency
110 East Adams Street
Springfield, Illinois 62706

Howard A. Learner
Environmental Law and Policy
Center of the Midwest
203 North LaSalle Street
Suite 1390
Chicago, Illinois 60601

EIS Review Coordinator
U.S. Environmental Protection Agency
77 W. Jackson Blvd.
Chicago, Illinois 60604-3590

Chairman
Will County Board of Supervisors
Will County Board Courthouse
Joliet, Illinois 60434

Byron/Braidwood Power Stations

U. S. Nuclear Regulatory Commission
Byron/Resident Inspectors Office
4448 North German Church Road
Byron, Illinois 61010-9750

Ms. Lorraine Creek
Rt. 1, Box 182
Manteno, Illinois 60950

Mrs. Phillip B. Johnson
1907 Stratford Lane
Rockford, Illinois 61107

Attorney General
500 South 2nd Street
Springfield, Illinois 62701

Michael Miller, Esquire
Sidley and Austin
One First National Plaza
Chicago, Illinois 60690

George L. Edgar
Newman & Holtzinger, P.C.
1615 L Street, N.W.
Washington, D.C. 20036

Commonwealth Edison Company
Byron Station Manager
4450 North German Church Road
Byron, Illinois 61010

Illinois Dept. of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Commonwealth Edison Company
Braidwood Station Manager
Rt. 1, Box 84
Braceville, Illinois 60407

Chairman, Ogle County Board
Post Office Box 357
Oregon, Illinois 61061



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555-0001

COMMONWEALTH EDISON COMPANY

DOCKET NO. STN 50-454

BYRON STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 62
License No. NPF-37

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated March 7, 1994, as superceeded on March 24, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-37 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 62 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra

Robert A. Capra, Director
Project Directorate III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 30, 1994



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

COMMONWEALTH EDISON COMPANY

DOCKET NO. STN 50-455

BYRON STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 62
License No. NPF-66

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated March 7, 1994, as superceded on March 24, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public;
and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-66 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A (NUREG-1113), as revised through Amendment No. 62 and revised by Attachment 2 to NPF-66, and the Environmental Protection Plan contained in Appendix B, both of which were attached to License No. NPF-37, dated February 14, 1985, are hereby incorporated into this license. Attachment 2 contains a revision to Appendix A which is hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra

Robert A. Capra, Director
Project Directorate III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 30, 1994

ATTACHMENT TO LICENSE AMENDMENT NOS. 62 AND 62

FACILITY OPERATING LICENSE NOS. NPF-37 AND NPF-66

DOCKET NOS. STN 50-454 AND STN 50-455

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

Remove Pages

3/4 6-2

3/4 6-3

Insert Pages

3/4 6-2

3/4 6-3

CONTAINMENT SYSTEMS

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of:
 - 1) Less than or equal to L_a , 0.10% by weight of the containment air per 24 hours at P_a , 44.4 psig, or
 - 2) Less than or equal to L_t , 0.07% by weight of the containment air per 24 hours for Unit 1 (0.07% by weight of the containment air per 24 hours for Unit 2) at P_t , 22.2 psig.
- b. A combined leakage rate of less than $0.60 L_a$ for all penetrations and valves subject to Type B and C tests, when pressurized to P_a .

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With either the measured overall integrated containment leakage rate exceeding $0.75 L_a$ or $0.75 L_t$, as applicable, or the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding $0.60 L_a$, restore the overall integrated leakage rate to less than $0.75 L_a$ or less than $0.75 L_t$, as applicable, and the combined leakage rate for all penetrations subject to Type B and C tests to less than $0.60 L_a$ prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR Part 50 using the methods and provisions of ANSI N45.4-1972:

- a. Type A (Overall Integrated Containment Leakage Rate) testing shall be conducted in accordance with the requirements specified in Appendix J to 10 CFR 50, as modified by approved exemptions;

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- b. If any periodic Type A test fails to meet either $0.75 L_a$ or $0.75 L_t$, the test schedule for subsequent Type A tests shall be reviewed and approved by the Commission. If two consecutive Type A tests fail to meet $0.75 L_a$, a Type A test shall be performed at least every 18 months until two consecutive Type A tests meet $0.75 L_a$;
- c. The accuracy of each Type A test shall be verified by a supplemental test which:
 - 1) Confirms the accuracy of the test by verifying that the supplemental test result, L_c , minus the sum of the Type A and the superimposed leak, L_o , is equal to or less than $0.25 L_a$ or $0.25 L_t$;
 - 2) Has a duration sufficient to establish accurately the change in leakage rate between the Type A test and the supplemental test; and
 - 3) Requires that the rate at which gas is injected into the containment or bled from the containment during the supplemental test is between $0.75 L_a$ and $1.25 L_a$.
- d. Type B and C tests shall be conducted with gas at a pressure not less than P_a , 44.4 psig, at intervals no greater than 24 months except for tests involving:
 - 1) Air locks, and
 - 2) Purge supply and exhaust isolation valves with resilient material seals.
- e. Air locks shall be tested and demonstrated OPERABLE by the requirements of Specification 4.6.1.3;
- f. Purge supply and exhaust isolation valves with resilient material seals shall be tested and demonstrated OPERABLE by the requirements of Specification 4.6.1.7.3 or 4.6.1.7.4, as applicable; and
- g. The provisions of Specification 4.0.2 are not applicable.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

COMMONWEALTH EDISON COMPANY

DOCKET NO. STN 50-456

BRAIDWOOD STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 52
License No. NPF-72

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated March 7, 1994, as superceded on March 24, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-72 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 52 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra

Robert A. Capra, Director
Project Directorate III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 30, 1994



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

COMMONWEALTH EDISON COMPANY
DOCKET NO. STN 50-457
BRAIDWOOD STATION, UNIT NO. 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 52
License No. NPF-77


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated March 7, 1994, as superceded on March 24, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-77 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 52 and the Environmental Protection Plan contained in Appendix B, both of which were attached to License No. NPF-72, dated July 2, 1987, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director
Project Directorate III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 30, 1994

ATTACHMENT TO LICENSE AMENDMENT NOS. 52 AND 52
FACILITY OPERATING LICENSE NOS. NPF-72 AND NPF-77
DOCKET NOS. STN 50-456 AND STN 50-457

Replace the following pages of the Appendix "A" Technical Specifications with the attached pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change.

Remove Pages

3/4 6-2

3/4 6-3

Insert Pages

3/4 6-2

3/4 6-3

CONTAINMENT SYSTEMS

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of:
 - 1) Less than or equal to L_a , 0.10% by weight of the containment air per 24 hours at P_a , 44.4 psig, or
 - 2) Less than or equal to L_t , 0.07% by weight of the containment air per 24 hours for Unit 1 (0.07% by weight of the containment air per 24 hours for Unit 2) at P_t , 22.2 psig.
- b. A combined leakage rate of less than $0.60 L_a$ for all penetrations and valves subject to Type B and C tests, when pressurized to P_a .

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With either the measured overall integrated containment leakage rate exceeding $0.75 L_a$ or $0.75 L_t$, as applicable, or the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding $0.60 L_a$, restore the overall integrated leakage rate to less than $0.75 L_a$ or less than $0.75 L_t$, as applicable, and the combined leakage rate for all penetrations subject to Type B and C tests to less than $0.60 L_a$ prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR Part 50 using the methods and provisions of ANSI N45.4-1972:

- a. Type A (Overall Integrated Containment Leakage Rate) testing shall be conducted in accordance with the requirements specified in Appendix J to 10 CFR 50, as modified by approved exemptions;

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

b. If any periodic Type A test fails to meet either $0.75 L_a$ or $0.75 L_t$, the test schedule for subsequent Type A tests shall be reviewed and approved by the Commission. If two consecutive Type A tests fail to meet either $0.75 L_a$ or $0.75 L_t$, a Type A test shall be performed at least every 18 months until two consecutive Type A tests meet either $0.75 L_a$ or $0.75 L_t$;

c. The accuracy of each Type A test shall be verified by a supplemental test which:

1) Confirms the accuracy of the test by verifying that the supplemental test result, L_c , is in accordance with the appropriate following equation:

$$|L_c - (L_{am} + L_o)| \leq 0.25 L_a \text{ or } |L_c - (L_{tm} + L_o)| \leq 0.25 L_t$$

where L_{am} or L_{tm} is the measured Type A test leakage and L_o is the superimposed leak;

2) Has a duration sufficient to establish accurately the change in leakage rate between the Type A test and the supplemental test; and

3) Requires that the rate at which gas is injected into the containment or bled from the containment during the supplemental test is between $0.75 L_a$ and $1.25 L_a$, or $0.75 L_t$ and $1.25 L_t$.

d. Type B and C tests shall be conducted with gas at a pressure not less than P_a , 44.4 psig, at intervals no greater than 24 months except for tests involving:

1) Air locks, and

2) Purge supply and exhaust isolation valves with resilient material seals.

e. Air locks shall be tested and demonstrated OPERABLE by the requirements of Specification 4.6.1.3;

f. Purge supply and exhaust isolation valves with resilient material seals shall be tested and demonstrated OPERABLE by the requirements of Specification 4.6.1.7.3 or 4.6.1.7.4, as applicable; and

g. The provisions of Specification 4.0.2 are not applicable.



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 62 TO FACILITY OPERATING LICENSE NO. NPF-37,
AMENDMENT NO. 62 TO FACILITY OPERATING LICENSE NO. NPF-66,
AMENDMENT NO. 52 TO FACILITY OPERATING LICENSE NO. NPF-72,
AND AMENDMENT NO. 52 TO FACILITY OPERATING LICENSE NO. NPF-77
COMMONWEALTH EDISON COMPANY
BYRON STATION, UNIT NOS. 1 AND 2
BRAIDWOOD STATION, UNIT NOS. 1 AND 2
DOCKET NOS. STN 50-454, STN 50-455, STN 50-456 AND STN 50-457

1.0 INTRODUCTION

By submittal dated March 7, 1994, as superseded by a submittal dated March 24, 1994, the Commonwealth Edison Company (CECo or the licensee) submitted a request for an amendment to the operating licenses of Byron Nuclear Station, Units 1 and 2, and Braidwood Nuclear Station, Units 1 and 2. The proposed amendments would revise Byron and Braidwood Technical Specification (TS) 4.6.1.2 by deleting the schedular requirements for Type A containment integrated leakage rate (ILRT) tests to be performed at 40 ± 10 month intervals. The changed TS would instead reference Type A testing in accordance with Appendix J to 10 CFR 50. The proposed amendments would also include a minor editorial change.

2.0 BACKGROUND

The TS for Byron and Braidwood currently require that a set of three Type A ILRTs be performed specifically at 40 ± 10 month intervals during each 10-year service period, with the third test of each set to be performed during the shutdown for the 10-year plant inservice inspection. Appendix J to 10 CFR 50 requires that a set of three Type A tests be conducted at approximately equal intervals during the 10-year service period, and also requires that the performance of the third test coincide with the shutdown for the 10-year plant inservice inspection.

While the testing frequency requirements in the Byron and Braidwood TSs essentially duplicate those in Appendix J to 10 CFR 50, the TS specifically require that testing be done at 40 ± 10 month intervals. The licensee states that for Byron, Units 1 and 2, the current 18 month fuel cycle would make it difficult to conduct the third test within the required 40 ± 10 month interval and still have it coincide with the 10-year inservice inspection outages.

CECo further states that the time intervals for testing are currently met by Braidwood, Units 1 and 2, but requests changes to maintain consistency with the Byron TS and to eliminate any future need for a TS change as a result of revisions to Appendix J. Therefore, the licensee proposes to revise the TS by deleting the detailed surveillance schedule for Type A tests and instead reference the performance of Type A testing in accordance with Appendix J to 10 CFR 50.

3.0 TECHNICAL SPECIFICATION CHANGES

TS Surveillance Requirement 4.6.1.2.a would be revised by removing the requirement that Type A tests be conducted at 40 ± 10 month intervals with the third test being conducted during the shutdown for the 10-year inservice inspection. The revised Surveillance Requirement would read as follows:

"Type A (Overall Integrated Containment Leakage Rate) testing shall be conducted in accordance with the requirements specified in Appendix J to 10 CFR 50, as modified by approved exemptions."

In addition, TS Surveillance Requirement 4.6.1.2.b would be modified by deleting the reference to the testing schedule referenced in the unrevised version of Surveillance Requirement 4.6.1.2.a. This change is editorial in nature.

4.0 EVALUATION

Satisfactory leakage results are a requirement for the establishment of containment operability. Neither the general frequency nor the required number of Type A tests would be changed by the proposed revisions. Also, the maximum allowable leakage rate at the calculated peak containment pressure would not be changed. Only the detailed 40 ± 10 month test interval would be changed to provide more flexibility. Type A, B, and C tests would continue to be performed in accordance with Appendix J to 10 CFR 50. Type A test acceptance criteria would not be changed and combined leakage of penetrations subject to Type B and Type C tests would be maintained within the required limits. Also, the proposed changes do not impact the design basis of the containment and would not change the response of containment during a design basis accident. Finally, the testing method, acceptance criteria, and the Bases to the TS are not changed by the proposed revisions to the TS. Therefore, based on all of the above, the staff finds the proposed changes to be acceptable.

An administrative change to TS Section 3.6.1.2a(2) for Braidwood, Unit 1, was made to include the limiting value for the integrated leakage rate for Braidwood, Unit 2. The Unit 2 value (0.07% by weight of air per 24 hours) had been included in the Unit 2 TS at the time of licensing. Because Braidwood has common TSs, the values for both units should be shown in Section 3.6.1.2a(2).

5.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Illinois State official was notified of the proposed issuance of the amendments. The State official had no comments.

6.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (59 FR 22002). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

7.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: H. Dawson

Date: June 30, 1994