

April 23, 1999

Mr. Oliver D. Kingsley, President
Nuclear Generation Group
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, IL 60515

SUBJECT: ISSUANCE OF AMENDMENTS (TAC NOS. MA4472, MA4473, MA4474 AND
MA4475)

Dear Mr. Kingsley:

The U.S. Nuclear Regulatory Commission (Commission) has issued the enclosed Amendment No. 107 to Facility Operating License No. NPF-37 and Amendment No. 107 to Facility Operating License No. NPF-66 for the Byron Station, Unit Nos. 1 and 2, respectively, and Amendment No. 100 to Facility Operating License No. NPF-72 and Amendment No. 100 to Facility Operating License No. NPF-77 for the Braidwood Station, Unit Nos. 1 and 2, respectively. The amendments are in response to your application dated December 29, 1998.

The amendments change Technical Specification (TS) Tables 3.3.1-1 and 3.3.2-1, to revise the Allowable Values for 12 functions of the Reactor Trip System and Engineered Safety Features Actuation System.

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by

NRC FILE CENTER COPY

Stewart N. Bailey, Project Manager, Section 2
Project Directorate III-2
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-454, STN 50-455,
STN 50-456 and STN 50-457

Enclosures: 1. Amendment No. 107 to NPF-37
2. Amendment No. 107 to NPF-66
3. Amendment No. 100 to NPF-72
4. Amendment No. 100 to NPF-77
5. Safety Evaluation

DISTRIBUTION:
PDIII/2 r/f (2) PUBLIC
JZwolinski/SBlack JMauck
SBailey JHickman
CMoore (2) ACRS
OGC MJordan, RIII
W Beckner, O13H15 AMendiola
G. Hill (8), T5C3
CNorsworthy (SE)

cc w/encls: See next page

DOCUMENT NAME: G:\PD3-2\CM\BRAID-BYAMDA4472. *See Previous Concurrence Sheet

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	PM:PDIII-2	C	LA:PDIII-2	2	PM:PDIII-2	E	C:HICB		OGC		SC:PDIII/2	E
NAME	SBAILEY:sp		CMOORE		JHICKMAN		JMauck*		RBachmann*		TMendiola	
DATE	04/22/99		04/30/99		04/21/99		03/22/99		03/29/99		04/23/99	505

9904290284 990423
PDR ADOCK 05000454
P PDR

ICIAL RECORD COPY

07-1

O. Kingsley
Commonwealth Edison Company

cc:

Ms. C. Sue Hauser, Project Manager
Westinghouse Electric Corporation
Energy Systems Business Unit
Post Office Box 355
Pittsburgh, Pennsylvania 15230

Joseph Gallo
Gallo & Ross
1025 Connecticut Ave., N.W., Suite 1014
Washington, DC 20036

Howard A. Learner
Environmental law and Policy
Center of the Midwest
35 East Wacker Dr., Suite 1300
Chicago, Illinois 60601

U.S. Nuclear Regulatory Commission
Byron Resident Inspectors Office
4448 N. German Church Road
Byron, Illinois 61010-9750

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Ms. Lorraine Creek
RR 1, Box 182
Manteno, Illinois 60950

Chairman, Ogle County Board
Post Office Box 357
Oregon, Illinois 61061

Mrs. Phillip B. Johnson
1907 Stratford Lane
Rockford, Illinois 61107

George L. Edgar
Morgan, Lewis and Bochi
1800 M Street, N.W.
Washington, DC 20036

Byron/Braidwood Stations

Attorney General
500 S. Second Street
Springfield, Illinois 62701

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Commonwealth Edison Company
Byron Station Manager
4450 N. German Church Road
Byron, Illinois 61010-9794

Commonwealth Edison Company
Site Vice President - Byron
4450 N. German Church Road
Byron, Illinois 61010-9794

U.S. Nuclear Regulatory Commission
Braidwood Resident Inspectors Office
RR 1, Box 79
Braceville, Illinois 60407

Mr. Ron Stephens
Illinois Emergency Services
and Disaster Agency
110 E. Adams Street
Springfield, Illinois 62706

Chairman
Will County Board of Supervisors
Will County Board Courthouse
Joliet, Illinois 60434

Commonwealth Edison Company
Braidwood Station Manager
RR 1, Box 84
Braceville, Illinois 60407-9619

O. Kingsley
Commonwealth Edison Company

- 2 -

Byron/Braidwood Stations

Ms. Bridget Little Rorem
Appleseed Coordinator
117 N. Linden Street
Essex, Illinois 60935

Commonwealth Edison Company
Reg. Assurance Supervisor - Braidwood
RR 1, Box 84
Braceville, Illinois 60407-9619

Document Control Desk-Licensing
Commonwealth Edison Company
1400 Opus Place, Suite 400
Downers Grove, Illinois 60515

Commonwealth Edison Company
Reg. Assurance Supervisor - Byron
4450 N. German Church Road
Byron, Illinois 61010-9794

Commonwealth Edison Company
Site Vice President - Braidwood
RR 1, Box 84
Braceville, Illinois 60407-9619

Ms. Pamela B. Stroebel
Senior Vice President and General Counsel
Commonwealth Edison Company
P.O. Box 767
Chicago, Illinois 60690-0767

Mr. David Helwig
Senior Vice President
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Mr. Gene H. Stanley
PWR Vice President
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Mr. Christopher Crane
BWR Vice President
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 900
Downers Grove, Illinois 60515

Mr. R. M. Krich
Vice President - Regulatory Services
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, Illinois 60515



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, D.C. 20555-0001

COMMONWEALTH EDISON COMPANY

DOCKET NO. STN 50-454

BYRON STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No.107
License No. NPF-37

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated December 29, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-37 is hereby amended to read as follows:

9904290287 990423
PDR ADOCK 05000454
P PDR


9904290287

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 107 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in black ink, appearing to read "Jon Toplis for", is written over the typed name and title.

Anthony Mendiola, Chief, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 23, 1999



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

COMMONWEALTH EDISON COMPANY

DOCKET NO. STN 50-455

BYRON STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 107
License No. NPF-66


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated December 29, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-66 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A (NUREG-1113), as revised through Amendment No. 107 and revised by Attachment 2 to NPF-66, and the Environmental Protection Plan contained in Appendix B, both of which were attached to License No. NPF-37, dated February 14, 1985, are hereby incorporated into this license. Attachment 2 contains a revision to Appendix A which is hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in cursive script, appearing to read "Anthony Mendiola for".

Anthony Mendiola, Chief, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 23, 1999

ATTACHMENT TO LICENSE AMENDMENT NOS. 107 AND 107

FACILITY OPERATING LICENSE NOS. NPF-37 AND NPF-66

DOCKET NOS. STN 50-454 AND STN 50-455

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

Remove Pages

3.3.1-14
3.3.1-15
3.3.1-16
3.3.1-18
3.3.1-19
3.3.2-9
3.3.2-12
3.3.2-14

Insert Pages

3.3.1-14
3.3.1-15
3.3.1-16
3.3.1-18
3.3.1-19
3.3.2-9
3.3.2-12
3.3.2-14

Table 3.3.1-1 (page 1 of 6)
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Manual Reactor Trip	1.2	2	B	SR 3.3.1.13	NA
	3(a), 4(a), 5(a)	2	C	SR 3.3.1.13	NA
2. Power Range Neutron Flux					
a. High	1.2	4	D	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.7 SR 3.3.1.11 SR 3.3.1.15	≤ 110.8% RTP
b. Low	1(b), 2	4	E	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11 SR 3.3.1.15	≤ 27.0% RTP
3. Power Range Neutron Flux Rate					
a. High Positive Rate	1.2	4	E	SR 3.3.1.7 SR 3.3.1.11	≤ 6.2% RTP with time constant ≥ 2 sec
b. High Negative Rate	1.2	4	E	SR 3.3.1.7 SR 3.3.1.11 SR 3.3.1.15	≤ 6.2% RTP with time constant ≥ 2 sec
4. Intermediate Range Neutron Flux	1(b), 2(c)	2	F, G	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 30.0% RTP
5. Source Range Neutron Flux	2(d)	2	H, I	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11 SR 3.3.1.15	≤ 1.42 E5 cps
	3(a), 4(a), 5(a)	2	I, J	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.11 SR 3.3.1.15	≤ 1.42 E5 cps

(continued)

- (a) With Rod Control System capable of rod withdrawal or one or more rods not fully inserted.
- (b) Below the P-10 (Power Range Neutron Flux) interlock.
- (c) Above the P-6 (Source Range Block Permissive) interlock.
- (d) Below the P-6 (Source Range Block Permissive) interlock.

Table 3.3.1-1 (page 2 of 6)
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
6. Overtemperature ΔT	1.2	4	E	SR 3.3.1.1 SR 3.3.1.3 SR 3.3.1.6 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	Refer to Note 1 (Page 3.3.1-18)
7. Overpower ΔT	1.2	4	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	Refer to Note 2 (Page 3.3.1-19)
8. Pressurizer Pressure					
a. Low	1(e)	4	K	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	≥ 1875 psig
b. High	1.2	4	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	≤ 2393 psig
9. Pressurizer Water Level - High	1(e)	3	K	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	$\leq 93.5\%$ of instrument span
10. Reactor Coolant Flow - Low (per loop)	1(e)	3	K	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	$\geq 89.3\%$ of loop minimum measured flow
11. Reactor Coolant Pump (RCP) Breaker Position (per train)	1(e)	4	K	SR 3.3.1.13	NA

(continued)

(e) Above the P-7 (Low Power Reactor Trips Block) interlock.

Table 3.3.1-1 (page 3 of 6)
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
12. Undervoltage RCPs (per train)	1(e)	4	K	SR 3.3.1.9 SR 3.3.1.10 SR 3.3.1.15	≥ 4920 V
13. Underfrequency RCPs (per train)	1(e)	4	K	SR 3.3.1.9 SR 3.3.1.10 SR 3.3.1.15	≥ 56.08 Hz
14. Steam Generator (SG) Water Level - Low Low (per SG)					
a. Unit 1	1,2	4	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	$\geq 16.1\%$ of narrow range instrument span
b. Unit 2	1,2	4	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	$\geq 34.8\%$ of narrow range instrument span
15. Turbine Trip					
a. Emergency Trip Header Pressure (per train)	1(f)	3	L	SR 3.3.1.10 SR 3.3.1.14	≥ 910 psig
b. Turbine Throttle Valve Closure (per train)	1(f)	4	L	SR 3.3.1.10 SR 3.3.1.14	$\geq 1\%$ open
16. Safety Injection (SI) Input from Engineered Safety Feature Actuation System (ESFAS)	1,2	2 trains	M	SR 3.3.1.13	NA

(continued)

(e) Above the P-7 (Low Power Reactor Trips Block) interlock.

(f) Above the P-8 (Power Range Neutron Flux) interlock.

Table 3.3.1-1 (page 5 of 6)
Reactor Trip System Instrumentation

Note 1: Overtemperature ΔT

The Overtemperature ΔT Function Allowable Value shall not exceed the following Trip Setpoint by more than 1.04% of ΔT span.

$$\Delta T \frac{(1+\tau_1 s)}{(1+\tau_2 s)} \left[\frac{1}{1+\tau_3 s} \right] \leq \Delta T_0 \left\{ K_1 - K_2 \frac{(1+\tau_4 s)}{(1+\tau_5 s)} \left[T \frac{1}{(1+\tau_6 s)} - T' \right] + K_3 (P - P') - f_1(\Delta I) \right\}$$

Where: ΔT is measured Reactor Coolant System (RCS) ΔT , °F.

ΔT_0 is the indicated ΔT at RTP, °F.

s is the Laplace transform operator, sec^{-1} .

T is the measured RCS average temperature, °F.

T' is the nominal T_{avg} at RTP, $\leq 588.4^\circ\text{F}$.

P is the measured pressurizer pressure, psig.

P' is the nominal RCS operating pressure, = 2235 psig.

$K_1 = 1.325$	$K_2 = 0.0297/^\circ\text{F}$	$K_3 = 0.00181/\text{psig}$
$\tau_1 = 8 \text{ sec}$	$\tau_2 = 3 \text{ sec}$	$\tau_3 \leq 2 \text{ sec}$
$\tau_4 = 33 \text{ sec}$	$\tau_5 = 4 \text{ sec}$	$\tau_6 \leq 2 \text{ sec}$

$$f_1(\Delta I) = \begin{cases} -3.35\{24 + (q_t - q_b)\} & \text{when } q_t - q_b < -24\% \text{ RTP} \\ 0\% \text{ of RTP} & \text{when } -24\% \text{ RTP} \leq q_t - q_b \leq 10\% \text{ RTP} \\ 4.11\{(q_t - q_b) - 10\} & \text{when } q_t - q_b > 10\% \text{ RTP} \end{cases}$$

Where q_t and q_b are percent RTP in the upper and lower halves of the core, respectively, and $q_t + q_b$ is the total THERMAL POWER in percent RTP.

Table 3.3.1-1 (page 6 of 6)
Reactor Trip System Instrumentation

Note 2: Overpower ΔT

The Overpower ΔT Function Allowable Value shall not exceed the following Trip Setpoint by more than 3.60% of ΔT span.

$$\Delta T \frac{(1+\tau_1 s)}{(1+\tau_2 s)} \left[\frac{1}{1+\tau_3 s} \right] \leq \Delta T_0 \left\{ K_4 - K_5 \frac{\tau_7 s}{1+\tau_7 s} \left[\frac{1}{1+\tau_6 s} \right] T - K_6 \left[T \frac{1}{1+\tau_6 s} - T'' \right] - f_2(\Delta I) \right\}$$

Where: ΔT is measured RCS ΔT , °F.

ΔT_0 is the indicated ΔT at RTP, °F.

s is the Laplace transform operator, sec^{-1} .

T is the measured RCS average temperature, °F.

T'' is the nominal T_{avg} at RTP, $\leq 588.4^\circ\text{F}$.

$$K_4 = 1.072$$

$$K_5 = 0.02/^\circ\text{F for increasing } T_{\text{avg}} \\ 0/^\circ\text{F for decreasing } T_{\text{avg}}$$

$$K_6 = 0.00245/^\circ\text{F when } T > T'' \\ 0/^\circ\text{F when } T \leq T''$$

$$\tau_1 = 8 \text{ sec}$$

$$\tau_2 = 3 \text{ sec}$$

$$\tau_3 \leq 2 \text{ sec}$$

$$\tau_6 \leq 2 \text{ sec}$$

$$\tau_7 = 10 \text{ sec}$$

$$f_2(\Delta I) = 0 \text{ for all } \Delta I.$$

Table 3.3.2-1 (page 1 of 6)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Safety Injection					
a. Manual Initiation	1,2,3,4	2	B	SR 3.3.2.9	NA
b. Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	C	SR 3.3.2.4 SR 3.3.2.5 SR 3.3.2.7	NA
c. Containment Pressure - High 1	1,2,3	3	D	SR 3.3.2.1 SR 3.3.2.6 SR 3.3.2.10 SR 3.3.2.12	≤ 4.6 psig
d. Pressurizer Pressure - Low	1,2,3 ^(a)	4	D	SR 3.3.2.1 SR 3.3.2.6 SR 3.3.2.10 SR 3.3.2.12	≥ 1817 psig
e. Steam Line Pressure - Low	1,2,3 ^(a)	3 per steam line	D	SR 3.3.2.1 SR 3.3.2.6 SR 3.3.2.10 SR 3.3.2.12	≥ 614 psig ^(b)
2. Containment Spray					
a. Manual Initiation	1,2,3,4	2	B	SR 3.3.2.9	NA
b. Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	C	SR 3.3.2.4 SR 3.3.2.5 SR 3.3.2.7	NA
c. Containment Pressure High - 3	1,2,3	4	E	SR 3.3.2.1 SR 3.3.2.6 SR 3.3.2.10 SR 3.3.2.12	≤ 21.2 psig

(continued)

(a) Above the P-11 (Pressurizer Pressure) interlock.

(b) Time constants used in the lead/lag controller are $t_1 \geq 50$ seconds and $t_2 \leq 5$ seconds.

Table 3.3.2-1 (page 4 of 6)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
5. Turbine Trip and Feedwater Isolation					
a. Automatic Actuation Logic and Actuation Relays	1.2 ^(h) , 3 ^(h)	2 trains	G	SR 3.3.2.4 SR 3.3.2.5 SR 3.3.2.7	NA
b. Steam Generator (SG) Water Level - High High (P-14)					
1) Unit 1	1.2 ^(h) , 3 ^(h)	4 per SG	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.5 SR 3.3.2.6 SR 3.3.2.7 SR 3.3.2.10 SR 3.3.2.12	≤ 89.9% of narrow range instrument span
2) Unit 2	1.2 ^(h) , 3 ^(h)	4 per SG	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.5 SR 3.3.2.6 SR 3.3.2.7 SR 3.3.2.10 SR 3.3.2.12	≤ 81.5% of narrow range instrument span
c. Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.				

(continued)

(h) Except when all Feedwater Isolation Valves are closed or isolated by a closed manual valve.

Table 3.3.2-1 (page 6 of 6)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
8. ESFAS Interlocks					
a. Reactor Trip, P-4	1.2.3	2 per train	F	SR 3.3.2.9	NA
b. Pressurizer Pressure, P-11	1.2.3	2	L	SR 3.3.2.6 SR 3.3.2.10	≤ 1936 psig
c. T _{avg} - Low Low, P-12	1.2.3	3	L	SR 3.3.2.6 SR 3.3.2.10	≥ 548.0°F



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

COMMONWEALTH EDISON COMPANY

DOCKET NO. STN 50-456

BRAIDWOOD STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 100
License No. NPF-72

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated December 29, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-72 is hereby amended to read as follows:


9904300032 990423
PDR ADOCK 05000454
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 100 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in cursive script, appearing to read "Jon Hoptis for", is written over the typed name and title.

Anthony Mendiola, Chief, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 23, 1999



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, D.C. 20555-0001

COMMONWEALTH EDISON COMPANY

DOCKET NO. STN 50-457

BRAIDWOOD STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 100
License No. NPF-77


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated December 29, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-77 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 100 and the Environmental Protection Plan contained in Appendix B, both of which were attached to License No. NPF-72, dated July 2, 1987, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in cursive script, appearing to read "Jon Hoplis for".

Anthony Mendiola, Chief, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 23, 1999

ATTACHMENT TO LICENSE AMENDMENT NOS. 100 AND 100

FACILITY OPERATING LICENSE NOS. NPF-72 AND NPF-77

DOCKET NOS. STN 50-456 AND STN 50-457

Replace the following pages of the Appendix "A" Technical Specifications with the attached pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change.

Remove Pages

3.3.1-14
3.3.1-15
3.3.1-16
3.3.1-18
3.3.1-19
3.3.2-9
3.3.2-12
3.3.2-14

Insert Pages

3.3.1-14
3.3.1-15
3.3.1-16
3.3.1-18
3.3.1-19
3.3.2-9
3.3.2-12
3.3.2-14

Table 3.3.1-1 (page 1 of 6)
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Manual Reactor Trip	1.2	2	B	SR 3.3.1.13	NA
	3(a), 4(a), 5(a)	2	C	SR 3.3.1.13	NA
2. Power Range Neutron Flux					
a. High	1.2	4	D	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.7 SR 3.3.1.11 SR 3.3.1.15	≤ 110.8% RTP
b. Low	1(b), 2	4	E	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11 SR 3.3.1.15	≤ 27.0% RTP
3. Power Range Neutron Flux Rate					
a. High Positive Rate	1.2	4	E	SR 3.3.1.7 SR 3.3.1.11	≤ 6.2% RTP with time constant ≥ 2 sec
b. High Negative Rate	1.2	4	E	SR 3.3.1.7 SR 3.3.1.11 SR 3.3.1.15	≤ 6.2% RTP with time constant ≥ 2 sec
4. Intermediate Range Neutron Flux	1(b), 2(c)	2	F,G	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 30.0% RTP
5. Source Range Neutron Flux	2(d)	2	H,I	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11 SR 3.3.1.15	≤ 1.42 E5 cps
	3(a), 4(a), 5(a)	2	I,J	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.11 SR 3.3.1.15	≤ 1.42 E5 cps

(continued)

- (a) With Rod Control System capable of rod withdrawal or one or more rods not fully inserted.
- (b) Below the P-10 (Power Range Neutron Flux) interlock.
- (c) Above the P-6 (Source Range Block Permissive) interlock.
- (d) Below the P-6 (Source Range Block Permissive) interlock.

Table 3.3.1-1 (page 2 of 6)
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
6. Overtemperature ΔT	1.2	4	E	SR 3.3.1.1 SR 3.3.1.3 SR 3.3.1.6 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	Refer to Note 1 (Page 3.3.1-18)
7. Overpower ΔT	1.2	4	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	Refer to Note 2 (Page 3.3.1-19)
8. Pressurizer Pressure					
a. Low	1(e)	4	K	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	≥ 1875 psig
b. High	1.2	4	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	≤ 2393 psig
9. Pressurizer Water Level - High	1(e)	3	K	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	$\leq 93.5\%$ of instrument span
10. Reactor Coolant Flow - Low (per loop)	1(e)	3	K	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	$\geq 89.3\%$ of loop minimum measured flow
11. Reactor Coolant Pump (RCP) Breaker Position (per train)	1(e)	4	K	SR 3.3.1.13	NA

(continued)

(e) Above the P-7 (Low Power Reactor Trips Block) interlock.

Table 3.3.1-1 (page 3 of 6)
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
12. Undervoltage RCPs (per train)	1(e)	4	K	SR 3.3.1.9 SR 3.3.1.10 SR 3.3.1.15	≥ 4920 V
13. Underfrequency RCPs (per train)	1(e)	4	K	SR 3.3.1.9 SR 3.3.1.10 SR 3.3.1.15	≥ 56.08 Hz
14. Steam Generator (SG) Water Level - Low Low (per SG)					
a. Unit 1	1.2	4	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	$\geq 16.1\%$ of narrow range instrument span
b. Unit 2	1.2	4	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.15	$\geq 34.8\%$ of narrow range instrument span
15. Turbine Trip					
a. Emergency Trip Header Pressure (per train)	1(f)	3	L	SR 3.3.1.10 SR 3.3.1.14	≥ 910 psig
b. Turbine Throttle Valve Closure (per train)	1(f)	4	L	SR 3.3.1.10 SR 3.3.1.14	$\geq 1\%$ open
16. Safety Injection (SI) Input from Engineered Safety Feature Actuation System (ESFAS)	1.2	2 trains	M	SR 3.3.1.13	NA

(continued)

(e) Above the P-7 (Low Power Reactor Trips Block) interlock.

(f) Above the P-8 (Power Range Neutron Flux) interlock.

Table 3.3.1-1 (page 5 of 6)
Reactor Trip System Instrumentation

Note 1: Overtemperature ΔT

The Overtemperature ΔT Function Allowable Value shall not exceed the following Trip Setpoint by more than 1.04% of ΔT span.

$$\Delta T \frac{(1+\tau_1 s)}{(1+\tau_2 s)} \left[\frac{1}{1+\tau_3 s} \right] \leq \Delta T_0 \left\{ K_1 - K_2 \frac{(1+\tau_4 s)}{(1+\tau_5 s)} \left[T \frac{1}{(1+\tau_6 s)} - T' \right] + K_3 (P - P') - f_1(\Delta I) \right\}$$

Where: ΔT is measured Reactor Coolant System (RCS) ΔT , °F.

ΔT_0 is the indicated ΔT at RTP, °F.

s is the Laplace transform operator, sec^{-1} .

T is the measured RCS average temperature, °F.

T' is the nominal T_{avg} at RTP, $\leq 588.4^\circ\text{F}$.

P is the measured pressurizer pressure, psig.

P' is the nominal RCS operating pressure, = 2235 psig.

$K_1 = 1.325$ $K_2 = 0.0297/^\circ\text{F}$ $K_3 = 0.00181/\text{psig}$

$\tau_1 = 8 \text{ sec}$ $\tau_2 = 3 \text{ sec}$ $\tau_3 \leq 2 \text{ sec}$

$\tau_4 = 33 \text{ sec}$ $\tau_5 = 4 \text{ sec}$ $\tau_6 \leq 2 \text{ sec}$

$f_1(\Delta I) = -3.35\{24 + (q_t - q_b)\}$ when $q_t - q_b < -24\%$ RTP
0% of RTP when $-24\% \text{ RTP} \leq q_t - q_b \leq 10\% \text{ RTP}$
4.11 $\{(q_t - q_b) - 10\}$ when $q_t - q_b > 10\% \text{ RTP}$

Where q_t and q_b are percent RTP in the upper and lower halves of the core, respectively, and $q_t + q_b$ is the total THERMAL POWER in percent RTP.

Table 3.3.1-1 (page 6 of 6)
Reactor Trip System Instrumentation

Note 2: Overpower ΔT

The Overpower ΔT Function Allowable Value shall not exceed the following Trip Setpoint by more than 3.60% of ΔT span.

$$\Delta T \frac{(1+\tau_1 s)}{(1+\tau_2 s)} \left[\frac{1}{1+\tau_3 s} \right] \leq \Delta T_0 \left\{ K_4 - K_5 \frac{\tau_7 s}{1+\tau_7 s} \left[\frac{1}{1+\tau_6 s} \right] T - K_6 \left[T \frac{1}{1+\tau_6 s} - T'' \right] - f_2(\Delta I) \right\}$$

Where: ΔT is measured RCS ΔT , °F.

ΔT_0 is the indicated ΔT at RTP, °F.

s is the Laplace transform operator, sec^{-1} .

T is the measured RCS average temperature, °F.

T'' is the nominal T_{avg} at RTP, $\leq 588.4^\circ\text{F}$.

$$K_4 = 1.072$$

$$K_5 = 0.02/^\circ\text{F for increasing } T_{\text{avg}} \\ 0/^\circ\text{F for decreasing } T_{\text{avg}}$$

$$K_6 = 0.00245/^\circ\text{F when } T > T'' \\ 0/^\circ\text{F when } T \leq T''$$

$$\tau_1 = 8 \text{ sec}$$

$$\tau_2 = 3 \text{ sec}$$

$$\tau_3 \leq 2 \text{ sec}$$

$$\tau_6 \leq 2 \text{ sec}$$

$$\tau_7 = 10 \text{ sec}$$

$$f_2(\Delta I) = 0 \text{ for all } \Delta I.$$

Table 3.3.2-1 (page 1 of 6)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Safety Injection					
a. Manual Initiation	1.2.3.4	2	B	SR 3.3.2.9	NA
b. Automatic Actuation Logic and Actuation Relays	1.2.3.4	2 trains	C	SR 3.3.2.4 SR 3.3.2.5 SR 3.3.2.7	NA
c. Containment Pressure - High 1	1.2.3	3	D	SR 3.3.2.1 SR 3.3.2.6 SR 3.3.2.10 SR 3.3.2.12	≤ 4.6 psig
d. Pressurizer Pressure - Low	1.2.3 ^(a)	4	D	SR 3.3.2.1 SR 3.3.2.6 SR 3.3.2.10 SR 3.3.2.12	≥ 1817 psig
e. Steam Line Pressure - Low	1.2.3 ^(a)	3 per steam line	D	SR 3.3.2.1 SR 3.3.2.6 SR 3.3.2.10 SR 3.3.2.12	≥ 614 psig ^(b)
2. Containment Spray					
a. Manual Initiation	1.2.3.4	2	B	SR 3.3.2.9	NA
b. Automatic Actuation Logic and Actuation Relays	1.2.3.4	2 trains	C	SR 3.3.2.4 SR 3.3.2.5 SR 3.3.2.7	NA
c. Containment Pressure High - 3	1.2.3	4	E	SR 3.3.2.1 SR 3.3.2.6 SR 3.3.2.10 SR 3.3.2.12	≤ 21.2 psig

(continued)

(a) Above the P-11 (Pressurizer Pressure) interlock.

(b) Time constants used in the lead/lag controller are $t_1 \geq 50$ seconds and $t_2 \leq 5$ seconds.

Table 3.3.2-1 (page 4 of 6)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
5. Turbine Trip and Feedwater Isolation					
a. Automatic Actuation Logic and Actuation Relays	1.2 ^(h) , 3 ^(h)	2 trains	G	SR 3.3.2.4 SR 3.3.2.5 SR 3.3.2.7	NA
b. Steam Generator (SG) Water Level - High High (P-14)					
1) Unit 1	1.2 ^(h) , 3 ^(h)	4 per SG	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.5 SR 3.3.2.6 SR 3.3.2.7 SR 3.3.2.10 SR 3.3.2.12	≤ 89.9% of narrow range instrument span
2) Unit 2	1.2 ^(h) , 3 ^(h)	4 per SG	D	SR 3.3.2.1 SR 3.3.2.4 SR 3.3.2.5 SR 3.3.2.6 SR 3.3.2.7 SR 3.3.2.10 SR 3.3.2.12	≤ 81.5% of narrow range instrument span
c. Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.				

(continued)

(h) Except when all Feedwater Isolation Valves are closed or isolated by a closed manual valve.

Table 3.3.2-1 (page 6 of 6)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
8. ESFAS Interlocks					
a. Reactor Trip. P-4	1.2.3	2 per train	F	SR 3.3.2.9	NA
b. Pressurizer Pressure. P-11	1.2.3	2	L	SR 3.3.2.6 SR 3.3.2.10	≤ 1936 psig
c. T _{avg} - Low Low. P-12	1.2.3	3	L	SR 3.3.2.6 SR 3.3.2.10	≥ 548.0°F



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 107 TO FACILITY OPERATING LICENSE NO. NPF-37,
AMENDMENT NO. 107 TO FACILITY OPERATING LICENSE NO. NPF-66,
AMENDMENT NO. 100 TO FACILITY OPERATING LICENSE NO. NPF-72,
AND AMENDMENT NO. 100 TO FACILITY OPERATING LICENSE NO. NPF-77
COMMONWEALTH EDISON COMPANY
BYRON STATION, UNIT NOS. 1 AND 2
BRAIDWOOD STATION, UNIT NOS. 1 AND 2
DOCKET NOS. STN 50-454, STN 50-455, STN 50-456 AND STN 50-457

1.0 INTRODUCTION

By letter dated December 29, 1998, the Commonwealth Edison Company (ComEd, or the licensee) requested changes to the Technical Specifications (TSs) for Byron Station, Units 1 and 2, and Braidwood Station, Units 1 and 2. The changes would revise the Allowable Values (AVs) for 12 functions of the Reactor Trip System (RTS) and Engineered Safety Features Actuation System (ESFAS).

2.0 EVALUATION

The AVs are used as a basis for checking instrument channel operability when performing instrument loop calibrations. AVs account for uncertainty, calibration tolerances and instrument drift, which is assumed to occur between calibrations, to verify that the trip or actuation will occur within the limits assumed in the safety analyses. The use of AVs for determining instrument operability is based on industry standards and practices.

The licensee proposed to change the AVs for twelve RTS and ESFAS functions. The changes result from updated calculations that use revised plant-specific parameters and reflect ComEd's use of more accurate Measurement and Test Equipment (M&TE). The licensee proposed to change the following AVs:

Reactor Trip System Allowable Values (Table 3.3.1-1)

Function 2.a.	Power Range Neutron Flux High
Function 2.b.	Power Range Neutron Flux Low
Function 3.a.	Power Range Neutron Flux Rate High Positive Rate

9904290288 990423
PDR ADOCK 05000454
P PDR

Function 3.b.	Power Range Neutron Flux Rate High Negative Rate
Function 4.	Intermediate Range Neutron Flux
Function 6.	Overtemperature ΔT
Function 7.	Overpower ΔT
Function 8.a.	Pressurizer Pressure Low
Function 15.a.	Turbine Trip, Emergency Trip Header Pressure

Engineered Safety Feature Actuation System Allowable Values (Table 3.3.2-1)

Function 1.d.	Safety Injection Pressurizer Pressure - Low
Function 5.b.2	Turbine Trip and Feedwater Isolation Steam Generator Water Level - High High (P-14) Unit 2
Function 8.c.	ESFAS Interlocks T_{avg} - Low Low

The revised AVs were determined in accordance with the Westinghouse methodology described in WCAP-12583, "Westinghouse Setpoint Methodology for Protection Systems, Byron/Braidwood Stations," dated May 1990, except for Table 3.3.1-1, Function 15a, "Turbine Trip, Emergency Trip Header Pressure." The NRC has previously reviewed and approved the Westinghouse methodology for use at Braidwood and Byron Stations, as is documented in the Safety Evaluation for License Amendment No. 42 for Braidwood and License Amendment No. 53 for Byron, dated April 13, 1993. The methodology used to determine the proposed AV for Table 3.3.1-1, Function 15a, "Turbine Trip, Emergency Trip Header Pressure," is consistent with the Instrument Society of America (ISA) standard, ISA-S67.04-1994, "Setpoints for Nuclear Safety-Related Instrumentation Used in Nuclear Power Plants" and Regulatory Guide 1.105, "Instrument Setpoints for Safety-Related Systems," Revision 2, dated February 1986. The staff has previously accepted this methodology for LaSalle County Station, Unit 1, as is documented in the safety evaluation for Amendment No. 129 for LaSalle County Station, dated July 6, 1998. Based on this, the staff finds the use of this methodology at Braidwood and Byron to be acceptable.

The licensee stated that no changes were made to the trip setpoints or the analytical limits used in the safety analyses. The only changes were to the AVs used as the basis for determining instrument channel operability, which have been derived from the analytical limits. In all cases, the difference between the trip setpoints and the AVs has been reduced, which increases the margin with respect to the analyzed safety limits.

The licensee used acceptable methodologies and updated, plant-specific input parameters, including M&TE, to determine the proposed AVs. Based on the above, the staff finds the proposed changes to be acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Illinois State official was notified of the proposed issuance of the amendments. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (64 FR 9186). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Stewart Bailey

Date: April 23, 1999