Docket Nos. STN 50-454 and STN 50-455

> Mr. D. L. Farrar Manager, Nuclear Regulatory Services Commonwealth Edison Company Executive Towers West III, Suite 500 1400 OPUS Place Downers Grove, Illinois 60515

DISTRIBUTION:	PDIII-2 p/f
NRC & Local PDRs	Docket File
J. Roe	J. Zwolinski
J. Dyer	J. Hickman
R. Assa	C. Moore
OGC	D. Hagan
G. Hill (4)	B. Clayton RIII
C. Grimes	ACRS (10)
OPA	OC/LFDCB
C. McCracken	-

Dear Mr. Farrar:

SUBJECT: CORRECTION TO AMENDMENT (TAC NOS. M84154 AND M84155)

Amendment No. 56 to Facility Operating License No. NPF-37 and Amendment No. 56 to Facility Operating License No. NPF-66 for the Byron Station, Unit Nos. 1 and 2 were issued on October 22, 1993. The amendments contained an error on page 3/4 7-20 of the revised Technical Specifications. A copy of the corrected page 3/4 7-20 is enclosed.

Sincerely,

Original Signed By:

Ramin R. Assa, Acting Project Manager Project Directorate III-2 Division of Reactor Projects - III/IV/V Office of Nuclear Reactor Regulation

Enclosure: Corrected page 3/4 7-20

cc w/enclosure: See next page

OFC	LANPDIII-2	(A) PM: PDIII-2	D:PDIII-2
NAME	CMOORE	RASSA RX	JDYER SE
DATE	11/993	11/1/93	1////93
COPY	(YES)NO	YES/NO	(YE\$/NO

9312020290 931117 PDR ADUCK 05000454 P PDR

NRC FILE CENTER COPY

Docket Nos. STN 50-454 and STN 50-455

> Mr. D. L. Farrar Manager, Nuclear Regulatory Services Commonwealth Edison Company Executive Towers West III, Suite 500 1400 OPUS Place Downers Grove, Illinois 60515

DISTRIBUTION:	PDIII-2 p/f
NRC & Local PDRs	Docket File
J. Roe	J. Zwolinski
J. Dyer	J. Hickman
R. Assa	C. Moore
OGC	D. Hagan
G. Hill (4)	B. Clayton RIII
C. Grimes	ACRS (10)
OPA	OC/LFDCB
C. McCracken	•

Dear Mr. Farrar:

SUBJECT: CORRECTION TO AMENDMENT (TAC NOS. M84154 AND M84155)

Amendment No. 56 to Facility Operating License No. NPF-37 and Amendment No. 56 to Facility Operating License No. NPF-66 for the Byron Station, Unit Nos. 1 and 2 were issued on October 22, 1993. The amendments contained an error on page 3/4 7-20 of the revised Technical Specifications. A copy of the corrected page 3/4 7-20 is enclosed.

Sincerely,

Original Signed By:

Ramin R. Assa, Acting Project Manager Project Directorate III-2 Division of Reactor Projects - III/IV/V Office of Nuclear Reactor Regulation

Enclosure: Corrected page 3/4 7-20

cc w/enclosure: See next page

			7	
OFC	LANPDIII-2	(A)PM:PDIII-2	D:PDIII-2	
NAME	CMOORE	RASSA RK	JDYER SAL	
DATE	1/1993	11 /1/93	11/17/93	
СОРУ	(YES)NO	YES/NO	(YE\$/NO	

Mr. D. L. Farrar Commonwealth Edison Company

cc:

r.

Mr. William P. Poirier, Director Westinghouse Electric Corporation Energy Systems Business Unit Post Office Box 355, Bay 236 West Pittsburgh, Pennsylvania 15230

Joseph Gallo, Esquire Hopkins and Sutter 888 16th Street, N.W. Suite 700 Washington, D.C. 20006

Michael I. Miller, Esquire Sidley and Austin One First National Plaza Chicago, Illinois 60690

Mr. Edward R. Crass Nuclear Safeguards and Licensing Sargent & Lundy Engineers 55 East Monroe Street Chicago, Illinois 60603

U. S. Nuclear Regulatory Commission Byron Resident Inspectors Office 4448 North German Church Road Byron, Illinois 61010-9750

Regional Administrator, Region III U. S. Nuclear Regulatory Commission 799 Roosevelt Road, Bldg. #4 Glen Ellyn, Illinois 60137

Chairman, Ogle County Board Post Office Box 357 Oregon, Illinois 61061

Robert Neumann Office of Public Counsel State of Illinois Center 100 W. Randolph Suite 11-300 Chicago, Illinois 60601 Byron Station Unit Nos. 1 and 2

Ms. Lorraine Creek Rt. 1, Box 182 Manteno, Illinois 60950

Douglass Cassel, Esquire 17 East Monroe Street, Suite 212 Chicago, Illinois 60603

Mrs. Phillip B. Johnson 1907 Stratford Lane Rockford, Illinois 61107

Attorney General 500 South 2nd Street Springfield, Illinois 62701

EIS Review Coordinator EPA Region V 230 S. Dearborn Street Chicago, Illinois 60604

Illinois Department of Nuclear Safety Office of Nuclear Facility Safety 1035 Outer Park Drive Springfield, Illinois 62704

Commonwealth Edison Company Byron Station Manager 4450 North German Church Road Byron, Illinois 61010

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- 3) Verifying a system flow rate between 55,669 cfm and 68,200 cfm through the exhaust filter plenum during operation when tested in accordance with ANSI N510-1980; and
- 4) Verifying that with the system operating at a flow rate between 55,669 cfm and 68,200 cfm through the train and exhausting through the HEPA filter and charcoal adsorbers, the total bypass flow of the system and the damper leakage is less than or equal to 1% when the system is tested by admitting DOP at the system intake and the damper leakage rate is determined by either direct measurements or pressure decay measurements at a test pressure of 2 inches of water and the auxiliary building exhaust fans are operating at their rated flow.
- c. After every 720 hours of charcoal adsorber operation, by verifying, within 31 days after removal, that a laboratory analysis of a representative carbon sample obtained from each bank of adsorbers of the train in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, when the average for a methyl iodide penetration of less than 1% when tested at a temperature of 30°C and a relative humidity of 70%.
- d. At least once per 18 months by:
 - 1) Verifying for each filter bank of the train that the pressure drop across the combined HEPA filters and charcoal adsorber banks of less than 6.0 inches Water Gauge while operating the exhaust filter plenum at a flow rate between 55,669 cfm and 68,200 cfm through the train;
 - 2) Verifying that the exhaust filter plenum starts on manual initiation or Safety Injection test signal; and
 - 3) Verifying that the system maintains the ECCS equipment rooms at a negative pressure of greater than or equal to 1/4 in. Water Gauge relative to the outside atmosphere during system operation while operating at a flow rate between 55,669 cfm and 68,200 cfm through the train.
- e. After each complete or partial replacement of a HEPA filter bank, by verifying that the exhaust filter plenum satisfies the in-place penetration testing acceptance criteria of less than 1% in accordance with ANSI N510-1980 for a DOP test aerosol while operating at a flow rate between 55,669 cfm and 68,200 cfm through the train; and

9312020300 931117 PDR ADDCK 05000454 P PDR