

May 12, 1993

Docket Nos. STN 50-454  
and STN 50-455

Mr. D. L. Farrar  
Manager, Nuclear Regulatory Services  
Commonwealth Edison Company  
Executive Towers West III, Suite 500  
1400 OPUS Place  
Downers Grove, Illinois 60515

Dear Mr. Farrar:

SUBJECT: CORRECTION TO AMENDMENT NO. 53 (TAC NOS. M83216 AND M83217)

By letter dated April 13, 1993, the U.S. Nuclear Regulatory Commission issued Amendment No. 53 for Byron Station, Units 1 and 2. Pages 2-5 and B 2-3 of the Technical Specifications, revised as part of that amendment, contained errors. Corrected pages are enclosed.

Should you have any questions or comments, please contact me at  
(301) 504-3017.

Sincerely,

Original signed by:

John B. Hickman, Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III/IV/V  
Office of Nuclear Reactor Regulation

Enclosure:  
Corrected pages

cc w/enclosure:  
See next page

NRC FILE CENTER COPY

<u>DISTRIBUTION:</u>	Docket File	DHagan
NRC & Local PDRs	PDIII-2 r/f	OPA
J. Roe	J. Zwolinski	GH11(4)
J. Dyer	C. Moore	WJones
J. Hickman	OGC	OC/LFDCB
ACRS (10)	B. Clayton RIII	CGrimes

OFC	LA:PDIII-2	PM:PDIII-2	D:PDIII-2		
NAME	CMOORE	JHICKMAN	JDYER		
DATE	5/1/93	5/12/93	5/12/93		

130047

9305200144 930512  
PDR ADOCK 05000454  
P PDR

DF01 1/1

Mr. D. L. Farrar  
Commonwealth Edison Company

cc:

Mr. William P. Poirier, Director  
Westinghouse Electric Corporation  
Energy Systems Business Unit  
Post Office Box 355, Bay 236 West  
Pittsburgh, Pennsylvania 15230

Joseph Gallo, Esquire  
Hopkins and Sutter  
888 16th Street, N.W.  
Suite 700  
Washington, D.C. 20006

Michael I. Miller, Esquire  
Sidley and Austin  
One First National Plaza  
Chicago, Illinois 60690

Mr. Edward R. Crass  
Nuclear Safeguards and  
Licensing  
Sargent & Lundy Engineers  
55 East Monroe Street  
Chicago, Illinois 60603

U. S. Nuclear Regulatory Commission  
Byron Resident Inspectors Office  
4448 North German Church Road  
Byron, Illinois 61010-9750

Regional Administrator, Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road, Bldg. #4  
Glen Ellyn, Illinois 60137

Chairman, Ogle County Board  
Post Office Box 357  
Oregon, Illinois 61061

Robert Neumann  
Office of Public Counsel  
State of Illinois Center  
100 W. Randolph  
Suite 11-300  
Chicago, Illinois 60601

Byron Station  
Unit Nos. 1 and 2

Ms. Lorraine Creek  
Rt. 1, Box 182  
Manteno, Illinois 60950

Douglass Cassel, Esquire  
17 East Monroe Street, Suite 212  
Chicago, Illinois 60603

Mrs. Phillip B. Johnson  
1907 Stratford Lane  
Rockford, Illinois 61107

Attorney General  
500 South 2nd Street  
Springfield, Illinois 62701

EIS Review Coordinator  
EPA Region V  
230 S. Dearborn Street  
Chicago, Illinois 60604

Illinois Department of  
Nuclear Safety  
Office of Nuclear Facility Safety  
1035 Outer Park Drive  
Springfield, Illinois 62704

Commonwealth Edison Company  
Byron Station Manager  
4450 North German Church Road  
Byron, Illinois 61010

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINTS</u>	<u>ALLOWABLE VALUE</u>
12. Reactor Coolant Flow-Low	$\geq 90\%$ of loop minimum measured flow*	$\geq 89.3\%$ of loop minimum measured flow*
13. Steam Generator Water Level Low-Low		
a. Unit 1	$\geq 33.0\%$ of narrow range instrument span	$\geq 31.0\%$ of narrow range instrument span
b. Unit 2	$\geq 36.3\%$ of narrow range instrument span	$\geq 34.8\%$ of narrow range instrument span
14. Undervoltage - Reactor Coolant Pumps	$\geq 5268$ volts - each bus	$\geq 4920$ volts - each bus
15. Underfrequency - Reactor Coolant Pumps	$\geq 57.0$ Hz	$\geq 56.08$ Hz
16. Turbine Trip		
a. Emergency Trip Header Pressure	$\geq 1000$ psig	$\geq 815$ psig
b. Turbine Throttle Valve Closure	$\geq 1\%$ open	$\geq 1\%$ open
17. Safety Injection Input from ESF	N.A.	N.A.
18. Reactor Coolant Pump Breaker Position Trip	N.A.	N.A.

\* Minimum measured flow = 97,600 gpm

BYRON - UNITS 1 &amp; 2

2-5

AMENDMENT NO. 53

## 2.2 LIMITING SAFETY SYSTEM SETTINGS

### BASES

---

#### 2.2.1 REACTOR TRIP SYSTEM INSTRUMENTATION SETPOINTS

The Reactor Trip Setpoint Limits specified in Table 2.2-1 are the nominal values at which the Reactor trips are set for each functional unit. The Trip Setpoints have been selected to ensure that the core and Reactor Coolant System are prevented from exceeding their Safety Limits during normal operation and design basis anticipated operational occurrences and to assist the Engineered Safety Features Actuation System in mitigating the consequences of accidents. The Setpoint for a Reactor Trip System or interlock function is considered to be adjusted consistent with the nominal value when the "as measured" Setpoint is within the band allowed for calibration accuracy.

To accommodate the instrument drift assumed to occur between operational tests and the accuracy to which Setpoints can be measured and calibrated, Allowable Values for the Reactor Trip Setpoints have been specified in Table 2.2-1. Operation with Setpoints less conservative than the Trip Setpoint but within the Allowable Value is acceptable since an allowance has been made in the safety analysis to accommodate this error.

The methodology to derive the Trip Setpoints is based upon combining all of the uncertainties in the channels. Inherent to the determination of the Trip Setpoints are the magnitudes of these channel uncertainties. Sensors and other instrumentation utilized in these channels are expected to be capable of operating within the allowances of these uncertainty magnitudes. Rack drift in excess of the Allowable Value exhibits the behavior that the rack has not met its allowance. Being that there is a small statistical chance that this will happen, an infrequent excessive drift is expected. Rack or sensor drift, in excess of the allowance that is more than occasional, may be indicative of more serious problems and should warrant further investigation.