November 4, 1998

Mr. Oliver D. Kingsley, President Nuclear Generation Group Commonwealth Edison Company Executive Towers West III 1400 Opus Place, Suite 500 Downers Grove, IL 60515

## SUBJECT: CORRECTION TO AMENDMENT - BYRON STATION AND BRAIDWOOD STATION (TAC NOS. M96449, M96450, M96451, M96452, MA0765, MA0766, MA0767 AND MA0768)

Dear Mr. Kingsley:

9811170061 981104

ADDCK

PDR

05

00454

PDR

By letter dated October 6, 1998, the U.S. Nuclear Regulatory Commission (Commission) issued Amendment No. 104 to Facility Operating License No. NPF-37 and Amendment No. 104 to Facility Operating License No. NPF-66 for the Byron Station, Unit Nos. 1 and 2, respectively, and Amendment No. 96 to Facility Operating License No. NPF-72 and Amendment No. 96 to Facility Operating License No. NPF-77 for the Braidwood Station, Unit Nos. 1 and 2, respectively. By letter dated October 15, 1998, the Commission issued Amendment No. 105 to Facility Operating License No. NPF-37 and Amendment No. 105 to Facility Operating License No. NPF-66 for the Byron Station, Unit Nos. 1 and 2, respectively, and Amendment No. 97 to Facility Operating License No. NPF-72 and Amendment No. 97 to Facility Operating License No. NPF-77 for the Braidwood Station, Unit Nos. 1 and 2, respectively. Subsequently, some typographical errors were noted in the revised Technical Specification pages that were enclosed with these amendments. The corrected Technical Specification pages are enclosed. We apologize for any inconvenience this may have caused you.

Sincerely,

ORIG. SIGNED BY Stewart N. Bailey, Project Manager Project Directorate III-2 Division of Reactor Projects - III/IV Office of Nuclear Reactor Regulation

ς Ι

C	Docket Nos. STN STN 50-456, ST	54, STI 457	N 50-45	55,	<u>DISTRIBUTION</u> : EAdensam, EGA1 CMoore (2)		PDIII-2 r/f SBailev	PUBLIC SRichards JHickman			
E	Enclosures: Corr	TS pa	ges		OGC, O15B18 ACRS, T2E26		GHill (8) MJordan, RII	WBe I	ckner	1	
c	c w/encls: See	next p	age			GHubbard		REmch	ТМа	rsh	Droi
DOCUMENT NAME: G:\PDIII-2\CM\BRAID-BY\BB96449.LTR To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy											
OFFICE	PM:PDIII-2	E	LA:RD	11-2	1e	PM:PDIII-2	e	D:PDIII-2	0	/	
NAME	SBAILEY SUB		dub	RE	I	JHICKMAN	274	SRICHARDS	58		
DATE	11/3 /98		11/3	/98		11/ 4 /98		11/ 4 /98			



# UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 4, 1998

Mr. Oliver D. Kingsley, President Nuclear Generation Group Commonwealth Edison Company Executive Towers West III 1400 Opus Place, Suite 500 Downers Grove, IL 60515

# SUBJECT: CORRECTION TO AMENDMENT - BYRON STATION AND BRAIDWOOD STATION (TAC NOS. M96449, M96450, M96451, M96452, MA0765, MA0766, MA0767 AND MA0768)

Dear Mr. Kingsley:

By letter dated October 6, 1998, the U.S. Nuclear Regulatory Commission (Commission) issued Amendment No. 104 to Facility Operating License No. NPF-37 and Amendment No. 104 to Facility Operating License No. NPF-66 for the Byron Station, Unit Nos. 1 and 2, respectively, and Amendment No. 96 to Facility Operating License No. NPF-72 and Amendment No. 96 to Facility Operating License No. NPF-77 for the Braidwood Station, Unit Nos. 1 and 2, respectively. By letter dated October 15, 1998, the Commission issued Amendment No. 105 to Facility Operating License No. NPF-37 and Amendment No. 105 to Facility Operating License No. NPF-66 for the Byron Station, Unit Nos. 1 and 2, respectively, and Amendment No. 97 to Facility Operating License No. NPF-72 and Amendment No. 97 to Facility Operating License No. NPF-77 for the Braidwood Station, Unit Nos. 1 and 2, respectively. Subsequently, some typographical errors were noted in the revised Technical Specification pages that were enclosed with these amendments. The corrected Technical Specification pages are enclosed. We apologize for any inconvenience this may have caused you.

Sincerely,

Stewart N. Bailey, Project-Manager Project Directorate III-2 Division of Reactor Projects - III/IV Office of Nuclear Reactor Regulation

Docket Nos. STN 50-454, STN 50-455, STN 50-456, STN 50-457

Enclosures: Corrected TS pages

cc w/encls: See next page

O. Kingsley Commonwealth Edison Company

CC:

Ms. C. Sue Hauser, Project Manager Westinghouse Electric Corporation Energy Systems Business Unit Post Office Box 355 Pittsburgh, Pennsylvania 15230

Joseph Gallo Gallo & Ross 1250 Eye St., N.W., Suite 302 Washington, DC 20005

Michael I. Miller, Esquire Sidley and Austin One First National Plaza Chicago, Illinois 60603

Howard A. Learner Environmental law and Policy Center of the Midwest 35 East Wacker Dr., Suite 1300 Chicago, Illinois 60601

U.S. Nuclear Regulatory Commission Byron Resident Inspectors Office 4448 N. German Church Road Byron, Illinois 61010-9750

Regional Administrator, Region III U.S. Nuclear Regulatory Commission 801 Warrenville Road Lisle, Illinois 60532-4351

Ms. Lorraine Creek RR 1, Box 182 Manteno, Illinois 60950

Chairman, Ogle County Board Post Office Box 357 Oregon, Illinois 61061

Mrs. Phillip B. Johnson 1907 Stratford Lane Rockford, Illinois 61107 Byron/Braidwood Stations

George L. Edgar Morgan, Lewis and Bochius 1800 M Street, N.W. Washington, DC 20036

Attorney General 500 S. Second Street Springfield, Illinois 62701

Illinois Department of Nuclear Safety Office of Nuclear Facility Safety 1035 Outer Park Drive Springfield, Illinois 62704

Commonwealth Edison Company Byron Station Manager 4450 N. German Church Road Byron, Illinois 61010-9794

Commonwealth Edison Company Site Vice President - Byron 4450 N. German Church Road Byron, Illinois 61010-9794

U.S. Nuclear Regulatory Commission Braidwood Resident Inspectors Office RR 1, Box 79 Braceville, Illinois 60407

Mr. Ron Stephens Illinois Emergency Services and Disaster Agency 110 E. Adams Street Springfield, Illinois 62706

Chairman Will County Board of Supervisors Will County Board Courthouse Joliet, Illinois 60434

Commonwealth Edison Company Braidwood Station Manager RR 1, Box 84 Braceville, Illinois 60407 O. Kingsley Commonwealth Edison Company

Ms. Bridget Little Rorem Appleseed Coordinator 117 N. Linden Street Essex, Illinois 60935

Document Control Desk-Licensing Commonwealth Edison Company 1400 Opus Place, Suite 400 Downers Grove, Illinois 60515

Commonwealth Edison Company Site Vice President - Braidwood RR 1, Box 84 Braceville, IL 60407

Mr. David Helwig Senior Vice President Commonwealth Edison Company Executive Towers West III 1400 Opus Place, Suite 900 Downers Grove, IL 60515

Mr. Gene H. Stanley PWR's Vice President Commonwealth Edison Company Executive Towers West III 1400 Opus Place, Suite 900 Downers Grove, IL 60515

Mr. Steve Perry BWR's Vice President Commonwealth Edison Company Executive Towers West III 1400 Opus Place, Suite 900 Downers Grove, IL 60515

Mr. Dennis Farrar Regulatory Services Manager Commonwealth Edison Company Executive Towers West III 1400 Opus Place, Suite 500 Downers Grove, IL 60515 - 2 -

#### Byron/Braidwood Stations

Ms. Irene Johnson, Licensing Director Nuclear Regulatory Services Commonwealth Edison Company Executive Towers West III 1400 Opus Place, Suite 500 Downers Grove, IL 60515

Commonwealth Edison Company Reg. Assurance Supervisor - Braidwood RR 1, Box 79 Braceville, Illinois 60407

Commonwealth Edison Company Reg. Assurance Supervisor - Byron 4450 N. German Church Road Byron, Illinois 61010-9794

Mr. Michael J. Wallace Senior Vice President Commonwealth Edison Company Executive Towers West III 1400 Opus Place, Suite 900 Downers Grove, IL 60515

# ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

FU	NCTI	ONAL UNIT		TRIP <u>SETPOINT</u>	ALLOWABLE
6.	Auxil	iary Feedwater (Continued	3)		
	f.	Division 11 for Unit 1 (Division 21 for Unit 2) ESF Bus Undervoltage- Start Motor-Driven Pump		2870 volts	2730 volts
	g.	Auxiliary Feedwater Pump Suction Pressure- Low (Transfer to Essential Service Water)		≥18.1 psia	≥17.4 psia <sup>`</sup>
7.	Auto Cont Isola	matic Opening of ainment Sump Suction tion Valves			
	a.	Automatic Actuation Logic and Actuation Relays		N.A.	N.A.
	b.	RWST Level-Low-Low Coincident with Safety Injection	See Item 1 above for Safety Injection	46.7%	44.7% Values
			decition is above for dalety injection	The suppling and Allowable	, yuuuuu

BYRON - UNITS 1 & 2

PLANT SYSTEMS

CONDENSATE STORAGE TANK

## LIMITING CONDITION FOR OPERATION

3.7.1.3 The condensate storage tank (CST) shall be OPERABLE with a contained water level of at least 60%\* (75%\*\*).

APPLICABILITY: MODES 1, 2, and 3.

### ACTION:

With the CST inoperable, within 4 hours either:

- a. Restore the CST to OPERABLE status or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours, or
- b. Demonstrate the OPERABILITY of the Essential Service Water System as a backup supply to the auxiliary feedwater pumps and restore the CST to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

### SURVEILLANCE REQUIREMENTS

4.7.1.3.1 The CST shall be demonstrated OPERABLE at least once per 12 hours by verifying the contained water level is within its limits when the tank is the supply source for the auxiliary feedwater pumps.

4.7.1.3.2 The Essential Service Water System shall be demonstrated OPERABLE at least once per 12 hours by performing the surveillance specified in Specification 4.7.4a. whenever the Essential Service Water System is the supply source for the auxiliary feedwater pumps.

\*Applicable to Unit 1 and to Unit 2 after Cycle 7. \*\*Not applicable to Unit 1. Applicable to Unit 2 through Cycle 7.

### PLANT SYSTEMS

CONDENSATE STORAGE TANK

### LIMITING CONDITION FOR OPERATION

3.7.1.3 The condensate storage tank (CST) shall be OPERABLE with a contained water level of at least 57%\* (66%\*\*) {80%\*\*\*}.

APPLICABILITY: MODES 1, 2, and 3.

#### ACTION:

With the CST inoperable, within 4 hours either:

- a. Restore the CST to OPERABLE status or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours, or
- b. Demonstrate the OPERABILITY of the Essential Service Water System as a backup supply to the auxiliary feedwater pumps and restore the CST to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

#### SURVEILLANCE REQUIREMENTS

4.7.1.3.1 The CST shall be demonstrated OPERABLE at least once per 12 hours by verifying the contained water level is within its limits when the tank is the supply source for the auxiliary feedwater pumps.

4.7.1.3.2 The Essential Service Water System shall be demonstrated OPERABLE at least once per 12 hours by performing the surveillance specified in Specification 4.7.4a. whenever the Essential Service Water System is the supply source for the auxiliary feedwater pumps.

\*Applicable to Unit 1 after Cycle 8 and to Unit 2 after Cycle 8. \*\*Applicable to Unit 1 after Cycle 7. Applicable to Unit 2. \*\*\*Applicable to Unit 1 through Cycle 7. Not applicable to Unit 2.

9811180082 981104 ADDCK 05000454 PDR

BRAIDWOOD - UNITS 1 & 2

### PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- 3) Verifying a system flow rate of 66,900 cfm  $\pm$  10% through the train and 22,300 cfm  $\pm$ 10% per bank through the exhaust filter plenum during operation when tested in accordance with ANSI N510-1980; and
- 4) Verifying that with the system operating at a flow rate of 66,900 cfm ±10% through the train and 22,300 cfm ±10% per bank and exhausting through the HEPA filter and charcoal adsorbers, the total bypass flow of the system and the damper leakage is less than or equal to 1% when the system is tested by admitting cold DOP at the system intake and the damper leakage rate is determined by either direct measurements or pressure decay measurements at a test pressure of 2 inches of water and the auxiliary building exhaust fans are operating at their rated flow.
- C. After every 720 hours of charcoal adsorber operation, by verifying, within 31 days after removal, that a laboratory analysis of a representative carbon sample obtained from each bank of adsorbers of the train in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory function 2, March 1978, when the average for a methyl iodide penetration of less than 1% when tested at a temperature of 30°C and a relative humidity of 70%.
- d. At least once per 18 months by:
  - Verifying for each filter bank of the train that the pressure drop across the combined HEPA filters and charcoal adsorber banks of less than 6.0 inches Water Gauge while operating the exhaust filter plenum at a flow rate of 66,900 cfm ± 10% through the train and 22,300 cfm ±10% per bank;
  - 2) Verifying that the exhaust filter plenum starts on manual initiation or Safety Injection test signal; and
  - 3) Verifying that the system maintains the ECCS equipment rooms at a negative pressure of greater than or equal to 1/4 in. Water Gauge relative to the outside atmosphere during system operation while operating at a flow rate of 66,900 cfm  $\pm 10\%$  through the train and 22,300 cfm  $\pm 10\%$  per bank.
- e. After each complete or partial replacement of a HEPA filter bank, by verifying that the exhaust filter plenum satisfies the in-place penetration testing acceptance criteria of less than 1% in accordance with ANSI N510-1980 for a DOP test aerosol while operating at a flow rate of 66,900 cfm  $\pm$  10% through the train and 22,300 cfm  $\pm$ 10% per bank; and