



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

MAR 14 2002

10 CFR 50.4

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of )  
Tennessee Valley Authority )

Docket No. 50-390

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 - STEAM GENERATOR TUBE  
INSPECTION - 15 DAY REPORT

This letter fulfills the reporting requirements contained in Technical Specification (TS) 5.9.9, "SG Tube Inspection Report." In accordance with TS 5.9.9, listed below are the number of steam generator (SG) tubes that were plugged or sleeved during the WBN Unit 1 Cycle 4 refueling outage:

Results of WBN Inservice Inspections		
	Number of Tubes	
SG Number	Plugged	Sleeved
1	28	0
2	37	0
3	34	0
4	87	0
<b>Totals</b>	186	0

D030

U.S. Nuclear Regulatory Commission

Page 2

MAR 14 2002

Should there be questions regarding this report, please contact me at (423) 365-1824.

Sincerely,

A handwritten signature in black ink, appearing to read "Paul L. Pace". The signature is fluid and cursive, with a large initial "P" and "L".

Paul L. Pace, Manager  
Site Licensing and Industry Affairs

cc: See page 3

U.S. Nuclear Regulatory Commission

Page 3

**MAR 14 2002**

cc:

NRC Resident Inspector  
Watts Bar Nuclear Plant  
1260 Nuclear Plant Road  
Spring City, Tennessee 37381

Mr. L. Mark Padovan, Senior Project Manager  
U.S. Nuclear Regulatory Commission  
MS 08G9  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852-2738

U.S. Nuclear Regulatory Commission  
Region II  
Sam Nunn Atlanta Federal Center  
61 Forsyth St., SW, Suite 23T85  
Atlanta, Georgia 30303