

P.O. Box 968 ■ Richland, Washington 99352-0968

March 12, 2002 GO2-02-041

Docket No. 50-397

U. S. Nuclear Regulatory Commission Document Control Desk Washington, D. C. 20555

Gentlemen:

Subject:

**COLUMBIA GENERATING STATION OPERATING LICENSE NPF-21** 

MONTHLY OPERATING REPORT

**FEBRUARY 2002** 

Transmitted herewith is the Monthly Operating Report for the month of February 2002 as required by Technical Specification 5.6.4.

Respectfully,

W.S. Oxenford (Mail Drop 927M)

Plant General Manager

Attachment

cc:

E.W. Merschoff - NRC RIV

J.S. Cushing - NRR

NRC Sr. Resident Inspector – 988C T.C. Poindexter - Winston & Strawn

**INPO** 

**ANI Library** 

Utility Data Institute

D.L. Williams - BPA / 1399

5224

## **OPERATING STATUS REPORT**

for Columbia Generating Station

Date: March 1, 2002

1.	Docket: 50-397			
2.	Reporting Period: February 2002			
3.	Utility Contact: Patricia Campbe	<b>II</b> (509) 377-4664		
4.	Design Electrical Rating (Net MWe)	:		1153
5.	Maximum Dependable Capacity - su		1107	
		MONTH	YEAR	CUMULATIVE
6.	Hours Reactor Critical	456.0	4 -000	
	Hours Reactor Critical	456.8	1,200.8	112,351.5
7.	Hours Generator On-Line	430.8 440.5	1,200.8 1,184.5	112,351.5 109,027.5
7. 8.			,	•
	Hours Generator On-Line	440.5	1,184.5	109,027.5

None

10.

Challenges to safety/relief valves:

## **UNIT SHUTDOWNS**

DOCKET NO.: 50-397

UNIT NAME: Columbia Generating Station

DATE: March 1, 2002

COMPLETED BY: P. Campbell TELEPHONE: (509) 377-4664

REPORT PERIOD: February, 2002

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method of Shutting Down(2)	Cause / Corrective Actions Comments
02-001	2/14/02	F	231.5	D	1	Technical Specification required shutdown due to emergency diesel generator inoperability.

**SUMMARY:** The plant began and ended the month at full power operation.

(1) REASON		(2) METHOD
A - Equipment Failure	E - Operator Training &	1 - Manual
B - Maintenance or Test	License Examination	2 - Manual Trip/Scram
C - Refueling	F - Administration	3 - Auto Trip/Scram
D - Regulatory Restriction	G - Operational Error	4 - Continuation
•	H - Other	5 – Other (Explain)