

May 6, 1997

Ms. Irene Johnson, Acting Manager
Nuclear Regulatory Services
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, IL 60515

SUBJECT: ISSUANCE OF AMENDMENTS (TAC NOS. M97161, M97162, M97163 AND M97164)

Dear Ms. Johnson:

The U.S. Nuclear Regulatory Commission (Commission) has issued the enclosed Amendment No. 89 to Facility Operating License No. NPF-37 and Amendment No. 89 to Facility Operating License No. NPF-66 for the Byron Station, Unit Nos. 1 and 2, respectively, and Amendment No. 81 to Facility Operating License No. NPF-72 and Amendment No. 81 to Facility Operating License No. NPF-77 for the Braidwood Station, Unit Nos. 1 and 2, respectively. The amendments are in response to Commonwealth Edison Company's application dated November 4, 1996, as supplemented on December 4, 1996, and March 20, 1997.

The amendments revise the technical specifications (TS) to permit the removal of containment tendon sheathing filler grease in up to 35 tendons for Byron, Unit 1, and Braidwood, Unit 1, in advance of the steam generator replacement outages. The grease will be removed approximately 6 months prior to the respective steam generator replacement outages. In addition, in Amendment No. 80 issued on April 16, 1997, the title in Braidwood's TS 6.9.1.7 was unintentionally left uncorrected. The corrected page is included in this amendment.

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/

George F. Dick, Senior Project Manager
Project Directorate III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-454, STN 50-455,
STN 50-456 and STN 50-457

- Enclosures: 1. Amendment No. 89 to NPF-37
- 2. Amendment No. 89 to NPF-66
- 3. Amendment No. 81 to NPF-72
- 4. Amendment No. 81 to NPF-77
- 5. Safety Evaluation

NRG FILE CENTER COPY

DFOI

cc w/encl: see next page

DISTRIBUTION: Docket File PUBLIC PDIII-2 r/f C. Grimes, 013H15
 R. Capra C. Moore (2) G. Dick (3) OGC, 015B18 G. Hill (8), T5C3
 ACRS, T2E26 H. Ashar J. Roe, JWR E. Adensam R. Lanksbury, RIII

*concurrence provided by SE dated 4/8/97; no major changes

DOCUMENT NAME: G:\CMNTJR\BRAID-BY\BB97161.AMD

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	PM:PDIII-2 <i>20</i> E	LA:PDIII-2 <i>2</i>	NRR:ECGB	OGC	D:PDIII-2 E
NAME	GDICK <i>GA</i>	CMOORE	*GBAGCHI	<i>C. Moore</i>	RCAPRA <i>Re</i>
DATE	04/30/97	04/30/97	04/08/97	05/02/97	05/6/97

9705120021 970506
PDR ADDCK 05000454
P PDR

OFFICIAL RECORD COPY

subject to changes NOTED

CP1

Commonwealth Edison Company
Braidwood Station Manager
Rt. 1, Box 84
Braceville, Illinois 60407

Ms. Bridget Little Rorem
Appleseed Coordinator
117 North Linden Street
Essex, Illinois 60935

Document Control Desk-Licensing
Commonwealth Edison Company
1400 Opus Place, Suite 400
Downers Grove, Illinois 60515

Mr. H. G. Stanley
Site Vice President
Braidwood Station
Commonwealth Edison Company
RR 1, Box 84
Braceville, IL 60407

I. Johnson
Commonwealth Edison Company

cc:

Mr. William P. Poirier, Director
Westinghouse Electric Corporation
Energy Systems Business Unit
Post Office Box 355, Bay 236 West
Pittsburgh, Pennsylvania 15230

Joseph Gallo
Gallo & Ross
1250 Eye St., N.W.
Suite 302
Washington, DC 20005

Michael I. Miller, Esquire
Sidley and Austin
One First National Plaza
Chicago, Illinois 60603

Howard A. Learner
Environmental Law and Policy
Center of the Midwest
203 North LaSalle Street
Suite 1390
Chicago, Illinois 60601

U.S. Nuclear Regulatory Commission
Byron Resident Inspectors Office
4448 North German Church Road
Byron, Illinois 61010-9750

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Ms. Lorraine Creek
Rt. 1, Box 182
Manteno, Illinois 60950

Chairman, Ogle County Board
Post Office Box 357
Oregon, Illinois 61061

Mrs. Phillip B. Johnson
1907 Stratford Lane
Rockford, Illinois 61107

Byron/Braidwood Power Stations

George L. Edgar
Morgan, Lewis and Bochi
1800 M Street, N.W.
Washington, DC 20036

Attorney General
500 South Second Street
Springfield, Illinois 62701

EIS Review Coordinator
U.S. Environmental Protection Agency
77 W. Jackson Blvd.
Chicago, Illinois 60604-3590

Illinois Department of
Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Commonwealth Edison Company
Byron Station Manager
4450 North German Church Road
Byron, Illinois 61010

Kenneth Graesser, Site Vice President
Byron Station
Commonwealth Edison Station
4450 N. German Church Road
Byron, Illinois 61010

U.S. Nuclear Regulatory Commission
Braidwood Resident Inspectors Office
Rural Route #1, Box 79
Braceville, Illinois 60407

Mr. Ron Stephens
Illinois Emergency Services
and Disaster Agency
110 East Adams Street
Springfield, Illinois 62706

Chairman
Will County Board of Supervisors
Will County Board Courthouse
Joliet, Illinois 60434



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

COMMONWEALTH EDISON COMPANY

DOCKET NO. STN 50-454

BYRON STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 89
License No. NPF-37


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated November 4, 1996, as supplemented on December 4, 1996, and March 20, 1997, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-37 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 89 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



George F. Dick, Senior Project Manager
Project Directorate III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 6, 1997



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

COMMONWEALTH EDISON COMPANY

DOCKET NO. STN 50-455

BYRON STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 89
License No. NPF-66


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated November 4, 1996, as supplemented on December 4, 1996, and March 20, 1997, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-66 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A (NUREG-1113), as revised through Amendment No. 89 and revised by Attachment 2 to NPF-66, and the Environmental Protection Plan contained in Appendix B, both of which were attached to License No. NPF-37, dated February 14, 1985, are hereby incorporated into this license. Attachment 2 contains a revision to Appendix A which is hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



George F. Dick, Senior Project Manager
Project Directorate III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 6, 1997

ATTACHMENT TO LICENSE AMENDMENT NOS. 89 AND 89
FACILITY OPERATING LICENSE NOS. NPF-37 AND NPF-66
DOCKET NOS. STN 50-454 AND STN 50-455

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Pages indicated by an asterisk (*) are provided for convenience only.

Remove Pages

*3/4 6-7

3/4 6-8

Insert Pages

*3/4 6-7

3/4 6-8

CONTAINMENT SYSTEMS

AIR TEMPERATURE

LIMITING CONDITION FOR OPERATION

3.6.1.5 Primary containment average air temperature shall not exceed 120°F.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With the containment average air temperature greater than 120°F, reduce the average air temperature to within the limit within 8 hours, or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.5 The primary containment average air temperature shall be the arithmetical average of the temperatures of the running fans at the following locations and shall be determined at least once per 24 hours:

Location

- A RCFC Dry Bulb Inlet Temperature
- B RCFC Dry Bulb Inlet Temperature
- C RCFC Dry Bulb Inlet Temperature
- D RCFC Dry Bulb Inlet Temperature

CONTAINMENT SYSTEMS

CONTAINMENT VESSEL STRUCTURAL INTEGRITY

LIMITING CONDITION FOR OPERATION

3.6.1.6 The structural integrity of the containment vessel shall be maintained at a level consistent with the acceptance criteria in Specifications 4.6.1.6.1*, 4.6.1.6.2, and 4.6.1.6.3.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

- a. With more than one tendon with an observed lift-off force between the predicted lower limit and 90% of the predicted lower limit or with one tendon below 90% of the predicted lower limit, restore the tendon(s) to the required level of integrity within 15 days and perform an engineering evaluation of the containment and provide a Special Report to the Commission within 30 days in accordance with Specification 6.9.2 or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With any abnormal degradation of the structural integrity other than ACTION a. at a level below the acceptance criteria of Specifications 4.6.1.6.1, 4.6.1.6.2, and 4.6.1.6.3, restore the containment vessel to the required level of integrity within 72 hours and perform an engineering evaluation of the containment and provide a Special Report to the Commission within 15 days in accordance with Specification 6.9.2 or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.6.1 Containment Vessel Tendons. The containment vessel tendons' structural integrity shall be demonstrated at the end of 1, 3, and 5 years following the initial containment vessel structural integrity test and at 5-year intervals thereafter. The tendons' structural integrity shall be demonstrated by:

- a. Determining that a random but representative sample of at least 19 tendons (5 dome, 6 vertical, and 8 hoop) each have an observed lift-off force within predicted limits for each. For each subsequent inspection one tendon from each group may be kept unchanged to develop a history and to correlate the observed data. If the observed lift-off force of any one tendon in the original sample population lies between the predicted lower limit and 90% of the predicted lower limit, two tendons, one on each side of this tendon should be checked for their lift-off forces. If both of these adjacent tendons are found to be within their predicted limits, all three tendons should be restored to the required level of integrity. This single deficiency may be considered unique and acceptable. Unless there is abnormal degradation of the containment vessel during the first three inspections, the sample population for subsequent inspections shall include at least 10 tendons (3 dome, 3 vertical, and 4 hoop);

*Unit 1 may have sheathing filler grease voids in excess of 5% of the net duct volume for up to 35 tendons until the end of B1R08.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

COMMONWEALTH EDISON COMPANY

DOCKET NO. STN 50-456

BRAIDWOOD STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 81
License No. NPF-72


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated November 4, 1996, as supplemented on December 4, 1996, and March 20, 1997, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-72 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 81 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



George F. Dick, Senior Project Manager
Project Directorate III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 6, 1997



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

COMMONWEALTH EDISON COMPANY

DOCKET NO. STN 50-457

BRAIDWOOD STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 81
License No. NPF-77


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated November 4, 1996, as supplemented on December 4, 1996, and March 20, 1997, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-77 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 81 and the Environmental Protection Plan contained in Appendix B, both of which were attached to License No. NPF-72, dated July 2, 1987, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



George F. Dick, Senior Project Manager
Project Directorate III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 6, 1997

ATTACHMENT TO LICENSE AMENDMENT NOS. 81 AND 81
FACILITY OPERATING LICENSE NOS. NPF-72 AND NPF-77
DOCKET NOS. STN 50-456 AND STN 50-457

Replace the following pages of the Appendix "A" Technical Specifications with the attached pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change. Pages indicated by an asterisk (*) are provided for convenience only.

Remove Pages

*3/4 6-7

3/4 6-8

Insert Pages

*3/4 6-7

3/4 6-8

CONTAINMENT SYSTEMS

AIR TEMPERATURE

LIMITING CONDITION FOR OPERATION

3.6.1.5 Primary containment average air temperature shall not exceed 120°F.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With the containment average air temperature greater than 120°F, reduce the average air temperature to within the limit within 8 hours, or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.5 The primary containment average air temperature shall be the arithmetical average of the temperatures of the running fans at the following locations and shall be determined at least once per 24 hours:

Location

- A RCFC Dry Bulb Inlet Temperature
- B RCFC Dry Bulb Inlet Temperature
- C RCFC Dry Bulb Inlet Temperature
- D RCFC Dry Bulb Inlet Temperature.

CONTAINMENT SYSTEMS

CONTAINMENT VESSEL STRUCTURAL INTEGRITY

LIMITING CONDITION FOR OPERATION

3.6.1.6 The structural integrity of the containment vessel shall be maintained at a level consistent with the acceptance criteria in Specifications 4.6.1.6.1*, 4.6.1.6.2, and 4.6.1.6.3.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

- a. With more than one tendon with an observed lift-off force between the predicted lower limit and 90% of the predicted lower limit or with one tendon below 90% of the predicted lower limit, restore the tendon(s) to the required level of integrity within 15 days and perform an engineering evaluation of the containment and provide a Special Report to the Commission within 30 days in accordance with Specification 6.9.2 or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With any abnormal degradation of the structural integrity other than ACTION a. at a level below the acceptance criteria of Specifications 4.6.1.6.1, 4.6.1.6.2, and 4.6.1.6.3, restore the containment vessel to the required level of integrity within 72 hours and perform an engineering evaluation of the containment and provide a Special Report to the Commission within 15 days in accordance with Specification 6.9.2 or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.6.1 Containment Vessel Tendons. The containment vessel tendons' structural integrity shall be demonstrated at the end of 1, 3, and 5 years following the initial containment vessel structural integrity test and at 5-year intervals thereafter. The tendons' structural integrity shall be demonstrated by:

- a. Determining that a random but representative sample of at least 19 tendons (5 dome, 6 vertical, and 8 hoop) each have an observed lift-off force within predicted limits for each. For each subsequent inspection one tendon from each group may be kept unchanged to develop a history and to correlate the observed data. If the observed lift-off force of any one tendon in the original sample population lies between the predicted lower limit and 90% of the predicted lower limit, two tendons, one on each side of this tendon should be checked for their lift-off forces. If both of these adjacent tendons are found to be within their predicted limits, all three tendons should be restored to the required level of integrity. This single deficiency may be considered unique and acceptable. Unless there is abnormal degradation of the containment vessel during the first three inspections, the sample population for subsequent inspections shall include at least 10 tendons (3 dome, 3 vertical, and 4 hoop);

*Unit 1 may have sheathing filler grease voids in excess of 5% of the net duct volume for up to 35 tendons from May 1, 1998, until the end of A1R07.

ADMINISTRATIVE CONTROLS

REPORTING REQUIREMENTS (Continued)

ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT*

6.9.1.6 The Annual Radiological Environmental Operating Report covering the operation of the facility during the previous calendar year shall be submitted prior to May 1 of each year. The report shall include summaries, interpretations, and analysis of trends of the results of the Radiological Environmental Monitoring Program for the reporting period. The material provided shall be consistent with the objectives outlined in (1) the ODCM and (2) Sections IV.B.2, IV.B.3, and IV.C of Appendix I to 10 CFR Part 50.

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT**

6.9.1.7 A Radioactive Effluent Release Report covering the operation of the facility during the previous year shall be submitted prior to May 1 of each year. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the facility. The material provided shall be (1) consistent with the objectives outlined in the ODCM and PCP and (2) in conformance with 10 CFR 50.36a and Section IV.B.1 of Appendix I to 10 CFR Part 50.

MONTHLY OPERATING REPORT

6.9.1.8 Routine reports of operating statistics and shutdown experience, including documentation of all challenges to the PORVs or RCS safety valves, shall be submitted on a monthly basis to the Director, Office of Resource Management, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, with a copy to the Regional Administrator of the NRC Regional Office, no later than the 15th of each month following the calendar month covered by the report.

OPERATING LIMITS REPORT

6.9.1.9 Operating limits shall be established and documented in the OPERATING LIMITS REPORT (OLR) before each reload cycle or any remaining part of a reload cycle for the following:

1. Moderator Temperature Coefficient for Specification 3.1.1.3,
2. Shutdown Bank Insertion Limit for Specification 3.1.3.5,
3. Control Bank Insertion Limit for Specification 3.1.3.6,
4. Axial Flux Difference Limits, Target Band for Specification 3.2.1,
5. Heat Flux Hot Channel Factor and $K(Z)$ for Specification 3.2.2,
6. Nuclear Enthalpy Rise Hot Channel Factor, and Power Factor Multiplier for Specification 3.2.3, and
7. F_{xy} Radial Peaking Factor for Specification 4.2.2.2.

*A single submittal may be made for a multi-unit station.

**A single submittal may be made for a multi-unit station. The submittal should combine those sections that are common to all units at the station; however, for units with separate radwaste systems, the submittal shall specify the releases of radioactive material from each unit.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 89 TO FACILITY OPERATING LICENSE NO. NPF-37,
AMENDMENT NO. 89 TO FACILITY OPERATING LICENSE NO. NPF-66,
AMENDMENT NO. 81 TO FACILITY OPERATING LICENSE NO. NPF-72,
AND AMENDMENT NO. 81 TO FACILITY OPERATING LICENSE NO. NPF-77
COMMONWEALTH EDISON COMPANY
BYRON STATION, UNIT NOS. 1 AND 2
BRAIDWOOD STATION, UNIT NOS. 1 AND 2
DOCKET NOS. STN 50-454, STN 50-455, STN 50-456 AND STN 50-457

1.0 INTRODUCTION

By letter dated November 4, 1996, as supplemented on December 4, 1996, and March 20, 1997, Commonwealth Edison Company (ComEd, the licensee), proposed to amend the Technical Specifications (TS) for Byron Nuclear Power Station, Unit 1 (Byron 1); and Braidwood Nuclear Power Station, Unit 1 (Braidwood 1). The licensee proposed to revise TS 3.6.1.6, "Containment Vessel Structural Integrity" to allow a one-time exception to requirement 4.6.1.6.1.e.1) of the TS surveillance requirements (TSSR) in support of Unit 1 steam generator replacement (SGR) at each station. The TSSR requires that the voids in sheathing filler grease, which inhibits the corrosion of prestressing tendon, shall not exceed 5 percent. To facilitate detensioning and removal of the selected prestressing tendons from the tendon sheathing prior to cutting an opening in the containment, during cool weather, the licensee plans to remove the grease during a warmer season. Thus, the Amendment requests a waiver from the TSSR requirement until after the replacement of the respective steam generators. The March 20, 1997, submittal provided additional clarifying information that did not change the initial proposed no significant hazards consideration determination.

2.0 EVALUATION

The containment structures for Byron and Braidwood stations consist of cylinders with shallow-dome roofs supported by flat circular foundation slabs. The cylinder and dome of each containment structure are prestressed with hoop, vertical and dome tendons. Each tendon consists of 170 stress relieved, cold drawn wires, and is installed in 6-inch diameter sheet metal tendon sheathing. The sheathings are filled with corrosion inhibiting grease to protect the tendons. To accommodate the replacement of the steam generators at Byron 1 and Braidwood 1, a temporary access opening through the containment

cylindrical wall will be required. This opening will be approximately 20 feet wide and 22 feet high, located 62 feet above grade. Twenty-one hoop tendons and 10 vertical tendons will be intercepted by the opening. These tendons will have to be removed prior to cutting the opening. The proposed Amendment requests the potential removal of grease from 35 tendons.

The schedule for cutting the opening in Byron 1 containment indicates that the plant will be shut down in November 1997 for SGR activities. Expected cold weather during this month will make it difficult to remove thickened grease from the tendon sheathings. Therefore, the licensee plans to remove the grease from the selected tendons in June 1997. Thus, the selected tendons will remain without grease for 5 months during operation of the plant and reactor. Braidwood 1 requested approval to operate without grease in some tendons from May 1, 1998 until its fall 1998 refueling outage. That outage is currently scheduled to begin on September 5, 1998. Without the amendment to the TSSR, this condition would violate the requirement that the voids in the sheathing filler grease not exceed 5 percent of the net volume of the sheathing. The licensee's technical evaluation consists of ensuring that the containment integrity will not be compromised due to the lack of corrosion inhibiting grease in 35 tendons during the 6 month period.

The licensee provides the following reasons in support of the proposed TS Amendment:

1. A source of dry air will be used to pressurize the tendon sheathing to remove the grease. Use of dry air will ensure that no moisture is introduced in the sheathing.
2. During tendon fabrication all tendon wires were completely immersed in rust protective coating.
3. The coiled tendons and the interior surface of the tendon sheathing were coated after fabrication to provide additional corrosion protection during storage and handling.
4. Initial installation of the grease involved pumping heated grease into the sheathing to completely fill the sheathing.
5. The results of the prior three surveillances met the TSSR requirements for prestressing forces, grease qualifications, and anchorages of tendons.
6. Experience data for other similar plants (Fort Calhoun, Wolf Creek) indicated that with voids of up to 36 percent existing for several years, the tendon wires showed no signs of corrosion.
7. Industry experience: several tendons were removed from a containment structure (non-operating plant), wrapped in plastic and stored outside from April to December subject to weather elements (rain, sun, snow, and freezing temperatures). In December, the plastic wraps were opened and

five to ten gallons of water were found. The inspection of individual wires showed no signs of corrosion. The licensee notes this as a demonstration of the effectiveness of the corrosion protection methods (items 2, 3, and 4 above) used for tendons in containments.

8. The licensee states that the end anchorages of hoop and vertical tendons are protected from exposure to weather because of the existing enclosures over buttresses and dome walkways at all Units of Byron and Braidwood.

The licensee stated that following the steam generator replacement outage, the tendons will be retensioned to their required level of prestressing force and the sheathing will be refilled with grease. In addition, the licensee stated that it will include in the next tendon surveillance, one of the tendons from each group (horizontal and vertical).

The staff recognizes the validity of the above reasons as support for the proposed TS amendment, and agrees with the licensee's contention regarding the effectiveness of the original rust-preventive coatings. The dry air procedure for removing the grease will ensure that the moisture is not introduced during the grease removal process. Also, the enclosures over the ends of the exposed anchorages of the 35 tendons will protect them against direct intrusion of moisture in the uncovered tendons. Considering the short period (6 months or less) involved in implementation of the amended TS, the staff concludes that the containment integrity will not be compromised during this period.

3.0 SUMMARY

Based on the review of the licensee's amendment request and its additional information, the staff concludes that the containment structural integrity will not be compromised under operating and shutdown modes prior to defueling of the respective reactors during the period when the grease is removed from the selected prestressing tendons. Based on the schedule of SGR activities, the period will not exceed 6 months.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Illinois State official was notified of the proposed issuance of the amendments. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the

amendments involve no significant hazards consideration, and there has been no public comment on such finding (62 FR 2186). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: H. Ashar

Date: May 6, 1997