

DISTRIBUTION

Docket JRBuchanan
 NRC PDR TBAbernathy
 Local PDR WMcDonald, MIPC
 ORB #2 Reading
 BCRusche
 EGCASE
 KRgoller/TJCarter
 RMDiggs
 RPSnaider
 PWO'Connor
 OELD
 OI&E (3)
 BJones
 BScharf (10)
 DEisenhut
 ACRS (16)
 OPA (CMiles)

Docket No. 50-263

MAR 11 1977

Northern States Power Company
 ATTN: Mr. L. O. Mayer, Manager
 Nuclear Support Services
 414 Nicollet Mall - Eighth Floor
 Minneapolis, Minnesota 55401

Gentlemen:

RE: MONTICELLO NUCLEAR GENERATING PLANT

The enclosed Order of Modification pertains to Facility Operating License No. DPR-22 issued for Monticello Nuclear Generating Plant. The Order corrects errors and reflects changes in the methods of analysis in the ECCS performance evaluation submitted in accordance with 10 CFR § 50.46.

The errors detected were of the nature of inputs to computer codes used in the analyses or were due to numerical errors in the calculations performed. The total impact of the errors and model changes is conservative and no reduction of plant operating limits is required to accommodate the presence of the errors.

This Order confirms the appropriateness of Northern States Power Company's voluntary action of agreeing to submit, on a timely basis, an ECCS re-evaluation using a General Electric ECCS evaluation model approved by the staff.

A copy of the Order is being filed with the Office of the Federal Register for publication.

Sincerely,

Original Signed by:
 Dennis L. Ziemann
 Dennis L. Ziemann, Chief
 Operating Reactors Branch #2
 Division of Operating Reactors

Enclosure:
 Order for Modification
 of License

cc w/enclosure:
 See next page

RMD
 RMDiggs
 3/10/77

VStello
 DOR:DIR
 VStello
 3/11/77

EGCase
 NRR:D/DIR
 EGCASE
 3/ 177

BCRusche
 NRR:DIR
 BCRusche
 3/ 177

OFFICE >	DOR:ORB #2	DOR:ORB #2	DOR:ORB #2	OELD	<i>See P.ogram</i> DOR:AD/OT	<i>See P.ogram</i> DOR:AD/ORS
SURNAME >	RPSnaider:ro	PWO'Connor	DLZiemann	<i>Krossman</i>	DEisenhut	KRGoller
DATE >	3/10/77	3/11/77	3/11/77	3/11/77	3/9/77	3/10/77

March 11, 1977

cc w/enclosure:

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and
Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Arthur Renquist, Esquire
Vice President - Law
Northern States Power Company
414 Nicollet Mall
Minneapolis, Minnesota 55401

Howard J. Vogel, Esquire
Legal Counsel
2750 Dean Parkway
Minneapolis, Minnesota 55416

Mr. Kenneth Dzigan
Environmental Planning Consultant
Office of City Planner
Grace Building
421 Wabasha Street
St. Paul, Minnesota 55102

Sandra S. Gardebring
Executive Director
Minnesota Pollution Control Agency
1935 W. County Road B2
Roseville, Minnesota 55113

Anthony Z. Roisman, Esquire
Roisman, Kessler and Cashdan
1025 15th Street, N. W., 5th Floor
Washington, D. C. 20005

The Environmental Conservation Library
Minneapolis Public Library
300 Nicollet Mall
Minneapolis, Minnesota 55401

Mr. D. S. Douglas, Auditor
Wright County Board of Commissioners
Buffalo, Minnesota 55313

State Department of Health
ATTN: Secretary & Executive Officer
University Campus
Minneapolis, Minnesota 55440

Chief, Energy Systems
Analyses Branch (AW-459)
Office of Radiation Programs
U. S. Environmental Protection Agency
Room 645, East Tower
401 M Street, S. W.
Washington, D. C. 20460

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: EIS COORDINATOR
230 South Dearborn Street
Chicago, Illinois 60604

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
Northern States Power Company) Docket No. 50-263
Monticello Nuclear Generating)
Plant)

ORDER FOR MODIFICATION OF LICENSE

I.

The Northern States Power Company (the licensee), is the holder of Provisional Operating License No. DPR-22 which authorizes the operation of the nuclear power reactor known as Monticello Nuclear Generating Plant (the facility) at steady state reactor power levels not in excess of 1670 megawatts thermal (rated power). The facility consists of a boiling water reactor (BWR) located at the licensee's site in Wright County, Minnesota.

II.

In conformance with evaluations of the performance of the Emergency Core Cooling System (ECCS) of the facility submitted by the licensee on July 9, 1975, and supplements thereto dated August 4, 1975, and April 23, 1976, the Technical Specifications issued for the facility on October 30, 1975, and June 18, 1976, limit the Average Planar Heat Generation Rates to the values shown on Technical Specifications Figures 3.11.1-A through 3.11.1-D.

The ECCS performance evaluation submitted by the licensee was based upon a previously approved ECCS evaluation model developed by General Electric Company (General Electric), the designer of the facility. This model has been found to conform to the requirements of the Commission's ECCS

Acceptance Criteria, 10 CFR Part 50 § 50.46 and Appendix K. The evaluation indicated that with the average planar linear heat generation rate limited as set forth above, and with the other limits set forth in the facility's Technical Specifications, the ECCS cooling performance for the facility would conform with the criteria contained in 10 CFR § 50.46(b) which govern calculated peak clad temperature, maximum cladding oxidation, maximum hydrogen generation, coolable geometry and long term cooling.

Recently, the NRC staff was informed by General Electric that several errors had been discovered in the computer codes used to calculate peak clad temperature and the clad oxidation percentage in the General Electric evaluation model. These errors have been discovered by General Electric during a continuing internal Quality Assurance audit of their LOCA evaluation model codes. This audit is still under way and the errors reported reflect those found to date. The additional effort expended by the vendor to enhance the assurance of the quality of its evaluation model, the staff believes, was prudent and desirable. Identification of additional errors of a minor nature may still develop during the ongoing QA checks. Nonetheless, the staff believes it appropriate to order the correction of those uncovered thus far. While some of these errors discussed herein have either no significant effect or a conservative effect on the evaluation results, one or more of the errors included in the Monticello ECCS evaluation leads to non-conservative values. Based on a preliminary assessment, including information and supportive calculations by General Electric, the NRC staff has determined that the

combined effect of the following code errors would, when corrected, result in an ECCS evaluation requiring no reduction in operating limits for Monticello.

(1) Pressure Rule

The LAMB code is used to calculate system pressure during the LOCA. This calculated pressure is then used as an input to the REFLOOD code which calculates the water level vs time relationship in the core. General Electric used an approximation of the pressure response of the LAMB code that was thought, at the time of approval, to be an acceptable representation of the physical phenomena involved. Later application of this approximation to certain cases showed it to be non-conservative. General Electric proposes to correct this nonconservatism by utilizing a conservative approximation to the pressure rule for input into REFLOOD. This correction increases reflood time by 0 to 50 seconds and decreases MAPLHGR by 0 to 5%.

(2) Bundle Vaporization

General Electric has used incorrect coefficients in the calculation of the amount of vaporization occurring during core spray. The vapor formation in the bundle is a prime determinant of the amount of spray water that can get through the upper tie plate and reflood the core. The vapor formation was under-calculated by approximately 4% resulting in a 20-second increase in reflooding time and about a 2% decrease in the MAPLHGR.

(3) Discharge Break Modeling

General Electric proposes to take credit for an approved model for suction line friction (from the vessel nozzle to the discharge side of the

recirculation pump) that improves reflooding time for the discharge break by approximately 15 seconds. This increases the MAPLHGR for discharge break limited plants by about 1.5%. This error does not apply to Monticello.

(4) Structural Absorption of Gamma Heat

General Electric has erroneously taken double credit for power generation in non-fuel structural material. Correction of this error results in approximately a 4% decrease in the MAPLHGR for certain plants. This error does not apply to Monticello.

(5) Increased Counter Current Flow Limiting (CCFL) Differential Pressure

Some experimental evidence exists that the differential pressure in a fuel assembly during periods of CCFL may be higher than previously assumed. This could cause a delay in reflood time. Correction of this error reduces the Monticello MAPLHGR by 1 to 2%.

(6) Others

Several small changes of inputs to the evaluation codes were identified as being necessary to correct errors. They included:

- (a) The use of actual plant specific break areas for the LOCA;
- (b) A reduced core plate weight;
- (c) An increase in the peripheral bypass area used in the counter current flooding calculations;
- (d) The correction of a decimal point error in the assumed guide tube thickness; and
- (e) Credit is no longer assumed for recirculation loop discharge valve closure during blowdown.

Due to the errors in the ECCS analysis currently approved by NRC for Monticello, the staff requested the licensee to submit an estimate of the impact of these errors on the peak clad temperature that would result from the worst break, if the errors were corrected. The revised ECCS calculations indicated that the MAPLHGR is conservative by approximately 2% considering the cumulative effect of these errors. Although GE model changes under review by the staff generically show that MAPLHGR limits even higher than those presently set forth in the Technical Specifications for Monticello would still satisfy ECCS limits, no credit for such increase was considered by the NRC.

The staff expects that when final revised calculations for the facility are submitted using the revised and corrected model, they will demonstrate that operation with the linear heat generation rates set forth in this Order will conform to the Criteria of 10 CFR § 50.46(b). Such revised calculations fully conforming to the requirements of 10 CFR § 50.46 are to be provided for the facility as soon as possible.

As discussed herein, the present MAPLHGR limits for this facility are such that they assure that the ECCS will conform to the performance requirements of 10 CFR § 50.46. Accordingly, such limits provide reasonable assurance that the public health and safety will not be endangered.

Upon notification by the NRC staff on February 14, 1977, the licensee committed to submit a re-evaluation of the ECCS performance of Monticello on a timely basis. The staff believes that the licensee's action, under the circumstances, is appropriate and that this action should be confirmed by NRC Order.

III.


Copies of the following documents are available for inspection at the Commission's Public Document Room at 1717 H Street, Washington, D. C. 20555 and are being placed in the Commission's local public document room at the Environmental Conservation Library, Minneapolis Public Library, 300 Nicollet Mall, Minneapolis, Minnesota 55401.

- (1) Letters from General Electric to NRC dated February 14, 1977, and January 26, 1977;
- (2) Letters from Northern States Power Company to the Director of Nuclear Reactor Regulation dated January 18, 1977, and February 18, 1977;
- (3) Letter dated July 9, 1975, from Northern States Power Company to NRC and supplements thereto dated August 4, 1975, and April 23, 1976;
- (4) This Order for Modification of License in the matter of Northern States Power Company (Monticello Nuclear Generating Plant).

Accordingly, pursuant to the Atomic Energy Act of 1954, as amended, and the Commission's Rules and Regulations in 10 CFR Parts 2 and 50, IT IS ORDERED THAT Provisional Operating License No. DPR-22 is hereby amended by adding the following new provision:

- (1) As soon as possible, the licensee shall submit a re-evaluation of ECCS cooling performance calculated in accordance with General Electric Company's Evaluation Model approved by the NRC staff and corrected for the errors described herein and any other corrections in the Model of which the licensee is aware at the time the calculations are performed.

FOR THE NUCLEAR REGULATORY COMMISSION



Ben C. Rusche, Director
Office of Nuclear Reactor Regulation

Dated in Bethesda, Maryland
this 11th day of March, 1977.

Docket No. 50-263

JUN 25 1976

Northern States Power Company
ATTN: Mr. L. O. Mayer, Manager
Nuclear Support Services
414 Nicollet Mall - 8th Floor
Minneapolis, Minnesota 55401

Gentlemen:

Thank you for advising us of the error in referencing Amendment No. 22 in lieu of Amendment No. 20 on the revised Technical Specification pages issued by us as part of Amendment No. 20 to License No. DPR-22 on June 18, 1976. By copy of this letter, our records and other recipients of Amendment No. 20 are being informed of this oversight by us.

DISTRIBUTION

Docket VStello
NRC PDR³ ACRS (16)
Local PDR TBarbarnathy
ORB #2 Reading JRBuchanan
OELD - SLewis
OI&E (3)
BJones (4)
JMcGough
RMDiggs
RPSnaider
DLZiemann
KRGoller
TJCarter
BScharf (10)
DEisenhut

Sincerely,

Original Signed by:
Dennis L. Ziemann

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

cc: see next page

DLS

OFFICE	DOR:ORB #2	DOR:ORB #2			
SURNAME	<i>RMDiggs</i> RMDiggs:ah	DLZiemann			
DATE	6/21/76	6/25/76			

June 25, 1976

cc

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and
Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Arthur Renquist, Esquire
Vice President - Law
Northern States Power Company
414 Nicollet Mall
Minneapolis, Minnesota 55401

Howard J. Vogel, Esquire
Legal Counsel
2750 Dean Parkway
Minneapolis, Minnesota 55416

Mr. Steve J. Gadler
2120 Carter Avenue
St. Paul, Minnesota 55108

Daniel L. Ficker, Esquire
Assistant City Attorney
Criminal Division
638 City Hall
St. Paul, Minnesota 55102

Mr. Kenneth Dzugan
Environmental Planning Consultant
Office of City Planner
Grace Building
421 Wabasha Street
St. Paul, Minnesota 55102

Sandra S. Gardebring, Esquire
Special Assistant Attorney General
Minnesota Pollution Control Agency
1935 W. County Road B2
Roseville, Minnesota 55113

Anthony Z. Roisman, Esquire
Roisman, Kessler and Cashdan
1712 N Street, N. W.
Washington, D. C. 20036

The Environmental Conservation
Library
Minneapolis Public Library
300 Nicollet Mall
Minneapolis, Minnesota 55401

Mr. D. S. Douglas, Auditor
Wright County Board of
Commissioners
Buffalo, Minnesota 55313

Warren H. Lawson, M. D.
Secretary and Executive Officer
State Department of Health
University Campus
Minneapolis, Minnesota 55440