

JUN 18 1976

TBAbernathy  
JRBuchanan

DISTRIBUTION:  
Docket  
NRC PDR  
Local PDR  
ORB-2 Reading  
Attorney, OELD  
OI&E (3)  
BJones (4)  
JMcGough  
RMDiggs  
RSnaider  
DLZiemann  
KRGoller  
TJCarter  
BScharf (10)  
DEisenhut  
VStello  
ACRS (16)

Docket No. 50-263

Northern States Power Company  
ATTN: Mr. L. O. Mayer  
Manager of Nuclear Support  
Services  
414 Nicollet Mall - 8th Floor  
Minneapolis, Minnesota 55401

Gentlemen:

In response to your request dated April 23, 1976, the Commission has issued the enclosed Amendment No. 20 to Provisional Operating License No. DPR-22 for the Monticello Nuclear Generating Plant. The amendment consists of changes to the Technical Specifications to incorporate more specific Limiting Conditions for Operation (LCO's) for the Average Planar Linear Heat Generation Rate (APLHGR), Linear Heat Generation Rate (LHGR), and Minimum Critical Power Ratio (MCPR). Your request has been modified as necessary to meet our requirements. The modifications have been discussed with your staff.

Copies of the related Safety Evaluation and the Federal Register Notice are also enclosed.

Sincerely,

Original signed by  
Dennis L. Ziemann

Dennis L. Ziemann, Chief  
Operating Reactors Branch #2  
Division of Operating Reactors

Enclosures:

1. Amendment No. 20 to DPR-22
2. Safety Evaluation
3. Federal Register Notice

cc w/enclosures:  
See next page

OFFICE ➤	DOR:ORB-2	FOR:ORB-2	OELD <i>HL</i>	DOR:ORB-2		
SURNAME ➤	RMDiggs <i>RMP</i>	RSnaider:esp	SH Lewis	DLZiemann		
DATE ➤	6/11/76	6/10/76	6/17/76	6/18/76		

June 18, 1976

cc w/enclosures:

Gerald Charnoff, Esquire  
Shaw, Pittman, Potts and  
Trowbridge  
1800 M Street, N. W.  
Washington, D. C. 20036

Arthur Renquist, Esquire  
Vice President - Law  
Northern States Power Company  
414 Nicollet Mall  
Minneapolis, Minnesota 55401

Howard J. Vogel, Esquire  
Legal Counsel  
2750 Dean Parkway  
Minneapolis, Minnesota 55416

Mr. Steve J. Gadler  
2120 Carter Avenue  
St. Paul, Minnesota 55108

Daniel L. Ficker, Esquire  
Assistant City Attorney  
Criminal Division  
638 City Hall  
St. Paul, Minnesota 55102

Mr. Kenneth Dzuga  
Environmental Planning Consultant  
Office of City Planner  
Grace Building  
421 Wabasha Street  
St. Paul, Minnesota 55102

Sandra S. Gardebring, Esquire  
Special Assistant Attorney General  
Minnesota Pollution Control Agency  
1935 W. County Road B2  
Roseville, Minnesota 55113

Anthony Z. Roisman, Esquire  
Roisman, Kessler and Cashdan  
1712 N Street, N. W.  
Washington, D. C. 20036

The Environmental Conservation  
Library  
Minneapolis Public Library  
300 Nicollet Mall  
Minneapolis, Minnesota 55401

Mr. D. S. Douglas, Auditor  
Wright County Board of Commissioners  
Buffalo, Minnesota 55313

cc w/enclosures and cy of NSPCo  
filing dtd. 4/23/76:  
Warren H. Lawson, M. D.  
Secretary and Executive Officer  
State Department of Health  
University Campus  
Minneapolis, Minnesota 55440



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

NORTHERN STATES POWER COMPANY

DOCKET NO. 50-263

MONTICELLO NUCLEAR GENERATING PLANT


AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 20  
License No. DPR-22

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Northern States Power Company (the licensee) dated April 23, 1976, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. After weighing the environmental aspects involved, the issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment.
3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Dennis L. Ziemann, Chief  
Operating Reactors Branch #2  
Division of Operating Reactors

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: June 18, 1976

ATTACHMENT TO LICENSE AMENDMENT NO. 20

FACILITY OPERATING LICENSE NO. DPR-22

DOCKET NO. 50-263

Replace the following existing pages of the Technical Specifications with attached revised pages bearing the same numbers. Changes on these pages are denoted by marginal lines.

vii  
viii  
189B  
189C  
189D  
189E  
189F  
189G  
189H  
189L  
189M

LIST OF FIGURES

<u>Figure No.</u>		<u>Page No.</u>
2.1-1	Deleted	
2.3.1	APRM Flow Referenced Scram and Rod Block-Trip Settings	
2.3.2	Relationship Between Peak Heat Flux and Power for Peaking Factor of 3.08	12
4.1.1	'M' Factor - Graphical Aid in the Selection of an Adequate Interval Between Tests	46
4.2.1	System Unavailability	74
3.4.1	Sodium Pentaborate Solution Volume - Concentration Requirements	92
3.4.2	Sodium Pentaborate Solution Temperature Requirements	93
3.6.1	Change in Charpy V Transition Temperature versus Neutron Exposure	122
3.6.2	Minimum Temperature versus Pressure for Pressure Tests	122A
3.6.3	Minimum Temperature versus Pressure for Mechanical Heatup or Cooldown Following Nuclear Shutdown	122B
3.6.4	Minimum Temperature versus Pressure for Core Operation	122C
4.6.1	Deleted	
4.6.2	Chloride Stress Corrosion Test Results @ 500°F	123
4.8.1	Off-gas Storage Tank Gross Activity Limits	176A
3.11.1-A	Maximum Average Linear Heat Generation Rate versus Planar Average Exposure Monticello 8D219 Fuel	189H
3.11.1-B	Maximum Average Linear Heat Generation Rate versus Planar Average Exposure Monticello 7D230 Fuel	189I

LIST OF FIGURES

<u>Figure No.</u>		<u>Page No.</u>
3.11.1-C	Maximum Average Linear Heat Generation Rate versus Planar Average Exposure Monticello 8D262 Fuel	189J
3.11.1-D	Maximum Average Linear Heat Generation Rate versus Planar Average Exposure Monticello 8D250 Fuel	189K
3.11.2	LHGR Versus Core Height	189L
3.11.3	$K_f$ Factor versus Percent of Rated Core Flow	189M
6.1.1	NSP Corporate Organizational Relationship to On-Site Operating Organization	193
6.1.2	Functional Organization for On-Site Operating Group	194

### 3.0 LIMITING CONDITIONS FOR OPERATION

#### 3.11 REACTOR FUEL ASSEMBLIES

##### Applicability

The Limiting Conditions for Operation associated with the fuel rods apply to those parameters which monitor the fuel rod operating conditions.

##### Objective

The objective of the Limiting Conditions for Operation is to assure the performance of the fuel rods.

##### Specifications

##### A. Average Planar Linear Heat Generation Rate (APLHGR)

During power operation, the APLHGR for each type of fuel as a function of average planar exposure shall not exceed the limiting value shown in Figures 3.11.1. If at any time during operation it is determined that the limiting value for APLHGR is being exceeded, action shall be initiated within 15 minutes to restore operation to within the prescribed limits. Surveillance and corresponding action shall continue until reactor operation is within the prescribed limits. If the APLHGR is not returned to within the prescribed limits within two (2) hours, the reactor shall be brought to the Cold Shutdown condition within 36 hours.

### 4.0 SURVEILLANCE REQUIREMENTS

#### 4.11 REACTOR FUEL ASSEMBLIES

##### Applicability

The Surveillance Requirements apply to the parameters which monitor the fuel rod operating conditions.

##### Objective

The objective of the Surveillance Requirements is to specify the type and frequency of surveillance to be applied to the fuel rods.

##### Specifications

##### A. Average Planar Linear Heat Generation Rate (APLHGR)

The APLHGR for each type of fuel as a function of average planar exposure shall be determined daily during reactor operation at  $\geq 25\%$  rated thermal power.

### 3.0 LIMITING CONDITIONS FOR OPERATION

#### B. Linear Heat Generation Rate (LHGR)

During power operation, the LHGR as a function of core height shall not exceed the limiting value shown in Figure 3.11.2. If at any time during operation it is determined that the limiting value for LHGR is being exceeded, action shall be initiated within 15 minutes to restore operation to within the prescribed limits. Surveillance and corresponding action shall continue until reactor operation is within the prescribed limits. If the LHGR is not returned to within the prescribed limits within two (2) hours, the reactor shall be brought to the Cold Shutdown condition within 36 hours.

### 4.0 SURVEILLANCE REQUIREMENTS

#### B. Linear Heat Generation Rate (LHGR)

The LHGR as a function of core height shall be checked daily during reactor operation at  $\geq 25\%$  of rated thermal power.

### 3.0 LIMITING CONDITIONS FOR OPERATION

#### C. Minimum Critical Power Ratio (MCPR)

During power operation, the Operating MCPR Limit shall be  $\geq 1.38$  for 8x8 fuel and  $\geq 1.29$  for 7x7 fuel at rated power and flow. If at any time during operation it is determined that the limiting value for MCPR is being exceeded, action shall be initiated within 15 minutes to restore operation to within the prescribed limits. Surveillance and corresponding action shall continue until reactor operation is within the prescribed limits. If the steady state MCPR is not returned to within the prescribed limits within two (2) hours, the reactor shall be brought to the Cold Shutdown condition within 36 hours. For core flows other than rated the Operating MCPR Limit shall be the above applicable MCPR value times  $K_f$  where  $K_f$  is as shown in Figure 3.11.3.

### 4.0 SURVEILLANCE REQUIREMENTS

#### C. Minimum Critical Power Ratio (MCPR)

MCPR shall be determined daily during reactor power operation at  $\geq 25\%$  rated thermal power and following any change in power level or distribution which has the potential of bringing the core to its operating MCPR limit.

## Bases 3.11

### A. Average Planar Linear Heat Generation Rate (APLHGR)

This specification assures that the peak cladding temperature following the postulated design basis loss-of-coolant accident will not exceed the limit specified in the 10CFR50, Appendix K.

The peak cladding temperature following a postulated loss-of-coolant accident is primarily a function of the average heat generation rate of all the rods of a fuel assembly at any axial location and is only dependent secondarily on the rod to rod power distribution within an assembly. Since expected local variations in power distribution within a fuel assembly affect the calculated peak cladding temperature by less than  $\pm 20^{\circ}\text{F}$  relative to the peak temperature for a typical fuel design, the limit on the average linear heat generation rate is sufficient to assure that calculated temperatures are within the 10CFR50 Appendix K limit. The limiting value for APLHGR is given by this specification.

Those abnormal operational transients, analyzed in FSAR Section 14.5, which result in an automatic reactor scram are not considered a violation of the LCO. Exceeding APLHGR limits in such cases need not be reported.

### B. LHGR

This specification assures that the linear heat generation rate in any rod is less than the design linear heat generation if fuel pellet densification is postulated. The power spike penalty specified is based on the analysis presented in Section 3.2.1 of Reference 1 and in References 2 and 3, and assumes a linearly increasing variation and axial gaps between core bottom and top and assures with a 95% confidence, that no more than one fuel rod exceeds the design linear heat generation rate due to power spiking.

Those abnormal operational transients, analyzed in FSAR Section 14.5, which result in an automatic reactor scram are not considered a violation of the LCO. Exceeding LHGR limits in such cases need not be reported.

### Bases 3.11 (continued)

#### C. Minimum Critical Power Ratio (MCPR)

The ECCS evaluation presented in Reference 4 assumed the steady state MCPR prior to the postulated loss of coolant accident to be 1.18 for all fuel types. The Operating MCPR Limit of 1.38 for 8x8 fuel and 1.29 for 7x7 fuel is determined from the analysis of transients discussed in Bases Sections 2.1 and 2.3. By maintaining an operating MCPR above these limits, the Safety Limit of 1.06 (T.S.2.1.A) applicable to all fuel types is maintained in the event of the most limiting abnormal operational transient.

For operation with less than rated core flow the Operating MCPR Limit is adjusted by multiplying the above limit by  $K_f$ . Reference 5 discusses how the transient analysis done at rated conditions encompasses the reduced flow situation when the proper  $K_f$  factor is applied.

Those abnormal operational transients, analyzed in FSAR Section 14.5, which result in an automatic reactor scram are not considered a violation of the LCO. Exceeding MCPR limits in such cases need not be reported.

#### References

1. "Fuel Densification Effects in General Electric Boiling Water Reactor Fuel," Supplements 6, 7, and 8, NEDM-10735, August, 1973.
2. Supplement 1 to Technical Report on Densification of General Electric Reactor Fuels, December 14, 1974 (USAEC Regulatory Staff)
3. Communication: V A Moore to I S Mitchell, "Modified GE Model for Fuel Densification," Docket 50-321, March 27, 1974.
4. "Monticello Nuclear Generating Plant Loss-Of-Coolant Accident Analysis Conformance with 10 CFR 50 Appendix K, August 1974," L O Mayer (NSP) to J F O'Leary, August 20, 1974.
5. "General Electric BWR Generic Reload Application for 8 x 8 Fuel," NEDO-20360, Revision 1, November, 1974.


3.11 BASES

189F

Amendment No, <sup>20</sup> 22

Bases 4.11


The APLHGR, LHGR and MCPR shall be checked daily to determine if fuel burnup, or control rod movement have caused changes in power distribution. Since changes due to burnup are slow, and only a few control rods are removed daily, a daily check of power distribution is adequate. For a limiting value to occur below 25% of rated thermal power, an unreasonably large peaking factor would be required, which is not the case for operating control rod sequences. In addition, the MCPR is checked whenever changes in the core power level or distribution are made which have the potential of bringing the fuel rods to their thermal-hydraulic limits.



3.11/4.11

Amendment No. ~~27~~ 20


189H



LHGR Versus Core Height

Figure 3.11.2

Figure 3.11.3  
 $K_f$  Factor Versus Percent  
of Rated Core Flow





UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENT NO. 20 TO PROVISIONAL OPERATING LICENSE NO. DPR-22

NORTHERN STATES POWER COMPANY

MONTICELLO NUCLEAR GENERATING PLANT

DOCKET NO. 50-263

INTRODUCTION

By letter dated April 23, 1976, Northern States Power Company (NSP) requested an amendment to Provisional Operating License No. DPR-22 for the Monticello Nuclear Generating Plant. The amendment involves changes to the Technical Specifications which incorporate more specific Limiting Conditions for Operation (LCO's) for the Average Planar Linear Heat Generation Rate (APLHGR), Linear Heat Generation Rate (LHGR), and Minimum Critical Power Ratio (MCPR).

DISCUSSION AND EVALUATION

By letter dated February 25, 1976, the NRC requested NSP to include in the Monticello Technical Specifications for APLHGR, LHGR, and MCPR, explicit remedial actions to be taken in the event the specification is exceeded. The proposed specifications would require, upon exceeding a limit, the initiation of remedial action within 15 minutes to restore operation to within the prescribed limits. If operation is not within prescribed limits within two hours, the proposed specifications would require that the reactor be placed in Cold Shutdown within 36 hours. Current Monticello Technical Specifications for APLHGR, LHGR, and MCPR do not specify such time limits for remedial action. The APLHGR, LHGR, and MCPR limits themselves are not modified.

The NRC staff has reviewed NSP's proposed technical specification changes regarding remedial action for APLHGR, LHGR, and MCPR limits. We have concluded that the proposed specifications, as modified by the staff, are in accordance with the provisions of 10 CFR Part 50, §50.36 (c)(2), which permits a limited period of time to restore plant parameters within operating limits rather than requiring that the plant be immediately shut down. In addition, the requested amendment would improve the APLHGR, LHGR, and MCPR specifications by placing more specific requirements on the operator. On this basis the proposed technical specification is acceptable.

ENVIRONMENTAL CONSIDERATION

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and pursuant to 10 CFR §51.5(d)(4) that an environmental statement, negative declaration, or environmental appraisal need not be prepared in connection with the issuance of this amendment.

CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) because the changes do not involve a significant increase in the probability or consequences of accidents previously considered and do not involve a significant decrease in a safety margin, the changes do not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: June 18, 1976

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-263

NORTHERN STATES POWER COMPANY

NOTICE OF ISSUANCE OF AMENDMENT TO  
PROVISIONAL OPERATING LICENSE

Notice is hereby given that the U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 20 to Facility Operating License No. DPR-22, issued to the Northern States Power Company (the licensee), which revised Technical Specifications for operation of the Monticello Nuclear Generating Plant (the facility) located in Wright County, Minnesota. The amendment is effective as of its date of issuance.

The amendment revises the Monticello Technical Specifications to incorporate more specific Limiting Conditions for Operation for Average Planar Linear Heat Generation Rate, Linear Heat Generation Rate, and Maximum Critical Power Ratio limits.


The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental statement, negative declaration or environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated April 23, 1976, (2) Amendment No. 20 to License No. DPR-22, and (3) the Commission's concurrently issued Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. and at The Environmental Conservation Library, Minneapolis Public Library, 300 Nicollet Mall, Minneapolis, Minnesota 55401. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 18 day of June, 1976.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Dennis L. Ziemann, Chief  
Operating Reactors Branch #2  
Division of Operating Reactors