Facility: GRAND GULF NUCLEAR STATION Date of Exam: 1 JUNE 2001													
					K/A	CATE	GOR	Y					
TIER	GROUP	K1	K2	K3	K4	K5	18 K6	A1	A2	A3	A4	G	POINT TOTAL
1. Emergency &	1	3	1	3				1	5			0	13
Abnormal Plant	2	5	4	2				2	4	-		2	19
Evolutions	3	1	1	1				1	0			0	4
	TIER TOTAL	9	6	6				4	9			2	36
2.	1	4	3	2	4	1	3	3	3	1	3	1	28
Plant Systems	2	3	0	3	1	0	2	2	2	4	1	1	19
	3	0	0	0	0	1	0	0	0	1	1	1	4
	TIER TOTAL	7	3	5	5	2	5	5	5	6	5	3	51
3. Generic	Knowledge a	& Abi	lities		CA	T 1	CA	T 2	CA	T 3	CA	T 4	13
Note: 1. 2. 3. 4. 5. 6 *	Ensure that at least two topics from every K/A category are sampled within each tier (i.e., the "Tier Totals" in each K/A category shall not be less than two) Actual point totals must match those specified in the table. Select topics from many systems; avoid selecting more than two or three K/A topics from a given system unless they relate to plant specific priorities. Systems / evolutions within each group are identified on the associated outline. The shaded areas are not applicable to the category tier.												
7.	but the topic On the follo topics' impo and category Enter the tie	he generic K/As in Tiers 1 and 2 shall be selected from section 2 of the K/A Catalog, at the topics must be relevant to the applicable evolution or system. In the following pages, enter the K/A numbers, a brief description of each topic, the opics' importance ratings for the RO license level, and the point totals for each system and category. K/As below 2.5 should be justified on the basis of plant-specific priorities. Inter the tier totals for each category in the table above.											

BWR RO EXAMINATION OUTLINE

Scenario 1 Day 1 (Continued)

Event No.	10CFR 55.45(a)	K/A	Event Type*	Event Description
1	4	262001 A4.01; A4.05	N (BOP)	Perform AC/DC Weekly Surveillance Control Room portion. (06-OP-1R20-W-0001)
2	2, 4, 5, 6, 7, 8	202001 A4.04 202002 A4.08 2.2.2	R (RO)	Reduce Total Core Flow to 90 % Reactor Power (IOI 03-1-01-2)
3	3, 5	215005 A2.02 2.1.12; 2.1.33	I (RO)	Respond to APRM 'A' failure upscale. Complete Technical Specification determinations.
4	3, 4, 5, 6	2.4.49 295014 AA1.07; AA2.03	C(RO, BOP)	Respond to a tube failure in LP FW Heater 3B. Perform actions per ONEP 05-1-02-V-5. Lower Reactor power with Recirc flow.
5	3, 4, 5, 6	2.4.49 295002 AA1.02; AA1.05; AA2.01	C(RO, BOP)	Recognize and respond to a loss of Main Condenser vacuum. Take actions per ONEP 05-1-02-V-8.
	2, 3, 4, 7	2.4.4; 2.4.49 295006 AA1.01; AA1.05; AA1.07		When required initiate a manual Reactor Scram.
6	6, 8, 12, 13	295037 EA1.0; EA2.0 203000 A3.08 241000 A4.06	M (ALL)	Upon Reactor Scram recognize the failure of all control rods to fully insert and take actions per EOPs for ATWS.
	3, 4	218000 A4.02; A4.03; A4.04; A4.05	l (BOP)	Recognize the failure of ADS to Inhibit and take actions to prevent automatic initiation of ADS.
	3, 4, 8	295037 EA1.04; EA1.10 211000 A1.0; A2.04; A3.0	C (BOP)	Recognize the failure of Standby Liquid Control to meet the parameters to inject into the Reactor when initiated and actions taken for Alternate Boron Injection.

All evolutions test 55.45(a) 12 & 13.

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Scenario 1 Day 1 (Continued)

Critical Tasks

- Inject Standby Liquid Control prior to Suppression Pool Temperature reaching 110 °F.
- Identify the need for Alternate Standby Liquid Control injection.
- Terminate and prevent injection from Feedwater and ECCS when conditions require entry into Level/Power Control.
- Commence injection into the reactor using Feedwater or RHR 'A' or 'B' through Shutdown Cooling when reactor level reaches –192".
- Insert Control Rods in response to ATWS conditions.

Scenario Outline

Form ES-D-1

Examiners:	Operators:
Objectives:	To evaluate the candidates' ability to operate the facility in response to the following evolutions: 1. Complete the AC/DC Weekly Surveillance Control Room portion.
	 Lower Reactor Power using Recirculation Flow. Respond to a failure of APRM 'A' upscale.
	 Take actions in response to a Low Pressure Feedwater Heater 3B Tube leak. Complete actions of the Loss of Feedwater Heating ONEP.
	 Analyze the affects of a reduction of Main Condenser Vacuum on plant operations and take required actions. Take actions per the EOPs in response to an ATWS and mitigate the consequences of the ATWS with no Main Steam Bypass Valves
	 Respond to a failure of a division of ADS to Inhibit to prevent initiation of ADS. Take actions for a failure of Standby Liquid Control to inject to the Reactor during an ATWS.
Initial Cond	itions: Reactor Power is at 100 %.
INOPERABI APRM 'H ESF 12 T TBCW Pu Appropriate	<u>_E Equipment</u> ' is INOP due to a failed power supply card ransformer is tagged out of service for maintenance imp 'C' is tagged out of service for pump seal replacement clearances and LCOs are written.
Turnover: Tensas Pari	The AC/DC Lineup Weekly surveillance is due to be performed. There are scattered thunder showers reported in the sh area.

Scenario 1 Day 1 (Continued)

Event No.	10CFR 55.45(a)	K/A	Event Type*	Event Description
1	4	262001 A4.01; A4.05	N (BOP)	Perform AC/DC Weekly Surveillance Control Room portion. (06-OP-1R20-W-0001)
2	2, 4, 5, 6, 7, 8	202001 A4.04 202002 A4.08 2.2.2	R (RO)	Reduce Total Core Flow to 90 % Reactor Power (IOI 03-1-01-2)
3	3, 5	215005 A2.02 2.1.12; 2.1.33	I (RO)	Respond to APRM 'A' failure upscale. Complete Technical Specification determinations.
4	3, 4, 5, 6	2.4.49 295014 AA1.07; AA2.03	C(RO, BOP)	Respond to a tube failure in LP FW Heater 3B. Perform actions per ONEP 05-1-02-V-5. Lower Reactor power with Recirc flow.
5	3, 4, 5, 6	2.4.49 295002 AA1.02; AA1.05; AA2.01	C(RO, BOP)	Recognize and respond to a loss of Main Condenser vacuum. Take actions per ONEP 05-1-02-V-8.
	2, 3, 4, 7	2.4.4; 2.4.49 295006 AA1.01; AA1.05; AA1.07		When required initiate a manual Reactor Scram.
6	6, 8, 12, 13	295037 EA1.0; EA2.0 203000 A3.08 241000 A4.06	M (ALL)	Upon Reactor Scram recognize the failure of all control rods to fully insert and take actions per EOPs for ATWS.
	3, 4	218000 A4.02; A4.03; A4.04; A4.05	l (BOP)	Recognize the failure of ADS to Inhibit and take actions to prevent automatic initiation of ADS.
	3, 4, 8	295037 EA1.04; EA1.10 211000 A1.0; A2.04; A3.0	C (BOP)	Recognize the failure of Standby Liquid Control to meet the parameters to inject into the Reactor when initiated and actions taken for Alternate Boron Injection.

All evolutions test 55.45(a) 12 & 13.

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Scenario 1 Day 1 (Continued)

Critical Tasks

- Inject Standby Liquid Control prior to Suppression Pool Temperature reaching 110 °F.
- Identify the need for Alternate Standby Liquid Control injection.
- Terminate and prevent injection from Feedwater and ECCS when conditions require entry into Level/Power Control.
- Commence injection into the reactor using Feedwater or RHR 'A' or 'B' through Shutdown Cooling when reactor level reaches –192".
- Insert Control Rods in response to ATWS conditions.

Append	x D		Scenario Outline	Form ES-D-1		
Facility:	GRAND GL	JLF NUCL	EAR STATION Scenario No.: 1	Op-Test No.: Day 1		
Examin	ers:		Operators:			
<u>Objecti</u> followin	 Objectives: To evaluate the candidates' ability to operate the facility in response to the following evolutions: Lower Reactor Power using Recirculation Flow. Respond to a failure of APRM 'A' upscale. Take actions in response to a Low Pressure Feedwater Heater 3B Tube leak. Complete actions of the Loss of Feedwater Heating ONEP. Analyze the affects of a reduction of Main Condenser Vacuum on plant operations and take required actions. Take actions per the EOPs in response to an ATWS and mitigate the consequences of the ATWS with no Main Steam Bypass Valves. Respond to a failure of a division of ADS to Inhibit to prevent initiation of ADS. Take actions for a failure of Standby Liquid Control to inject to the Reactor during an ATWS. 					
Initial C	Initial Conditions: Reactor Power is at 100 %.					
INOPE APR ESF TBC Approp	RABLE Equi M 'H' is INOI 12 Transforr V Pump 'C' riate clearan	pment P due to a f ner is tagged is tagged o ces and LC	failed power supply card ed out of service for maintenance ut of service for pump seal replacem COs are written.	ient		
<u>Turnov</u> New Ga the Ten	<u>er:</u> The plan as Turbines a sas Parish a	nt is sched at Baxter W area.	uled to lower power by 130 MWe to f /ilson SES. There are scattered thu	facilitate testing of the nder showers reported in		
Event No.	Malf. No.	Event Type*	Event Descriptio	on		
1		N (RO)	Reduce Total Core Flow to 90 % R (IOI 03-1-01-2)	leactor Power		

REVISION 3 05/16/2001

SCENARIO 1 PAGE 1

Scenario Outline

Scenario 1 Day 1 (Continued)

Event No.	Malf. No.	Event Type*	Event Description
2	c51009a	I (RO)	Respond to APRM 'A' failure upscale. Complete Technical Specification determinations.
3	fw232h @ 50% ramp to 80%	R/C (RO, BOP)	Respond to a tube failure in LP FW Heater 3B. Perform actions per ONEP 05-1-02-V-5. Lower Reactor power with Recirc flow.
4	fw163b @ 10% ramp to 20%	C(RO, BOP)	Recognize and respond to a loss of Main Condenser vacuum. Take actions per ONEP 05-1-02-V-8.
			When required initiate a manual Reactor Scram.
5	c11164 @ 25%	M (ALL)	Upon Reactor Scram recognize the failure of all control rods to fully insert and take actions per EOPs for ATWS.
	di_1b21m6 60a NORM	I (BOP)	Recognize the failure of ADS to Inhibit and take actions to prevent automatic initiation of ADS.
	c41263 @ 60%	C (BOP)	Recognize the failure of Standby Liquid Control to meet the parameters to inject into the Reactor when initiated and actions taken for Alternate Boron Injection.

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Critical Tasks

- Inject Standby Liquid Control prior to Suppression Pool Temperature reaching 110 °F.
- Identify the need for Alternate Standby Liquid Control injection.
- Terminate and prevent injection from Feedwater and ECCS when conditions require entry into Level/Power Control.
- Commence injection into the reactor using Feedwater or RHR 'A' or 'B' through Shutdown Cooling when reactor level reaches –192".
- Insert Control Rods in response to ATWS conditions.

Scenario 1 Day 1 (Continued)

Crew Turnover:

Rx at 100% CTP. APRM 'H' is failed due to a failed power supply card and bypassed. ESF 12 Transformer is tagged out of service for maintenance. TBCW Pump 'C' is tagged out of service for pump seal replacement. Appropriate clearances and LCOs are written.

The plant is scheduled to lower power by 130 MWe to facilitate testing of the New Gas Turbines at Baxter Wilson SES.

Plant EOOS factor is 10 GREEN.

There are scattered thunderstorms reported in the Tensas Parish area.

Simulator Setup: (Scenarios may be setup and shot into encrypted ICs and Password protected.)

Start the process from a new simulator load. Reset to IC-17.

Verify or perform the following:

IC:	17	
OOS:	ESF Transformer 12 (Place 1 1511, 1611, a TBCW C Pump (Place tag o	tags on 152-1903. 1904, 1905, nd 1704) n start HS)
Active malfunctions:	c51010h APRM H downsca c11164 @ 25% SDV Block c41263 @ 80% SLC injectio	le on pipe rupture
Active overrides	di_1b21m660a ADS Divisio	on I Inhibit Switch H13-P601 NORM
Pending overrides	None	
Pending malfunctions:	c51009a APRM 'A' upscale fw232h @ 50% LP FW Htr 1 min after first alarm reco fw163b @ 10% Main Cond over 4 min after reactor scr	(TRG 1) 3B tube failure (TRG 2) ramp to 80% over eived. enser Vacuum leak (TRG 3) ramp to 20% ram.
REVISION 3 05/16/2001	SCENARIO 1 PAGE 3	NUREG 1021 REVISION 8 SUPPLEMENT 1

Pending component malfunctions: None

Trigger files:	Trigger 1	APRM 'A' upscale
	Trigger 2	LP FW Heater Tube Rupture
	Trigger 3	Condenser Vacuum leak

COMPONENT	PANEL	INDICATION or CONTROL	SIMULATOR CODE	STATUS	DONE
APRM H		DOWNSCALE	c51010h		
TBCW PUMP C	P870-5C	GREEN LIGHT	lo_1p43m600c_g	OFF	
		HANDSWITCH	di_1p43m600c	STOP	
ESF 12 BREAKER 152-1903	P807-1C	GREEN LIGHT	lo_1r21m623_g	OFF	
		HANDSWITCH	di_1r21m623	TRIP	
ESF 12 BREAKER 152-1904	P807-1C	GREEN LIGHT	lo_1r21m624_g	OFF	
		HANDSWITCH	di_1r21m624	TRIP	
ESF 12 BREAKER 152-1905	P807-1C	GREEN LIGHT	lo_1r21m637_g	OFF	
		HANDSWITCH	di_1r21m637	TRIP	
ESF 12 FEEDER 152-1511	P864-1C	GREEN LIGHT	lo_1r21m601a_g	OFF	
		HANDSWITCH	di_1r21m601a	TRIP	
ESF 12 FEEDER 152-1611	P864-2C	GREEN LIGHT	lo_1r21m601b_g	OFF	
		HANDSWITCH	di_1r21m601b	TRIP	
ESF 12 FEEDER 152-1704	P601-16C	GREEN LIGHT	lo_1e22m709_g	OFF	
		HANDSWITCH	di_1e22m709	TRIP	
115 KV DISCONNECT J3885	P807-1C	GREEN LIGHT	lo_1r27r602_g	OFF	
J3885		DISCONNECT		OPEN	

Bypass Division 2 APRM Bypass Joystick to APRM H position.

Open Circuit Breakers 152-1903, 1904, 1905, 1511, 1611, and 1704

Place TBCW pump B to STOP (to clear Standby light) then to START, stop TBCW pump C.

Startup all PDS / SPDS screens. Clear any graphs and trends off of SPDS.

Setup the presently used cyclops display and verify it is functional.

Ensure the correct startup sequence is available at the P680 for the present IC.

Install turnover guide, red tag, and LCO paperwork as applicable.

Advance all chart recorders and ensure all pens are inking properly. (APRM chart recorders must be turned on and settings for scales on pens 0 - 125 scale)

REVISION 3 05/16/2001

SCENARIO 1 PAGE 4 NUREG 1021 REVISION 8 SUPPLEMENT 1

SIMULATOR OPERATION SCENARIO 1

Once simulator is reinitialized and setup complete take the simulator out of Freeze.

Once the Crew has taken control note the simulator time.

The Crew will lower reactor power using Reactor Recirc Flow Control. Cues:

If asked, acknowledge reports to Dispatcher, Chemistry, Radwaste, Radiation Protection, and STA of impending down power to 90%.

If asked, report as Reactor Engineer or STA, ramp rate for down power is at the discretion of the SRO. Should be around 390 MWth.

Once power is reduced by 130 MWe, <u>activate TRIGGER 1</u>. Cues:

If asked, report that APRM 'A' appears to be failed somehow upscale. Upscale and Upscale Trip lights are illuminated.

If asked, when crew bypasses the APRM, report APRM 'A' indicates BYPASSED on h13-P669.

If asked, as I&C report the failure on APRM 'A' will require more in depth troubleshooting and that a MAI will be generated.

The Crew will bypass APRM 'A' using the Division 1Neutron Monitoring Bypass joystick and reset RPS 'A' using the Division 1 and 3 RPS RESET Key switches.

The SRO will review Tech Specs 3.3.1.1 and 3.3.2.1. (A tracking LCO may be initiated on 3.3.1.3 PBDS.) Tracking LCOs will be written.

Six (6) minutes after APRM upscale, activate TRIGGER 2.

The Crew will lower power per Loss of Feedwater Heating ONEP to 60% core flow. Cues:

If asked, report at Turbine Building Operator the controllers on H22-P172 for LP FW Heater 3B are calling for dumps and drains to be full open and valves are responding. <u>Simulator Operator ramp fw232h from 50% to 80% over one (1) minute following first FW</u> <u>Heater alarm.</u>

If asked, report other Main Steam Line Radiation Monitors are reading approximately 1930 mR/hr.

REVISION 3 05/16/2001

SCENARIO 1 PAGE 5 NUREG 1021 REVISION 8 SUPPLEMENT 1

When plant is stabilized and four (4) minutes after isolation of LP FW Heater String 'B', <u>activate</u> TRIGGER 3.

Main Condenser Vacuum leak Cues:

If asked, report as Turbine Building Operator that you hear a high pitched whistling sound in the Condenser Bay.

The Crew will manually scram the reactor at which time the ATWS will appear.

<u>Simulator Operator after Reactor Scram modify fw163b to ramp from 10% to 20% over four (4)</u> <u>minutes.</u>

The Main Turbine will trip. RFPTs will require a vacuum reset. Main Steam Bypass Valves will close.

EP Attachments which may be requested:

Attachment 18 Defeat ATWS ARI3 minutes to DOAttachment 19 Defeat RPS4 minutes to DO) NE
Attachment 19 Defeat RPS 4 minutes to DC	ONE
	ONE
Attachment 20 Defeat RCIS 5 minutes to DC	ONE
Attachment 8 Defeat MSIV isolations 9 minutes to DC	ONE
Attachment 1 Defeat RCIC High SP Transfer 8 minutes to DC	ONE
Attachment 2 Defeat RCIC Trips 8 minutes to DC)NE

Attachment 28 (Alternate Boron) can not be done by any remote functions, just acknowledge the request.

SCENARIO 1 PAGE 6

TERMINATION

Once Control Rods are being inserted and the Lead Evaluator concurs the scenario may be terminated.

Critical Tasks

- Inject Standby Liquid Control prior to Suppression Pool Temperature reaching 110 °F.
- Identify the need for Alternate Standby Liquid Control injection.
- Terminate and prevent injection from Feedwater and ECCS when conditions require entry into Level/Power Control.
- Commence injection into the reactor using Feedwater or RHR 'A' or 'B' through Shutdown Cooling when reactor level reaches –192".
- Insert Control Rods in response to ATWS conditions.

REVISION 3 05/16/2001

SCENARIO 1 PAGE 7 NUREG 1021 REVISION 8 SUPPLEMENT 1

Г

Operator Actions

٦

Op-Test	Op-Test No.: Scenario No.:1 Event No.:1						
Event D	Event Description: Reduce Reactor power using Recirculation Flow Control						
Time	Position	Applicant's Actions or Behavior					
	SS	Conduct reactivity manipulation brief.					
	RO	Reduces Total Core Flow by throttling closed on the Recirc Flow Control Valves.					
	BOP	Monitors Pressure, Level, Power, and Turbine Loading.					

Operator Actions

Op-Test Event D	Op-Test No.: Scenario No.:1 Event No.:2 Event Description: Respond to a failure of APRM 'A' Upscale.					
Time	Position	Applicant's Actions or Behavior				
	RO	Determines APRM 'A' is Upscale and reviews Alarm Response Instructions.				
	SS	Reviews applicable Technical Specifications 3.3.1 Reactor Protection System 3.3.2 Control Rod Block Instrumentation				
	вор	Observe and report indications on APRM 'A'.				
	SS	Contact I&C to investigate APRM failure.				
	RO	Shift Neutron Monitoring APRM Division 1 to A bypassed.				
	RO	Reset ½ scram.				

Operator Actions

Form ES-D-2

Op-Test No.: Scenario No.:1 Event No.:3_ Event Description: Respond to a tube failure on LP FW Heater 3B. Perform actions per ONEP 05-1-02-V-5.				
Time	me Position Applicant's Actions or Behavior			
	RO	Recognizes annunciator concerning High level in 3B LP FW heater. Calls up display on PDS computer of N23 to determine heater level and operation of drains and dumps.		
	SS	Dispatch an operator to H22-P172 panel to investigate Heater Drains Controllers.		
	RO	Lowers Reactor Power using Reactor Recirc Flow control to 60 % Core flow or lower power by 20% per ONEP 05-1-02-V-5 Loss of Feedwater Heating. Monitor operation on the Power to Flow Map.		
	BOP	Verify isolation of LP FW heater string N19-F042B and N19-F040B on H13-P870 section 6C.		
	BOP	Verify Main Steam Line Rad Monitor High due to Hydrogen Water Chemistry operation.		
	RO or BOP	Monitors Reactor for Thermal Hydraulic Instability per ONEP 05-1- 02-III-3, Reduction in Recirc Flow.		
	RO or BOP	Monitors Feedwater temperature vs Reactor Power per ONEP 05-1- 02-V-5 Loss of Feedwater Heating.		

Appendix D Form ES-D-2 **Operator Actions** Op-Test No.: _____ Scenario No.: __1_ Event No.: __4___ Event Description: Loss of Main Condenser Vacuum (ONEP 05-1-02-V-8) and subsequent Manual Scram Time Position Applicant's Actions or Behavior BOP Investigates Offgas trouble and reports rising Offgas flow. SS Directs lowering of power by control rod insertion using insertion sequence. SS Dispatches local operators to monitor condenser area for leaks. SS Determines minimum vacuum for insertion of manual scram and communicates this to crew. Verifies control rods and positions per Pull Sheet and selects RO control rods per next gang of control rods. (May select Individual or Gang movement and may select any Control Rod in the Gang.) BOP Act as Verifier for Control Rod movements and monitors Main Condenser Vacuum. RO Inserts Control Rods per Control Rod Movement Sequence Sheet to reduce turbine load. SS Based on lowering Main Condenser Vacuum, orders manual scram of the Reactor Places the Reactor Mode Switch to Shutdown or arms and RO depresses at least one Manual Scram Pushbutton per RPS RO Verifies All Control Rods have fully inserted to position 00 and determines ALL Control Rods NOT fully inserted and reports to the SS. RO If the Manual Scram Pushbuttons utilized confirms stable reactor pressure and places the Reactor Mode Switch in Shutdown.

Op-Test No.: _____ Scenario No.: __1_ Event No.: __5___

Event Description: ATWS with no Main Steam Bypass Valves

Time	Position	Applicant's Actions or Behavior	
	SS	Enters EP-2A.	
	RO	Reports downshift of Recirc Pumps to Slow Speed.	
	RO	On orders initiates ARI/RPT.	
	BOP	On orders inhibits ADS, reports failure of Division 1 to inhibit, depresses manual reset pushbutton for Division 1 periodically.	
	вор	On orders initiates and overrides HPCS.	
	RO	Realigns Condensate and Feedwater on Startup Level Control and maintains reactor level within level band specified by the SS. RFPTs will require the Vacuum Trip to be overridden with permission of the SS.	
	RO	Reports closure of Main Steam Bypasses due to Condenser vacuum.	
	вор	On orders maintains RPV pressure in band specified by SS.	
	BOP	When ordered by SS, restores Auxiliary Building, Containment, and Drywell isolation (Instrument Air, Plant Service Water, and Drywell Chilled Water.	
	SS **	Orders Standby Liquid Control initiated prior to Suppression Pool Temperature reaching 110 0F.	
	BOP **	When ordered, initiates Standby Liquid Control and identifies the failure of SLC to inject.	
	SS **	Orders implementation of Attachment 28 Alternate Boron Injection.	

SS **	Orders installation of Attachments 18, 19, and 20 of EP-2.
SS **	Based on conditions orders Terminate and Prevent step to lower RPV level to reduce reactor power.
BOP/RO **	Terminates and prevents systems ordered by SS.
RO **	On orders of SS, initiates flow to the RPV from Condensate / Feedwater.
BOP/RO **	Insert Control Rods by scramming rods and inserting rods using CRD/RCIS. CRD Drive Pressure, Instrument Air to Containment and Auxiliary Building, and RPS reset.
SS	If level drops below –192 inches Fuel Zone, may elect to Emergency Depressurize. (Optional)
SS	Orders Terminate and Prevent step for Emergency Depressurization. (Optional)
BOP/RO	Terminates and prevents systems ordered by SS. (Optional)
BOP/RO	If ordered opens 8 ADS SRVs. (Optional)
SS	Upon Reactor pressure drop < 177 psig with 8 SRVs open, orders slow injection with Condensate and Feedwater. (Optional)
BOP/RO	Injects with Condensate at prescribed rates by SS. (Optional)

<u>Optionals</u> for Emergency Depressurization leg of EP-2A are only if SS elects to use this based on RPV Water Level < -192 inches.

Appendix D	Scenario Outline	Form ES-D-1
		1
Facility: GR/	ND GULF NUCLEAR STATION Scenario No.: 2 Op-Test No.: Day 2	
Examiners:	Operators:	
Objectives:	To evaluate the candidates' ability to operate the facility in response to the following evolutions: 1. Start SSW 'B' in support of chemical addition.	
	 Lower Reactor Power by inserting control rods. Respond to single immovable control rod per ONEP 05-1-02 Downshift Reactor Recirculation Pumps per IOI 03-1-01-2 & SOI 04-1-01-B33-1. Respond to trip to OFF of 'A' per ONEP 05-1-02-III-3. Respond to Service Transformer 11 trouble and subsequent trip. 	2-IV-1. Recirculation Pump
	 Take actions to mitigate a small break failure of Feedwater piping in the Drywell per EOPs. 	
	6. Take actions to manually initiate Division 2 ECCS upon failure to automatically initiate.	
Initial Cond single React INOPERABI APRM 'H' ESF 12 T TBCW Pu Appropriate	itions: Reactor Power is at 45 %. Plant shutdown is in progress for an outage. Reactor Recirculation pumps in I or Feed Pump in single element Master Level Control; <u>E Equipment</u> is INOP due to a failed power supply card ransformer is tagged out of service for maintenance mp 'C' is tagged out of service for pump seal replacement clearances and LCOs are written.	Fast Speed; a
Turnover: thunder sho	Chemistry requires SSW 'B' in operation to support a chemical addition. Continue plant shutdown per IOI-2. The wers reported in the Tensas Parish area.	ere are scattered

Scenario 2 Day 2 (Continued)

Event No.	10CFR 55.45(a)	K/A	Event Type*	Event Description	
1	4, 5, 6	2.1.30	N (BOP)	Place Standby Service Water 'B' in service for chemical addition. (EPI 04-1-03-P41-1)	
2	1, 2, 5, 6, 8	201005 A3.01; A3.02; A3.03; A4.01 2.2.2	R (RO)	Lower Reactor power using control rods to between 40 and 45%. (Control Rod Pull Sheet)	
3	1, 2, 3, 5, 6, 8	201001 A4.04 2.4.4; 2.4.11; 2.4.48	C (RO, BOP)	Identify immovable control rod, take actions to move the control rod. (ONEP 05-1-02- IV-1)	
4	2, 3, 4, 5, 6, 8	202001 A1.07; A3.02; A4.01 202002 A1.01; A4.01	N (RO)	Downshift Reactor Recirculation Pumps. (IOI 03-1-01-2 & SOI 04-1-01-B33-1)	
	3, 4, 5, 6	202001 A2.03	C (RO)	Respond to trip to OFF of Recirculation Pump 'A'. (ONEP 05-1-01-III-3)	
5	3, 5, 6, 8	295003 AA1.01; AA2.01 262001 A2.03; A2.07; A4.01	C (ALL)	Respond to Service Transformer 11 Trouble and subsequent trip of ST-11. (ONEP 05-1-02-I-4 & 05-1-02-I-1)	
6	3, 4, 5, 6, 7, 13	295031 EA1.0 203000 A3.08 241000 A4.06	M (ALL)	Respond to indications of small break LOCA on Feedwater Line 'B' per EOPs.	
	3, 4, 7, 10	2.4.4 295024 EA1.0	I (BOP)	Respond to a failure of Division 2 ECCS to automatically initiate on High Drywell Pressure.	
	3	295031 EA1.04 209002 A2.02	C (BOP)	Respond to a trip of the High Pressure Core Spray Pump.	

All evolutions test 55.45(a) 12 & 13.

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Critical Tasks

Recognize failure of Division 1 to initiate and manually initiate Division 1. Lower reactor pressure to allow injection from Low Pressure systems. _

-

REVISION 1 03/29/2001

Scenario Outline

Facility: GRAND GULF NUCLEAR STATION Scenario No.: 2 Op-Test No.: Day 2								
Examin	ners:Operators:							
Objecti follo Initial C Reactor Master INOPEF APRI ESF	 Objectives: To evaluate the candidates' ability to operate the facility in response to the evolutions: Start SSW 'B' in support of chemical addition. Lower Reactor Power by inserting control rods. Respond to single immovable control rod per ONEP 05-1-02-IV-1. Downshift Reactor Recirculation Pumps per IOI 03-1-01-2 & SOI 04-1-01-B33-1. Respond to trip to OFF of Recirculation Pump 'A' per ONEP 05-1-02-III-3. Respond to Service Transformer 11 trouble and subsequent trip. Take actions to mitigate a small break failure of Feedwater piping in the Drywell per EOPs. Take actions to manually initiate Division 2 ECCS upon failure to automatically initiate. Initial Conditions: Reactor Power is at 45 %. Plant shutdown is in progress for an outage. Reactor Recirculation pumps in Fast Speed; a single Reactor Feed Pump in single element Master Level Control; INOPERABLE Equipment APRM 'H' is INOP due to a failed power supply card							
Approp	riate clearan	is tagged o ces and LC	ut of service for pump seal replacement					
Turnover: Chemistry requires SSW 'B' in operation to support a chemical addition. Continue plant shutdown per IOI-2. There are scattered thunder showers reported in the Tensas Parish area.								
Event No.	Malf. No.	Event Type*	Event Description					
1		N (BOP)	Place Standby Service Water 'B' in service for chemical addition. (EPI 04-1-03-P41-1)					
2		R (RO)	Lower Reactor power using control rods to between 40 and 45%. (Control Rod Pull Sheet)					
3	z022022_ 32_33	C (RO, BOP)	Identify immovable control rod, take actions to move the control rod. (ONEP 05-1-02-IV-1)					

Scenario Outline

Scenario 2 Day 2 (Continued)

Event No.	Malf. No.	Event Type*	Event Description	
4		N (RO)	Downshift Reactor Recirculation Pumps. (IOI 03-1-01-2 & SOI 04-1-01-B33-1)	
	rr016a	C (RO)	Respond to trip to OFF of Recirculation Pump 'A'. (ONEP 05-1-01-III-3)	
5	xal2p807_2a _f_5 ON r21133a	C (ALL)	Respond to Service Transformer 11 Trouble and subsequent trip of ST-11. (ONEP 05-1-02-I-4 & 05-1-02-I-1)	
6	fw0171b @ 70% rr063b @ 5% b21f065b_i	M (ALL)	Respond to indications of small break LOCA on Feedwater Line 'B' per EOPs.	
	rr040f @ 0 rr041f @ 83%	l (BOP)	Respond to a failure of Division 2 ECCS to automatically initiate on High Drywell Pressure.	
	e22052	C (BOP)	Respond to a trip of the High Pressure Core Spray Pump.	
(N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor				

Critical Tasks

- Recognize failure of Division 2 to initiate and manually initiate Division 2.
- Lower reactor pressure to allow injection from Low Pressure systems.

Scenario 2 Day 2 (Continued)

Crew Turnover:

Rx at 45% CTP.

The plant is lowering power in preparation for an outage. Reactor Recirculation Pumps are operating in Fast Speed. The 'A' Reactor Feed Pump is operating in Single Element Master Level Control. Heater Drain Pumps are secured. Circ Water is in Single Pump Dual Train 'A' Pump in service. APRM 'H' is failed due to a failed power supply card and bypassed.

ESF 12 Transformer is tagged out of service for maintenance. TBCW Pump 'C' is tagged out of service for pump seal replacement. Appropriate clearances and LCOs are written.

Standby Service Water 'B' requires a Chemical Addition run. Section 7.4 of EPI 04-1-03-P41-2 is not required to be performed. Continue to shutdown the plant. At step 8.5 of IOI-2 Attachment IV. Startup Pull Sheet Step 005 (IC 15 S/D) 32-33 @ 48. Plant EOOS is 10 GREEN. There are scattered thunderstorms reported in the Tensas Parish area.

Simulator Setup: (Scenarios may be setup and shot into encrypted ICs and Password protected.)

Start the process from a new simulator load. Reset to IC-13.

Verify or perform the following:

13
APRM H ESE Transformer 12 (Place tags on 152, 1003, 1004, 1005
1511, 1611, and 1704)
TBCW C Pump (Place tag on start HS)
z022022_32_33 Control Rod 32-33 stuck
rr040f @ 0 Failure of Division 2 Drywell Pressure
B21-N094F
e22052 HPCS Pump trip on start
rr016a Recirc pump A incorrect slow speed start (TRG1)
tied to opening of CB-5A. (iodib33m607a(1))
b21f065b_i Failure of B21-F065B to close

Pending overrides	xal2p807_2a_f_5 ON Service Transformer 11 Trouble Alarm (TRG 2)		
Pending malfunctions:	 r21133a Service Transformer 11 trip (TRG 3) fw0171b @ 70% Feedwater B Line Rupture in Drywell (TRG 4) rr063b @ 5% Feedwater check valve leakage (Recirc Line Rupture) (TRG 4) rr041f @ 83% Reactor Level Transmitter B21-N091F (TRG 4) 		
Pending component malfunctions:	None		
Trigger files:	Trigger 1 Recirc Pump 'A' trip on downshift Trigger 2 Service Transformer 11 Trouble alarm		

Trigger 3 Service Transformer 11 Trip Trigger 4 Feedwater rupture in Drywell

COMPONENT PANEL		INDICATION or	SIMULATOR	STATUS	DONE
		CONTROL	CODE		
APRM H		DOWNSCALE	c51010h		
TBCW PUMP C	P870-5C	GREEN LIGHT	lo_1p43m600c_g	OFF	
		HANDSWITCH	di_1p43m600c	STOP	
ESF 12 BREAKER 152-1903	P807-1C	GREEN LIGHT	lo_1r21m623_g	OFF	
		HANDSWITCH	di_1r21m623	TRIP	
ESF 12 BREAKER 152-1904	P807-1C	GREEN LIGHT	lo_1r21m624_g	OFF	
		HANDSWITCH	di_1r21m624	TRIP	
ESF 12 BREAKER 152-1905	P807-1C	GREEN LIGHT	lo_1r21m637_g	OFF	
		HANDSWITCH	di_1r21m637	TRIP	
ESF 12 FEEDER 152-1511	P864-1C	GREEN LIGHT	lo_1r21m601a_g	OFF	
		HANDSWITCH	di_1r21m601a	TRIP	
ESF 12 FEEDER 152-1611	P864-2C	GREEN LIGHT	lo_1r21m601b_g	OFF	
		HANDSWITCH	di_1r21m601b	TRIP	
ESF 12 FEEDER 152-1704	P601-16C	GREEN LIGHT	lo_1e22m709_g	OFF	
		HANDSWITCH	di_1e22m709	TRIP	
115 KV DISCONNECT J3885	P807-1C	GREEN LIGHT	lo_1r27r602_g	OFF	
J3885		DISCONNECT		OPEN	

Bypass Division 2 APRM Bypass Joystick to APRM H position.

Open Circuit Breakers 152-1903, 1904, 1905, 1511, 1611, and 1704

Place TBCW pump B to STOP (to clear Standby light) then to START, stop TBCW pump C.

Startup all PDS / SPDS screens. Clear any graphs and trends off of SPDS.

Setup the presently used cyclops display and verify it is functional.

Ensure the correct startup sequence is available at the P680 for the present IC.

Install turnover guide, red tag, and LCO paperwork as applicable.

Advance all chart recorders and ensure all pens are inking properly. (APRM chart recorders must be turned on and settings for scales on pens 0 - 125 scale)

SIMULATOR OPERATION SCENARIO 2

Once simulator is reinitialized and setup complete take the simulator out of Freeze.

Once the Crew has taken control note the simulator time.

Crew will start SSW 'B' per EPI 04-1-03-P41-2.

Crew will review procedures for shutting down the plant and down shifting Recirc Pumps. Cues:

If asked, report as Reactor Engineer – you would prefer to insert control rods further before down shifting Recirc Pumps to Slow Speed.

If asked, report as Reactor Engineer – insert control rods per the Control Rod Pull Sheet beginning at step 005. Insertion of rods may be in gang or individual mode.

Crew will insert control rods to lower power and note Control Rod 32-33 will not move.

If asked, report as Local Operator, CRD Drive Filter DP and Suction Filter DP are normal.

If asked, report as Local Operator, CRD Flow Control Valves are operating normally and the HCU for 32-33 appears normal.

Respond to stuck control rod per ONEP 05-1-02-IV-1, CRD Malfunctions.

REMOVE Malfunction z022022 for control rod 32-33.

Once power is lowered to less than 45%, **Cue the crew at the Reactor Engineer that power to flow is sufficient to support downshifting Recirc Pumps to slow speed.**

During downshift Recirc Pump A will trip to OFF. Trigger 1 will activate when CB-5A opens on downshift.

Cues:

If asked, as Turbine Building Operator inform the Control Room that there are no apparent reasons for the failure of Recirc Pump 'A' to shift to slow speed.

If asked, respond as Electrical or I&C as required and request a MAI be generated to troubleshoot Recirc Pump 'A'.

Seven (7) minutes after the Recirc Pump trip, activate TRIGGER 2.

Service Transformer 11 Trouble. Cues:

If asked, as Outside Operator respond to Switchyard and report "Service Xfmr ST11 General Alarm" 2R-D1 is in alarm in the Switchgear house.

Dispatcher contacts the control room to request personnel be dispatched to determine the alarm.

If asked, at the Transformer "Oil Level Low" 1A-A1 is in alarm. The sight glass on the transformer has NO oil present.

If asked, respond as the Jackson Dispatcher that the UC & M crew has been dispatched and that the transformer should be unloaded.

Five (5) minutes after ST 11 Trouble alarm, activate TRIGGER 3.

Service Transformer 11 trip.

Cues:

If asked, respond as the Turbine Building operator to reset bus undervoltages, as necessary.

Four (4) minutes after Scram, activate TRIGGER 4.

The reactor will scram on Drywell pressure will rise from the Feedwater Line Break, this action will most likely occur before operators have a chance to manually scram the reactor.

Division 2 will not automatically initiate on the LOCA.

HPCS Pump will trip on initiation.

Crew will implement actions of EP-2 and EP-3.

After the LOCA is detected, perform the following attachments when requested.

Attachment 12 Defeat SDC interlocks 4 minutes to DONE

Attachment 12 for RHR 'A' can be of use. RHR 'B' through shutdown cooling injection is of no use.

Cues:

If asked, as the Auxiliary Building Operator report 52-153118 is trip free and will not reset.

RCIC, Feedwater, and Condensate are not available due to the location of the break.

Attachment s 25 (Condensate Transfer) and 26 (Fire Water) can not be installed by any remote functions just acknowledge the request.

REVISION 1 03/29/2001

TERMINATION

Once Reactor level is being restored with Low Pressure ECCS and the Lead Evaluator concurs the scenario may be terminated.

Critical Tasks

- Recognize failure of Division 2 to initiate and manually initiate Division 2.
- Lower reactor pressure to allow injection from Low Pressure systems.

Appendix D	Operator Actions	Form ES-D-2

Op-Test	Op-Test No.: Scenario No.: 2 Event No.: 1					
Event D	Event Description: Place Standby Service Water 'B' in service for chemical addition. (EPI 04-1-03-P41-2 & SOI 04-1-01-P41-1)					
Time	Position Applicant's Actions or Behavior					
	BOP	Starts SSW 'B' per EPI and SOI and aligns through components.				

Op-Test No.: Scenario No.:2 Event No.:2_ Event Description: Lower Reactor power using Control Rods from 45 % to 44 % (Control Rod Pull Sheet)			
Time	Position	Applicant's Actions or Behavior	
	SS	Conduct reactivity manipulation brief.	
	RO	Inserts control rods in individual or gang per control rod pull sheet to lower power to 44 %.	
	BOP	Assists RO in Control Rod selection verification, monitors Pressure, Level, Power, and Turbine Loading.	

Г

Operator Actions

Op-Test No.: Scenario No.:2_ Event No.:3			
Event D	escription: Ins	ert control rods to lower power. (Control Rod Pull Sheet)	
Control	Rod 32-33 is s	tuck, un-stick control rod per ONEP. (ONEP 05-1-02-IV-1)	
Time	Position	Applicant's Actions or Behavior	
	RO	Moves Control Rods from Position 42 to position 00. Once Control Rod 32-33 is attempted to be moved will recognize control rod is immovable.	
	SS	Dispatches operators to verify HCV, FCV, Drive Filter DP and Suction Filter DP.	
	SS	Obtains CRD Malfunctions ONEP 05-1-02-IV-1 and verifies action per section 3.5, orders CRD Drive pressure raised ~25 psid.	
	BOP	Raises CRD Drive pressure ~ 25 psid using C11-F003 Pressure Control Valve on H13-P601.	
	RO	Attempts to move the Control Rod and reports no movement.	
	BOP	Raises CRD Drive pressure ~25 psid using C11-F003 Pressure Control Valve on H13-P601.	
	RO	Attempts to move the Control Rod and reports movement and positions Control Rod 32-33 at position 00.	

Appendix D		Operator Actions	Form ES-D-2		
Op-Test Event D	No.: Sc escription: Dow (IC Reci	enario No.:2 Event No.:4 n shift Recirculation Pumps to slow speed. N 03-1-01-1 and SOI 04-1-01-B33-1) rculation Pump A trip to OFF on downshift (ON	EP 05-1-02-III-3)		
Time	Position	Applicant's Actions or Behavio	r		
	RO	Transfers Recirc Pumps to slow speed			
	RO	Respond to annunciators concerning Recirc Pump 'A' trip, and performs immediate actions of "Reduction in Recirculation System Flow Rate" ONEP 05-1-02-III-3.			
		Closes B33-F067A Monitors for Thermal Hydraulic Instability Monitors position on Power to Flow Map and region of operation			
	RO	Verifies Recirc Loop 'B' flow is < 44,600 gpm. Monitors Thermal Hydraulic Instability and reaction of Reactor Power.			
	вор				
	SS	Verifies actions per ONEP are completed, dispatches personnel to investigate the trip.			

Appendix D		Operator Actions	Form ES-D-2		
Op-Test Event D	t No.: Sc escription: Resp subs	enario No.: 2 Event No.: 5 oond to Service Transformer 11 Trouble alarm and equent trip of ST-11.			
Time	Position	Applicant's Actions or Behavior			
	BOP	Responds to Service Transformer 11 Trouble alarm Response Instructions.	per Alarm		
	SS	Dispatches operator to monitor local panel and Service Transformer.On orders of SS, transfers loads from Service Transformer 11 to Service Transformer 21.Reports trip of Service Transformer 11 and recovers any buses lost.Determines and recovers equipment lost.Dispatches operator to reset any Bus Undervoltage devices.			
	вор				
	BOP				
	RO/BOP				
	SS/BOP				
	SS	Dispatches operator to monitor diesel generator operation as necessary.			

Appendix D		Operator Actions	Form ES-D-2	
Op-Test Event D	t No.: Sc escription: Feed from	enario No.:2_ Event No.:6 water Rupture in the Drywell with leakage past cl the Reactor	heck valves	
Time	Position	Applicant's Actions or Behavior		
	RO	Recognizes scram on High Drywell Pressure/Low F level and performs the immediate actions for React Reports all rods fully inserted and places the React to SHUTDOWN.	Reactor Water or Scram. or Mode Switch	
	RO	Recognizes loss of ability to feed the reactor with C Feedwater. Communicates the loss to the SS. Ma conditions recognize which feed line has rupture.	Condensate and y depending on	
	SS	Enters EP-2 and EP-3, orders the BOP Operator to RCIC and inhibit ADS (if HPCS auto initiated the pu	initiate HPCS, ump is tripped).	
	BOP	Recognizes the failure of Division 2 to initiate and n Division 2 ECCS.	nanually initiates	
	вор	Verifies/initiates HPCS (recognizes trip of HPCS pu	ımp)	
	BOP or RO	Verifies/initiates RCIC (If RO/SS determine which F is ruptured prevents operation of RCIC – pumps int break.)	Feedwater Line to line with	
	SS	Orders CRD maximized and possible initiation of S	LC.	
	SS	Dispatches EP Attachments to be installed Attachment 12 RHR through Shutdown Cooling Attachment 25 Condensate Transfer injection Attachment 26 Fire Water injection		
	SS	Dispatches Operators, electricians to investigate pr HPCS.	oblems with	

SS **	Orders alignment of Low Pressure ECCS for injection to the Reactor.		
BOP or RO	Align Low Pressure ECCS for injection.		
SS	Orders depressurization of the Reactor with either SRVs or Main Steam Bypass Valves to a pressure which will allow injection from Low Pressure ECCS.		
SS **	If Reactor Level drops below – 192 inches, orders Emergency Depressurization with 8 SRVs (at least 5 SRVs should be open)		
BOP or RO **	On orders, opens 8 SRVs using handswitches (initiation pushbuttons may be used initially, however should be followed with handswitches.)		
SS **	If conditions require RPV Flooding order injection to attain RPV pressure 57 psig above Containment pressure		
BOP or RO	Verifies injection to the RPV with Low Pressure ECCS.		

Scenario Outline

i						
Facility: GR	AND GULF NUCLEAR STATION Scenario No.: 3 Op-Test No.: Day 1					
Examiners:	Operators:					
Objectives:	To evaluate the candidates' ability to operate the facility in response to the following evolutions:					
	1. Raise Reactor Power using Recirculation Flow.					
	2. Start 3 rd Condensate and Condensate Booster Pumps.					
	3. Respond to a trip of RPS Motor Generator 'B'.					
	4. Determine the source and respond to a leak on the suction valve of RHR Pump 'C', EOP entry.					
	5. Respond to a steam leak in the Auxiliary Building Steam Tunnel and a failure of Group 1 to isolate.					
	6. Take actions per the EOPs in response to two stuck control rods following a Reactor Scram.					
	7. Take actions per EOPs to control RPV parameters with a failure the MSIVs to isolate the steam leak.					
Initial Cond	itions: Reactor Power is at 83 % continuing power ascension to rated conditions.					
INOPERABI	F Equipment					
APRM 'H	is INOP due to a failed power supply card					
ESF 12 T	ransformer is tagged out of service for maintenance					
TBCW Pu	mp 'C' is tagged out of service for pump seal replacement					
Appropriate	clearances and LCOs are written.					
<u>Turnover:</u> thunder sho	Continue power ascension. Radwaste is prepared for full Condensate and Feedwater operation. There are scattered wers reported in the Tensas Parish area.					

Scenario **3** Day **1** (Continued)

Event No.	10CFR 55.45(a)	K/A	Event Type*	Event Description
1	1, 2, 4, 5, 6, 8	202001 A4.04 202002 A4.08 2.2.2	R (RO)	Raise Total Core Flow to >12.5 Mlbm/hr Feedwater Flow. (IOI 03-1-01-2)
2	2, 4, 5, 6	256000 A3.02; A4.01	N (RO)	Start 3 rd Condensate and Condensate Booster Pump. (SOI 04-1-01-N19-1)
3	3, 5, 6	212000 A1.11; A2.01; A4.07	C (RO, BOP)	Respond to trip of RPS Motor Generator 'B'. (ONEP 05-1-02-III-2)
4	3, 4, 5, 6	295036 EA1.02	C (BOP)	Determine the source and respond to a packing leak on E12-F004C RHR 'C' Suction Valve, with the valve failure determine unisolable and take actions per EOP $-3 \& 4$.
5	3, 4, 6, 13	2.4.46; 2.4.47; 2.4.48; 2.4.49	M (ALL)	Recognize and respond to a steam leak in the Auxiliary Building Steam Tunnel.
	3, 4, 6, 13	2.4.46; 2.4.47; 2.4.48; 2.4.49 290001 A2.06; A4.04	I (BOP)	Recognize the failure of Group 1 to automatically isolate and take actions to isolate the Main Steam Lines (ONEP 05-1-01-III-5)
	3, 4, 6, 13	2.4.46; 2.4.47; 2.4.48; 2.4.49 290001 A2.06; A4.04		Recognize the failure of a single Main Steam line to isolate and take actions for mitigation of the leak.
	4, 6, 12, 13	295037 EA1.0; EA2.0 212000 A4.17	C (RO)	Recognize the failure of two control rods to fully insert on the Reactor Scram and take actions as necessary per procedures to insert the control rods.

All evolutions test 55.45(a) 12 & 13.

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Critical Tasks

- Manually scram the reactor. Isolate the main steam lines. -
- -

Append	x D	Scenario Outline Form ES-D-1					
Facility:	Facility: GRAND GULF NUCLEAR STATION Scenario No.: 3 Op-Test No.: Day 1						
Examin	ers:		Operators:				
<u>Objecti</u> followin	Objectives: To evaluate the candidates' ability to operate the facility in response to the following evolutions:						
	1. Rai	se Reactor	Power using Recirculation Flow.				
	2. Sta	rt 3 rd Cond	ensate and Condensate Booster Pl	umps.			
	3. Re: 4. Det	ermine the	source and respond to a leak on the	ne suction valve of RHR			
	Pur	np 'C', EOF	P entry.				
	5. Res	spond to a	steam leak in the Auxiliary Building	Steam Tunnel and a failure			
	6. Tak	e actions r	solate. per the EOPs in response to two st	uck control rods following a			
	Rea	actor Scram).	dont control roug rono ming a			
	7. Take actions per EOPs to control RPV parameters with a failure the MSIVs						
	to is	solate the s	iteam leak.				
Initial C	onditions:	Reactor Po	ower is at 85 % continuing power as	scension to rated			
conditio	ns.						
INOPE	RABLE Equi	oment					
APR	M 'H' is INO	P due to a f	ailed power supply card				
ESF	12 Transforr	ner is tagg	ed out of service for maintenance	mont			
Approp	iate clearan	ces and LC	to service for pump seal replace	ment			
Turnov	er: Continu	e power as	cension. Radwaste is prepared for	r full Condensate and			
area.	area						
Evont	Malf No	Event	Evon	+			
No.	Mail. NO.	Type*	Descript	tion			
1		R (RO)	Raise Total Core Flow to >12.5 M (IOI 03-1-01-2)	Ilbm/hr Feedwater Flow.			
2	N (RO) Start 3 rd Condensate and Condensate Booster Pump. (SOI 04-1-01-N19-1)						

REVISION 2 03/29/2001

SCENARIO 3 PAGE 1

Scenario Outline

Scenario 3 Day 1 (Continued)

Event No.	Malf. No.	Event Type*	Event Description
3	c71077b	C (RO, BOP)	Respond to trip of RPS Motor Generator 'B'. (ONEP 05-1-02-III-2)
4	ct218c @ 2% see list for E12F004C	C (BOP)	Determine the source and respond to a packing leak on E12- F004C RHR 'C' Suction Valve, with the valve failure determine unisolable and take actions per EOP – 3 & 4.
5	ms066b @ 0.2% c71076	M (ALL)	Recognize and respond to a steam leak in the Auxiliary Building Steam Tunnel.
	epatt09 ms067b @ 20%	I (BOP)	Recognize the failure of Group 1 to automatically isolate and take actions to isolate the Main Steam Lines (ONEP 05-1-01-III-5)
	ms183b ms184b		Recognize the failure of a single Main Steam line to isolate and take actions for mitigation of the leak.
	z022022 _08-29 _12_09	C (RO)	Recognize the failure of two control rods to fully insert on the Reactor Scram and take actions as necessary per procedures to insert the control rods.

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Critical Tasks

- Manually scram the reactor.
- Isolate the main steam lines.

Scenario 3 Day 1 (Continued)

Crew Turnover: Rx at 83% CTP. The plant is raising power following an outage. APRM 'H' is failed due to a failed power supply card and bypassed. ESF 12 Transformer is tagged out of service for maintenance. TBCW Pump 'C' is tagged out of service for pump seal replacement. Appropriate clearances and LCOs are written.

The reactor is at the target rod line. Continue to bring the plant to full power per IOI-2 step 6.6.

Plant EOOS factor is 10 GREEN.

There are scattered thunderstorms reported in the Tensas Parish area.

Simulator Setup: (Scenarios may be setup and shot into encrypted ICs and Password protected.) Start the process from a new simulator load. Reset to IC-14.

Verify or perform the following:

IC:	14
OOS:	ESF Transformer 12 (Place tags on 152-1903. 1904, 1905, 1511, 1611, and 1704) TBCW C Pump (Place tag on start HS)
Active malfunctions:	c51010h APRM H downscale z022022_08_29 Control Rod 08-29 stuck z022022_12_09 Control Rod 12-09 stuck ms183b MSIV B21-F022B failed open (as-is) ms 184b MSIV B21-F028B failed open (as-is)
Active overrides	epatt09 EP Attachment 9 Defeat MSIV/Group 1 isolation INSTALL
Pending overrides	None

REVISION 2 03/29/2001

SCENARIO 3 PAGE 3 NUREG 1021 REVISION 8 SUPPLEMENT 1

Pending malfunctions:	c71077b RPS Moto	7b RPS Motor Generator 'B' trip (TRG 1)			
C	ct218c @ 2% Leak in RHR C room from Suppression Pool (TRG 2)				
	ms066b @ 0.2% N	Iain Steam Line B steam leak in Auxiliary Building			
	Steam Tunnel (TRG 4) ramp to 20% over 6 minutes				
	c71076 Failure to s	cram (manual available)			
	ms067b @ 20% Main Steam Line B Rupture ramp to 40% over 7 minutes (TRG 5).				
Pending component malfuncti	ons: lo 1e12m6	D2c g E12-F004C green light OFF (TRG 3)			
	lo_1e12m6	lo_1e12m602c_r E12-F004C red light OFF (TRG 3)			
	di_1e12m6	di 1e12m602c(2) E12-F004C handswitch to OPEN (TRG 3)			
	lo_1e12ads	lo 1e12ads23 RHR C MOV overload / power loss Status light			
	ON (TRG 3)			
	P601_17a_1	P601_17a_h_3 RHR C SYS OOSVC annunciator ON (TRG 3)			
Trigger files:	Trigger 1	RPS Motor Generator 'B' trip			
20	Trigger 2	Leak in RHR 'C' Pump Room			
	Trigger 3	E12-F004C failure			
	Trigger 4	Steam leak in Aux Bldg Steam Tunnel; Automatic Scram Failure			
	Trigger 5	Steam Rupture in Aux Bldg Steam Tunnel			

COMPONENT	PANEL	INDICATION or	SIMULATOR	STATUS	DONE
		CONTROL	CODE		
APRM H		DOWNSCALE	c51010h		
TBCW PUMP C	P870-5C	GREEN LIGHT	lo_1p43m600c_g	OFF	
		HANDSWITCH	di_1p43m600c	STOP	
ESF 12 BREAKER 152-1903	P807-1C	GREEN LIGHT	lo_1r21m623_g	OFF	
		HANDSWITCH	di_1r21m623	TRIP	
ESF 12 BREAKER 152-1904	P807-1C	GREEN LIGHT	lo_1r21m624_g	OFF	
		HANDSWITCH	di_1r21m624	TRIP	
ESF 12 BREAKER 152-1905	P807-1C	GREEN LIGHT	lo_1r21m637_g	OFF	
		HANDSWITCH	di_1r21m637	TRIP	
ESF 12 FEEDER 152-1511	P864-1C	GREEN LIGHT	lo_1r21m601a_g	OFF	
		HANDSWITCH	di_1r21m601a	TRIP	
ESF 12 FEEDER 152-1611	P864-2C	GREEN LIGHT	lo_1r21m601b_g	OFF	
		HANDSWITCH	di_1r21m601b	TRIP	
ESF 12 FEEDER 152-1704	P601-16C	GREEN LIGHT	lo_1e22m709_g	OFF	
		HANDSWITCH	di_1e22m709	TRIP	
115 KV DISCONNECT J3885	P807-1C	GREEN LIGHT	lo_1r27r602_g	OFF	
J3885		DISCONNECT		OPEN	

REVISION 2 03/29/2001

SCENARIO 3 PAGE 4 Bypass Division 2 APRM Bypass Joystick to APRM H position.

Open Circuit Breakers 152-1903, 1904, 1905, 1511, 1611, and 1704

Place TBCW pump B to STOP (to clear Standby light) then to START, stop TBCW pump C.

Ensure only two Condensate and Condensate Booster Pumps are operating.

Startup all PDS / SPDS screens. Clear any graphs and trends off of SPDS.

Setup the presently used cyclops display and verify it is functional.

Ensure the correct startup sequence is available at the P680 for the present IC.

Install turnover guide, red tag, and LCO paperwork as applicable.

Advance all chart recorders and ensure all pens are inking properly. (APRM chart recorders must be turned on and settings for scales on pens 0 - 125 scale)

SIMULATOR OPERATION SCENARIO 3

Once simulator is reinitialized and setup complete take the simulator out of Freeze.

Once the Crew has taken control note the simulator time.

The Crew will raise reactor power using Recirculation Flow to just above 14 mlbm/hr Feedwater Flow.

Above 14 mlbm/hr, they will place the third Condensate and Condensate Booster Pump in service. They may contact Radwaste about Condensate Demins.

Two (2) minutes after the Condensate Pump evolution is complete, activate TRIGGER 1.

Loss of RPS MG 'B' Cues:

If asked, report as Control Building Operator, RPS MG 'B' has tripped. The Alternate supply EPA breakers are closed.

Six (6) minutes after the loss of RPS MG 'B', activate TRIGGER 2.

Call up display of H13-P601 section 17C in the area of E12-F004C.

Upon alarms in RHR 'C' Pump room on high water level, the crew will attempt to close E12-F004C, when dual indication occurs on RHR 'C' suction valve <u>activate TRIGGER 3</u>.

REVISION 2 03/29/2001	SCENARIO 3	NUREG 1021 REVISION 8
	PAGE 5	SUPPLEMENT 1

Cues:

If asked, respond as the Auxiliary Building Operator that water is seeping from below the RHR 'C' Pump Room door. From viewing from 119' Piping Penetration Room water is covering the floor.

If asked, respond as the Auxiliary Building Operator that water is coming from around the E12-F004C. Could be a packing leak.

If asked to check the circuit breaker for E12-F004C (52-161114 MCC 16B11), respond as the operator the breaker is in the trip free position and will not reset.

If asked, respond as electricians the breaker will NOT reset and stay closed.

Five (5) minutes after the RHR 'C' Pump Room alarms are received, activate TRIGGER 4.

When Crew initiates Manual scram, activate TRIGGER 5.

Two (2) Minutes after Reactor Scram, report as Security white smoke or steam is coming out of the top of the Auxiliary Building.

If contacted, report as Health Physics there are NO abnormal radiation surveys of the Auxiliary Building.

If contacted, report as Chemistry there are NO verified leaking fuel bundles in the reactor.

If SS decides to install attachments to attempt to insert the two stuck control rods.

Attachment	18	Defeat ATWS ARI	4 minutes to DONE
Attachment	19	Defeat RPS	5 minutes to DONE
Attachment	20	Defeat RCIS	6 minutes to DONE
Attachment	2	Defeat RCIC Trips	8 minutes to DONE
Attachment	1	Defeat RCIC Suction Xfer	8 minutes to DONE
Attachment	12	Defeat RHR SDC Interlocks	6 minutes to DONE

TERMINATION

Once reactor pressure has lowered to < 600 psig and a system is aligned for RPV level control and the Lead Evaluator concurs the scenario may be terminated.

Critical Tasks

- Manually scram the reactor.

REVISION 2 03/29/2001

SCENARIO 3 PAGE 6 NUREG 1021 REVISION 8 SUPPLEMENT 1 - Isolate the main steam lines.

REVISION 2 03/29/2001

SCENARIO 3 PAGE 7 NUREG 1021 REVISION 8 SUPPLEMENT 1

Г

Operator Actions

1

Op-Test No.: Scenario No.:3_ Event No.:1			
Event Description: Raise Reactor Power by raising Total Recirc Flow.			
Time	Position	osition Applicant's Actions or Behavior	
	SS	Provides Reactivity brief to crew.	
	RO	Verifies position on Power to Flow Map.	
	RO	Opens Recirc Flow Control Valves to raise Reactor Power.	
	BOP	Monitor Power, Level, Pressure, and Turbine Loading during the evolution.	

Op-Test No.: Scenario No.:3_ Event No.:2 Event Description: Start 3 rd Condensate and Condensate Booster Pump (SOI 04-1-01-N19-1)			
Time	Position	Applicant's Actions or Behavior	
	RO	Starts up 3 rd Condensate Pump.	
	RO	Starts up 3 rd Condensate Booster Pump.	

Operator Actions

Op-Test No.: _____ Scenario No.: __3__ Event No.: __3___ Event Description: Respond to a trip of RPS Motor Generator 'B' (ONEP 05-1-02-III-2) Position Time Applicant's Actions or Behavior RO Identify the loss of RPS Motor Generator 'B' SS Dispatch operators to investigate loss of RPS MG. BOP Check H13-P610 for availability of Alternate Power for RPS 'B'. On orders from SS transfer RPS 'B' to alternate source. RO Resets RPS 'B' scram signals. SS Dispatches electricians to investigate loss of RPS MG.

Appendix D		Operator Actions	Form ES-D-2	
Op-Test No.: Scenario No.:3_ Event No.:4 Event Description: Respond to a leak from the Suppression Pool into RHR 'C' Pump Room via failed E12-F004C packing. (EP 3 & 4)				
Time	Position	Applicant's Actions or Behavi	or	
	RO	Reports RHR 'C' Room Sump High-High level a	ılarm.	
	SS	Enters EP-4 and dispatches operator to investig	gate.	
	ВОР	Reports RHR 'C' Room Flooded alarm and lowe Pool level.	ering Suppression	
	SS	Upon Suppression Pool Low level alarm, enters	s EP-3.	
	RO	On orders of SS attempts to isolate RHR 'C' by reports failure of valve to stroke and loss of pow	closing E12-F004C, /er.	
	SS	Orders makeup to Suppression Pool. May use Refueling Water Transfer or SPMU.	HPCS, RCIC,	
	SS	May elect to Manually scram the reactor.		

Form ES-D-2 Appendix D **Operator Actions** Op-Test No.: _____ Scenario No.: __3_ Event No.: __5___ Event Description: Respond to a steam leak in Auxiliary Building Steam Tunnel with a failure to isolate. (EP-4) w/ Automatic Scram failure Scenario is geared toward EP-4 actions, stuck control rods is for operator board awareness. Position Time Applicant's Actions or Behavior BOP Announces Steam Tunnel temperature alarms and EP-4 entry and failure of Group 1 to isolate. BOP** Manually isolates MSIVs and reports failure of 'B' Main Steam Line to isolate and closes B21-F098B Main Steam Shutoff Valve. RO** Inserts a manual Scram (recognition of failure to automatic scram is not critical if reactor manually scrammed.) RO Recognizes failure of two control rods to fully insert. (Control Rods 08-29 & 12-09) Enters EP-2A for two Control Rods and EP-4 for Steam leak in SS Auxiliary Building. (SS should recognize no conditions exist warranting lowering of reactor level for ATWS.) CREW Maintains reactor water level using RCIC or HPCS. Condensate and Feedwater may be used when reactor pressure drops below Condensate Booster Pump shutoff head. SS As conditions dictate may elect to lower reactor pressure using SRVs to reduce energy release to Secondary Containment. BOP or RO On orders of SS lowers reactor pressure using SRVs.