

April 3, 2002

LICENSEE: Calvert Cliffs Nuclear Power Plant, Inc.

FACILITY: Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2

SUBJECT: SUMMARY OF MARCH 21, 2002, MEETING WITH CALVERT CLIFFS
NUCLEAR POWER PLANT, INC. TO DISCUSS PARTIAL REPLACEMENT OF
POST-ACCIDENT MONITORING SYSTEM INSTRUMENTATION

On March 21, 2002, a public meeting was held between Calvert Cliffs Nuclear Power Plant, Inc. (CCNPPI) and the Nuclear Regulatory Commission (NRC) staff. The purpose of the meeting was to discuss the licensee's proposed implementation of a digital upgrade to the post-accident monitoring system (PAMS) for Calvert Cliffs, Unit Nos. 1 and 2. Enclosure 1 is the list of attendees and Enclosure 2 contains the slides from the meeting.

CCNPPI provided an overview of the upgrade project including the licensing approach. CCNPPI has evaluated the modification under 10 CFR 50.59 and concluded that, because the components that will be changed are for indication only and have no active function, the change does not require prior NRC review and approval. CCNPPI will be using the Westinghouse Common Qualified Platform as described in Topical Report (TR) CENPD-396-P, Rev. 01, "Common Qualified Platform" Appendix 1 which describes the Post Accident Monitoring System. The topical report is still under review by the staff. Westinghouse anticipates that the staff's review of its topical report will be completed by October 2002. CCNPPI plans to implement the PAMS modification in Unit 2 during the spring 2003 refueling outage and in Unit 1 during the spring 2004 outage.

Enclosures: As stated

cc w/encls: See next page

April 3, 2002

LICENSEE: Calvert Cliffs Nuclear Power Plant, Inc.

FACILITY: Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2

SUBJECT: SUMMARY OF MARCH 21, 2002, MEETING WITH CALVERT CLIFFS NUCLEAR POWER PLANT, INC. TO DISCUSS PARTIAL REPLACEMENT OF POST-ACCIDENT MONITORING SYSTEM INSTRUMENTATION

On March 21, 2002, a public meeting was held between Calvert Cliffs Nuclear Power Plant, Inc. (CCNPPI) and the Nuclear Regulatory Commission (NRC) staff. The purpose of the meeting was to discuss the licensee's proposed implementation of a digital upgrade to the post-accident monitoring system (PAMS) for Calvert Cliffs, Unit Nos. 1 and 2. Enclosure 1 is a list of attendees and Enclosure 2 contains the slides from the meeting.

CCNPPI provided an overview of the upgrade project including the licensing approach. CCNPPI has evaluated the modification under 10 CFR 50.59 and concluded that, because the components that will be changed are for indication only and have no active function, the change does not require prior NRC review and approval. CCNPPI will be using the Westinghouse Common Qualified Platform as described in Topical Report (TR) CENPD-396-P, Rev. 01, "Common Qualified Platform" Appendix 1 which describes the Post Accident Monitoring System. The topical report is still under review by the staff. Westinghouse anticipates that the staff's review of its topical report will be completed by October 2002. CCNPPI plans to implement the PAMS modification in Unit 2 during the spring 2003 refueling outage and in Unit 1 during the spring 2004 outage.

Enclosures: As stated

cc w/encls: See next page

DISTRIBUTION:

PUBLIC	OGC
PDI-1 R/F	ACRS/ACNW
DSkay	JZwolinski/TMarsh
SLittle	JMunday
EMarinos	DMcCain
KMortensen	TBergman, RGI
MChiramal	BPlatchek, RGI
CGraham	

Package: ML020980231

Enclosure 2: ML020940328

ACCESSION NO.: ML020880646

OFFICE	PM:PDI-1	E	LA:PDI-1	SC:PDI-1
NAME	DSkay		SLittle	JMunday
DATE	4/02/2002		4/3/02	4/3/02

Official Record Copy

Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 and 2

cc:

President
Calvert County Board of
Commissioners
175 Main Street
Prince Frederick, MD 20678

James Petro, Esquire
Counsel
Constellation Power Source
111 Market Street
Baltimore, MD 21202

Jay E. Silberg, Esquire
Shaw, Pittman, Potts, and Trowbridge
2300 N Street, NW
Washington, DC 20037

Mark Geckle
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

Resident Inspector
U.S. Nuclear Regulatory
Commission
P.O. Box 287
St. Leonard, MD 20685

Mr. Richard I. McLean, Manager
Nuclear Programs
Power Plant Research Program
Maryland Dept. of Natural Resources
Tawes State Office Building, B3
Annapolis, MD 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Kristen A. Burger, Esquire
Maryland People's Counsel
6 St. Paul Centre
Suite 2102
Baltimore, MD 21202-1631

Patricia T. Birnie, Esquire
Co-Director
Maryland Safe Energy Coalition
P.O. Box 33111
Baltimore, MD 21218

Mr. Loren F. Donatell
NRC Technical Training Center
5700 Brainerd Road
Chattanooga, TN 37411-4017

Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 and 2

cc:

President
Calvert County Board of
Commissioners
175 Main Street
Prince Frederick, MD 20678

Kristen A. Burger, Esquire
Maryland People's Counsel
6 St. Paul Centre
Suite 2102
Baltimore, MD 21202-1631

James Petro, Esquire
Counsel
Constellation Power Source
111 Market Street
Baltimore, MD 21202

Patricia T. Birnie, Esquire
Co-Director
Maryland Safe Energy Coalition
P.O. Box 33111
Baltimore, MD 21218

Jay E. Silberg, Esquire
Shaw, Pittman, Potts, and Trowbridge
2300 N Street, NW
Washington, DC 20037

Mr. Loren F. Donatell
NRC Technical Training Center
5700 Brainerd Road
Chattanooga, TN 37411-4017

Mark Geckle
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

Resident Inspector
U.S. Nuclear Regulatory
Commission
P.O. Box 287
St. Leonard, MD 20685

Mr. Richard I. McLean, Manager
Nuclear Programs
Power Plant Research Program
Maryland Dept. of Natural Resources
Tawes State Office Building, B3
Annapolis, MD 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

MEETING WITH CALVERT CLIFFS NUCLEAR POWER PLANT, INC.

THURSDAY, MARCH 21, 2002

<u>NAME</u>	<u>ORGANIZATION</u>
Barry Thurston	Constellation
Doug Lenker	Constellation
Jim McQuighan	Constellation
Steve Dobler	Constellation
Donna Moeller	Constellation
Steve Paul	Bechtel
John Duryea	Westinghouse
Denny Popp	Westinghouse
Donna Skay	NRR/ DLPM
Angelos Marinos	NRR/ EEIB
Keith Mortensen	NRR/ EEIB
Matt Chiramal	NRR/ EEIB
Christopher Graham	NRR/ EEIB