

June 12, 1984

Docket No. 50-263

Mr. D. M. Musolf
Nuclear Support Services Department
Northern States Power Company
414 Nicollet Mall - 8th Floor
Minneapolis, Minnesota 55401

Dear Mr. Musolf:

SUBJECT: ISSUANCE OF ORDER CONFIRMING LICENSEE COMMITMENTS
ON EMERGENCY RESPONSE CAPABILITY

The Commission has issued the enclosed Order confirming your commitments on emergency response capability for the Monticello Nuclear Generating Plant. This Order is based on your letters dated April 15, November 11, December 28 and 30, 1983 and March 30, 1984, committing to the actions specified in the Order.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

Original signed by/

Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Enclosure:
Order

cc w/enclosure:
See next page

DISTRIBUTION

Docket File	DEisenhut	ELJordan	JNGrace
NRC PDR	ORAB	TBarnhart (4)	SECY
Local PDR	SNorris	ACRS (10)	RDiggs
ORB#2 Reading	VRooney	OPA, CMiles	RSmith
Gray File	OELD	NSIC	Extra - 5

*Please see previous concurrence page.

DL:ORB#2	DL:ORB#2	DL:ORB#2	DL:ORB#5	DL:AD-OR	OELD	DL: DVP
SNorris:ajs*	HNicolaras*	DVassallo*	DCrutchfield*	GLainas*	SBurns*	DEisenhut
10/14/83	10/14/83	10/14/83	10/18/83	10/18/83	11/04/83	04/ /84

8406260027 840612
PDR ADOCK 05000263
F PDR

Mr. D. M. Musolf
Northern States Power Company
Monticello Nuclear Generating Plant

cc:

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and
Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

U. S. Nuclear Regulatory Commission
Resident Inspector's Office
Box 1200
Monticello, Minnesota 55362

Plant Manager
Monticello Nuclear Generating Plant
Northern States Power Company
Monticello, Minnesota 55362

Russell J. Hatling
Minnesota Environmental Control
Citizens Association (MECCA)
Energy Task Force
144 Melbourne Avenue, S. E.
Minneapolis, Minnesota 55113

Executive Director
Minnesota Pollution Control Agency
1935 W. County Road B2
Roseville, Minnesota 55113

Mr. Steve Gadler
2120 Carter Avenue
St. Paul, Minnesota 55108

Mr. John W. Ferman, Ph.D.
Nuclear Engineer
Minnesota Pollution Control Agency
1935 W. County Road B2
Roseville, Minnesota 55113

Commissioner of Health
Minnesota Department of Health
717 Delaware Street, S. E.
Minneapolis, Minnesota 55440

Auditor
Wright County Board of Commissioners
Buffalo, Minnesota 55313

U. S. Environmental Protection
Agency
Region V Office
Regional Radiation Representative
230 South Dearborn Street
Chicago, Illinois 60604

James G. Keppler
Regional Administrator
Region III Office
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

- 2 -

accident. The requirements are set forth in NUREG-0737, "Clarification of TMI Action Plan Requirements," and in Supplement 1 to NUREG-0737, "Requirements for Emergency Response Capability." Among these requirements are a number of items consisting of emergency response facility operability, emergency procedure implementation, addition of instrumentation, possible control room design modifications, and specific information to be submitted.

On December 17, 1982, a letter (Generic Letter 82-33) was sent to all licensees of operating reactors, applicants for operating licenses, and holders of construction permits enclosing Supplement 1 to NUREG-0737. In this letter operating reactor licensees and holders of construction permits were requested to furnish the following information, pursuant to 10 CFR 50.54(f), no later than April 15, 1983:

- (1) A proposed schedule for completing each of the basic requirements for the items identified in Supplement 1 to NUREG-0737, and
- (2) A description of plans for phased implementation and integration of emergency response activities including training.

III.

NSP responded to Generic Letter 82-33 by letter dated April 15, 1983. In a meeting on July 20, 1983, these dates were negotiated between NRC and NSP staffs. In a letter dated November 11, 1983, NSP committed to the negotiated dates. In this submittal, NSP made commitments to complete the basic requirements. In letters dated December 28 and 30, 1983, and March 30, 1984, NSP provided additional information and made additional

- 3 -

commitments to meet all requirements. The attached Table summarizing NSP's schedular commitments or status was developed by the NRC staff from the Generic Letter and the information provided by NSP during the meeting.

NSP's commitments include (1) dates for providing required submittals to the NRC, (2) dates for implementing certain requirements, and (3) a schedule for providing implementation dates for other requirements. These latter implementation dates will be reviewed, negotiated and confirmed by a subsequent order.

The NRC staff reviewed NSP's April 15, 1983 letter and entered into negotiations with the licensee regarding schedules for meeting the requirements of Supplement 1 to NUREG-0737. The NRC staff finds that the dates are reasonable, achievable dates for meeting the Commission requirements. The NRC staff concludes that the schedule proposed by the licensee will provide timely upgrading of the licensee's emergency response capability.

In view of the foregoing, I have determined that the implementation of NSP's commitments are required in the interest of the public health and safety and should, therefore, be confirmed by an immediately effective Order.

IV.

Accordingly, pursuant to Sections 103, 161i, 161o and 182 of the Atomic Energy Act of 1954, as amended, and the Commission's regulations in 10 CFR Parts 2 and 50, IT IS HEREBY ORDERED, EFFECTIVE IMMEDIATELY, THAT the licensee shall:

Implement the specific items described in the Attachment to this ORDER in the manner described in NSP's submittals noted in Section III herein no later than the dates in the Attachment.

- 4 -

Extensions of time for completing these items may be granted by the Director, Division of Licensing, for good cause shown.

V.

The licensee may request a hearing on this Order within 20 days of the date of publication of this Order in the Federal Register. Any request for a hearing should be addressed to the Director, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555. A copy should also be sent to the Executive Legal Director at the same address. A REQUEST FOR HEARING SHALL NOT STAY THE IMMEDIATE EFFECTIVENESS OF THIS ORDER.

If a hearing is to be held, the Commission will issue an Order designating the time and place of any such hearing.

If a hearing is held concerning this Order, the issue to be considered at the hearing shall be whether the licensee should comply with the requirements set forth in Section IV of this Order.

This Order is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Dated at Bethesda, Maryland,
this 12 day of June, 1984.

Attachment:
Licensee's Commitments on
Requirements Specified in
Supplement 1 to NUREG-0737

LICENSEE'S COMMITMENTS ON SUPPLEMENT 1 TO NUREG-0737

TITLE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)
1. Safety Parameter Display System (SPDS)	1a. Submit a safety analysis and an implementation plan to the NRC.	May 31, 1984: ^C Implementation Plan December 31, 1984: Safety Analysis Report
	1b. SPDS fully operational and operators trained.	Before startup of Cycle 12: SPDS equipment installed, software, operator training and pre-operational training completed. 6 Mos. after startup of Cycle 12: Operational testing of SPDS w/followup corrective actions completed.
2. Detailed Control Room Design Review (DCRDR)	2a. Submit a program plan to the NRC.	Complete
	2b. Submit a summary report to the NRC including a proposed schedule for implementation.	July 31, 1985
3. Regulatory Guide 1.97 - Application to Emergency Response Facilities	3a. Submit a report to the NRC describing how the requirements of Supplement 1 to NUREG-0737 have been or will be met.	Complete
	3b. Implement (installation or upgrade) requirements.	Before startup of Cycle 12

LICENSEE'S COMMITMENTS ON SUPPLEMENT 1 TO NUREG-0737

TITLE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)
4. Upgrade Emergency Operating Procedures (EOPs)	4a. Submit a Procedures Generation Package to the NRC.	July 31, 1984
	4b. Implement the upgraded EOPs.	September 30, 1985: EOP Implementation w/o SPDS. 6 Mos. after startup of Cycle 12: EOP Implementation w/SPDS.
5. Emergency Response Facilities	5a. Technical Support Center fully functional.	December 31, 1983: (Completed) Complete w/meteorological data and offsite dose assessment. Within 6 Mos. after startup of Cycle 12: Later enhancement by SPDS. Before startup of Cycle 12 Further enhancement by R. G. 1.97.
	5b. Operational Support Center fully functional.	Complete and fully functional.
	5c. Emergency Operations Facility fully functional.	Same as response to 5a (above).