

LICENSEE: ARIZONA PUBLIC SERVICE CO.

SITE: PALO VERDE 1 2 3

EN NUMBER: 26650

DOCKET: 05000528 05000529 05000530

EVENT DATE: 01-20-94

RX TYPE: PWR PWR PWR

EVENT TIME: 00:00

VENDORS: CE80 CE80 CE80

NOTIFY DATE: 01-20-94

EMERGENCY CLASS: N/A REGION: 5 STATE: AZ

TIME: 14:45

OPS OFFICER: THOMAS ANDREWS

10 CFR SECTION: NINF

INFORMATION ONLY

UNIT	SCRAM CODE	RX CRIT	INIT PWR	INITIAL MODE	CURR PWR	CURRENT MODE
1	N	Y	85	POWER OPERATION	85	POWER OPERATION
2	N	N	0	COLD SHUTDOWN	0	COLD SHUTDOWN
3	N	Y	85	POWER OPERATION	85	POWER OPERATION

THE ANCHOR DARLING VALVE COMPANY HAS NOTIFIED WESTINGHOUSE, WHO HAS SUBSEQUENTLY NOTIFIED PALO VERDE, OF A SITUATION RELATED TO 3", 4", AND 8" SWING CHECK VALVES MANUFACTURED BY ANCHOR DARLING.

THE VALVES HAVE DOWEL PINS THAT ARE NOT SUFFICIENT IN LENGTH AND MAY RESULT IN EITHER NOT FULLY SEATING OR NOT FULLY OPENING WHEN REQUIRED.

THE LICENSEE IS RESEARCHING THE INFORMATION PROVIDED IN THE 12/21/93 WESTINGHOUSE LETTER TO DETERMINE IF THIS EVENT IS REPORTABLE UNDER 10 CFR 50.52, 50.53 OR 10 CFR 21. THEY DO NOT KNOW WHAT SYSTEMS, IF ANY, THAT MAY BE AFFECTED BY THIS NOTIFICATION.

THE LICENSEE HAS NOTIFIED THE NRC RESIDENT INSPECTOR.

HOO NOTE: FAXED COPY OF EVENT TEXT AND COPY OF WESTINGHOUSE AND ANCHOR

DARLING LETTERS RECEIVED BY LICENSEE TO WALTER HAASS.