

November 27, 1984

Docket No. 50-263

Mr. D. M. Musolf
Nuclear Support Services Department
Northern States Power Company
414 Nicollet Mall - 8th Floor
Minneapolis, Minnesota 55401

Dear Mr. Musolf:

On October 31, 1984 we issued Amendment No. 27 to Facility Operating License No. DPR-22 for the Monticello Nuclear Generating Plant. Page 105 was inadvertently omitted when the amendment was issued. There are no technical changes on page 105, it was merely reformatted. Please substitute the enclosed page 105 for the existing page 105.

We regret any inconvenience this may have caused.

Sincerely,

Original signed by/

Vernon L. Rooney, Project Manager
Operating Reactors Branch #2
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION

Docket File
NRC PDR
Local PDR
ORB#2 Reading
DEisenhut

SNorris
V Rooney
OELD
LJHarmon
ELJordan

PMcKee
TBarnhart (4)
WJones
DBrinkman
ACRS (10)

OPA, CMiles
RDiggs
Gray File
Extra - 5
JPartlow

DL:ORB#2
SNorris:ajs
11/27/84

DL:ORB#2
V Rooney
11/27/84

DL:ORB#2
DVassallo
11/27/84

Mr. D. M. Musolf
Northern States Power Company
Monticello Nuclear Generating Plant

cc:

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and
Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

U. S. Nuclear Regulatory Commission
Resident Inspector's Office
Box 1200
Monticello, Minnesota 55362

Plant Manager
Monticello Nuclear Generating Plant
Northern States Power Company
Monticello, Minnesota 55362

Russell J. Hatling
Minnesota Environmental Control
Citizens Association (MECCA)
Energy Task Force
144 Melbourne Avenue, S. E.
Minneapolis, Minnesota 55113

Executive Director
Minnesota Pollution Control Agency
1935 W. County Road B2
Roseville, Minnesota 55113

Mr. Steve Gadler
2120 Carter Avenue
St. Paul, Minnesota 55108

John W. Ferman, Ph.D.
Nuclear Engineer
Minnesota Pollution Control Agency
1935 W. County Road B2
Roseville, Minnesota 55113

Commissioner of Health
Minnesota Department of Health
717 Delaware Street, S. E.
Minneapolis, Minnesota 55440

Auditor
Wright County Board of
Commissioners
Buffalo, Minnesota 55313

U. S. Environmental Protection
Agency
Region V Office
Regional Radiation Representative
230 South Dearborn Street
Chicago, Illinois 60604

James G. Keppler
Regional Administrator
Region III Office
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

3.0 LIMITING CONDITIONS FOR OPERATION

3. From and after the date that two of the LPCI pumps or admission valves are made or found to be inoperable for any reason, reactor operation is permissible only during the succeeding seven days unless such pumps or admission valves are made operable sooner, provided that during such seven days all active components of both core spray systems, the containment cooling subsystem (including 2 LPCI pumps) and the diesel generators required for operation of such components (if no external source of power were available) shall be demonstrated to be operable at least once each day.
4. A maximum of one drywell spray loop (containment cooling mode of RHR) may be inoperable for 30 days when the reactor water temperature is greater than 212°F. If the loop is not returned to service within 30 days, the orderly shutdown of the reactor will be initiated and the reactor water temperature shall be reduced to less than 212°F.
5. Each LPCI subsystem (RHR) pump shall be capable of delivering 4,000 gpm $\pm 10\%$ against a system head corresponding to three pumps delivering 12,000 gpm at a reactor pressure of 20 psi above the suppression chamber pressure. If this rate of delivery requirement cannot be met, the pump shall be considered inoperable.

3.5/4.5

Amendment No. 27

4.0 SURVEILLANCE REQUIREMENTS

3. When it is determined that the LPCI subsystem is inoperable, both core spray systems, the containment cooling subsystem, and the diesel generators required for operation of such components (if no external source of power were available) shall be demonstrated to be operable immediately and daily thereafter.
4. During each five year period, an air test shall be performed on the drywell spray headers and nozzles.

105

B412120526 B41127
PDR ADDCK 05000263
PDR