

LICENSEE: COMMONWEALTH EDISON CO.
SITE: DRESDEN 3 EN NUMBER: 26907
DOCKET: 05000249 EVENT DATE: 03-09-94
RX TYPE: BWR EVENT TIME: 20:40
VENDORS: GE-3 NOTIFY DATE: 03-09-94
EMERGENCY CLASS: N/A REGION: 3 STATE: IL TIME: 21:42
OPS OFFICER: CHAUNCEY GOULD
10 CFR SECTION: ASHU 50.72(b)(1)(i)(A) PLANT S/D REQD BY TS
UNIT SCRAM RX INIT INITIAL MODE CURR CURRENT MODE
CODE CRIT PWR PWR
3 N Y 60 POWER OPERATION 60 POWER OPERATION

THE PLANT ENTERED TS REQUIRED S/D DUE TO HPCI BEING DECLARED
INOPERABLE BECAUSE OF CONCERNS WITH ISOLATION VALVES "2301-4" &
"2301-5".

THESE CONCERNS WERE DISCOVERED AS A RESULT OF TESTING CONDUCTED
BY EPRI ON THIS TYPE VALVE. THEY DETERMINED THAT IN A BLOWDOWN
CONDITION, THESE VALVES WOULD NOT FULLY CLOSE DUE TO FRICTION,
THEREFORE, NOT FULFILLING THEIR DESIGNATED FUNCTION. THE
CORRECTIVE ACTION TO BE TAKEN WILL BE TO MODIFY THESE VALVES
DURING SHUTDOWN. THE PLANT HAS TO BE IN COLD SHUTDOWN BY 3/10/94
@ 18:30. THE RI WAS INFORMED.

HOO NOTE: SEE EVENT# 26877