

LICENSEE: DUQUESNE LIGHT CO.
SITE: BEAVER VALLEY 1 2 EN NUMBER: 27741
DOCKET: 05000334 05000412 EVENT DATE: 09-01-94
RX TYPE: PWR PWR EVENT TIME: 12:00
VENDORS: W-3-LP W-3-LP NOTIFY DATE: 09-01-94
EMERGENCY CLASS: N/A REGION: 1 STATE: PA TIME: 14:54
OPS OFFICER: GREG SCARFO
10 CFR SECTION: CCCC 21.21 UNSPECIFIED PARAGRAPH
UNIT SCRAM RX INIT INITIAL MODE CURR CURRENT MODE
CODE CRIT PWR PWR
1 N Y 100 POWER OPERATION 100 POWER OPERATION
2 N Y 100 POWER OPERATION 100 POWER OPERATION

A FAULT WAS DISCOVERED IN THE SOLID-STATE PROTECTION SYSTEM (SSPS) TESTER.

THE SOLID-STATE PROTECTION SYSTEM (SSPS) SEMI-AUTOMATIC (S/A) TESTER /CLOCK-COUNTER CARD WAS FOUND TO BE DEFECTIVE WHILE TESTING TRAIN "B" OF THE SOLID STATE PROTECTION SYSTEM. CHANNEL "A" OF THE SSPS S/A TESTER DID NOT TEST ALL LOGIC COMBINATIONS IN THE UNIVERSAL LOGIC CARD OF THE SSPS. THIS COULD RESULT IN A FAILURE IN THE UNIVERSAL LOGIC CARD NOT BEING DETECTED BY THE TESTER. THE SSPS TESTER IS SUPPLIED BY WESTINGHOUSE ELECTRIC CORPORATION