# Draft Submittal (Pink Paper)

•

1. Written Exam Sample outlines

# **MCGUIRE EXAM**

# 50-369, 370/2002-301 FEBRUARY 11 - 15, 2002

# Copy 1 of 3

#### 

#### Form ES

Facility:	McGuire				Date	ofE	<u>cam:</u>	2/22/	02	E	xam L	evel:	RO	
				<u> </u>	/A Cat	egory	/ Poin	ts					Point	İ
Tier	Group	K 1	K 2	K 3	K 4	K 5	K   6	A 1	A 2	A 3	A 4	G *	Total	Target
1	1	2	1	4				2	5			2	16	16
Emergency &	2	4	2	5		<b>18</b>		2	2			2	17	17
Abnormal	3	0	1	0				0	1	ur is inn Guarra		1	3	3
Plant	Tier													
Evolutions	Totals	6	4	9				4	8			5	36	36
	1	4	2	4	3	1	2	0	4	1	1	1	23	23
2	2	1	0	3	2	2	0	3	3	1	2	3	20	20
Plant	3	0	1	0	1	0	1	0	3	1	1	0	8	8
Systems	Tier													2
	Totals	5	3	7	6	3	3	3	10	3	4	4	51	51
3	Generic K	nowle	dge a	nd	Cat	1	Cat	2	Cat	3	Cat	4	4	
	Abilities				4	_	3		3		3		13	13
Note: 1. 2. 3. 4 5 6	Ensure tha within eac two). The point specified i ±1 from th total 100 p Select top topics from . Systems / The shade	at at le h tier total f in the at spe ooints ics fre m a sy evolu ed are	east to (i.e., to for ea table acified om ma ystem tions as are As in	wo to the "1 . The d in the any s unle within a not Fiers	pics fr lier To oup ar final p ne tabl ystem ss the n each applic 1 and	om e tals" nd tien ooint t e bas s; avo y rela grou able t 2 sha	very K in eac r in the otal fo ed on oid se te to p p are to the so the	(/A ca th K/A e proporeac NRC lectin plant- ident categ	a categor categor posed h gro revision g mor specifi ified c jory/ti- ed fro	y are s gory s outili up an ions. re that fic pri- fic pri- on the er. m Sec	sampl shall n ne mu d tier The fin n two orities association 2	ed st ma may o nal ex or thr ciated 2 of th	less than tch that deviate by am must ree K/A l outline.	
7	• On the fol the topic's each syst plant spec	o, but lowin s impo em ar cific p	the to g pag ortanc nd cat rioriti	pics es, ei ce rat egory es. E	must t nter th ings fo /. K/A inter th	be rele be K/A for the s belo he Tie	evant numi RO lie ow 2.5 er tota	to the bers, a cense shou Is for	a brie a brie level ild be each	icable f desc , and justifi categ	evolu riptio the po ied on ory in	n of e bint to the b the T	or system. ach topic, itals for pasis of able	

.

					i l		1		- 1	
206	ī l	9.61.8.6	cherkesonds bre sseqrd enichu:neewjed eqirlanoldatenetral edit to agbeiwork sevles qrubb					30. <u>5</u>		000074 (W/E06&E07) Inad. Core Cooling / 4
deselected			qesejeceq							000069 (WE14) Loss of CTMT Integrity ( 5
506	<del>،</del> ا	6.617.6	qmuq referest bios chod rothom rothone elenedo of vilidA			61.I				8 Lossy Even Room
806		5.5/9.2	ageinst personnel exposure	3.10			_			900067 Plate On-eile / 9
			breug one notisiber to stevel evisceoxe eouber of serubeoorg rmothed of vitilida.					İ		
¥69	ŀ	7.E\ <b>2</b> .E	knowledge of the resears for the following responses Effect on the nuclear service water discharge flow header of a loss of CCW				3.04			000062 Loss of Nuclest Service Water / 4
		0.00.0	Beview 1.3V brie T2VV9 rollrom rolbne eteredo of villida		-	10.1				61, and that he Elec. Inst. Possible 20000
725										
906	ī	7.6/6.6	bettery discharge rates on capacity						r0.r	000055 Station Blackout / 6
			Knowledge of the operational implications of the following concepts Effect of							
1.634	L	1.14/6.5	of the solution of the solutio		20.S					4 muuseY teenebroo to see Losooo
		0.011.0	sublicuts				3,3	┝──		ME08 BCS Overcooling - PTS / 4
668		8 C/2 C	knowiedge for the reasons for the following responsesmanipulsion of controls inequalitied to obtain destined operating results during an on-the provided to obtain destined operations.							
283	L	£.4/8.4	qht robser a phhiuper anoitibricoterqrefni bna enimistab ot yilidA		2.02					000040 (W/E12) Steam Line Rupture - Excessive Heat
	1						÷.,	1		<ul> <li>The second se</li></ul>
			ອະນຸດອາມາດດ້ວຍດາ ສະບຸດສາມາດດ ສິນເສຍ ແມ່ນດອກ ແລະ	6272	_				÷.	000026 Loss of Component Cooling Water / 8
968	Ľ	8.6/3.8	Endificants for endificants polyionis show on using a							
181	1	4.2/4.4					3.02	Γ	Γ	000024 Emergency Boration / 1
			COP in beniations actions and account of the following the sources actions contained in EOP							
								iri i		er son for the standard
									· ·	
028	Ļ	2.6\4.6	enuterequet votate rigid no eCDF enuces of nertw…Jengetori brie enimiete of vilidA		60.S					AnoltanutiaM 938 Stittenne
698	ŀ	1 W/E E	Knowiedge of the operational implications of the following concepts as they apply to the…celculation of minimum structown margin		Γ	Ī			90.1	000005 Inoperable/Stuck Control Rod /1
noiteeuQ	Points	,qmi	(s)okoT A/M	อ	Ŷ	¥	3 K	s K	Ь.	E/APE # / Name / Safety Function
										100-S3

K/A Category Totale

9 Vivita Analoo Totase Regin 870000

to t⊺≉∃qA∃

Group Point Total:

S.5.7.5 male as goleron of their third account or process point that is causing an element of Alikida

9L

01

McGuire Sample Plan

	Ļ	17	2 Oreus Point Total	•	<u> </u>	-			K/A Category Totals:
884		2.9/3,1	Knowledge for the teasors indicate conditionary descriptions and characteristics during transient conditions, including codent chemistry and the effects of temperature, pressure, and reactivity changes and operating limitations and			μ -			
398	_	3.6/3.6	Ability to operate and/or monitorautomatic actuation		<u>10</u>	<u> </u>			000061 ARM System Alarma / 7
deselected			deselected at random			∔			000060 Accidental Gaseous Radwasta Rel. / 9
deselected			deselected at random	┣ ─	_	<u> </u>			000059 Accidental Liquid Radwasta Rel. / 9
904		4.0/4.2	Knowledge of the reasons for the following responsesscitions contained in EOP for loss of dc power		┨───	1.02			000058 Loss of DC Power / 6
deselected			desséedad at random						000054 Loss of Main Feedwater / 4
321		3.2/3.5	Knowledge of the operational implications of the following concepts as they apply to the leak rate vs. pressure drop					1.02	nnon's steam Canerator Tube Rupture / 3
deselected			deselected at random						000037 Steam Generator Tube Leak / 3
37.1		2.7/3.0	Knowledge of the operational implications of the following concepts as they apply to the Effects of voltage changes on performance					1.01	000033 Loss of Informediate Range NI / 7
903		2.5/3.1	Knowledge of the operational implications of the following concepts as they apply to the Effects of voltage changes on performance	<u> </u>		<b> </b>		1.01	000032 Loss of Source Range NI / 7
						· .			
710.1	<u></u>	3.7/4.4	Ability to evaluate plant performance and make operational jucyments based on operating characteristics, reactor behavior and instrument 7 Interpretation	; 					000025 Loss of RHR System / 4
857		2,9/3.8	Ability to determine and interprethow long pressurtzer level can be maintained within limits	12	2		┣	<u> </u>	100022 Loss of Reactor Coolant Makeup / 2
deselected			deselected at random			┨──		ļ	WE01&02 Rediagnosis and St Termination / 3
571	_ <b>_</b>	3.6/4.0	Knowledge of the internetationships between components and runctions of control and safety systems including instrumentation, signals, interfocts, failure modes, and automatic and manual features				2.1		viE03 LOCA Cooldown - Depress. / 4
359.2	-	3.6/3.8	Knowledge for the reasons for the following responsesRO or SRO function within the control norm team as appropriate to the sealpined position in such as way that procedures are adhered to and the limitations in the facilities license and amendments are not violated		┣───		(a)		VIE04 LOCA Outside Containment / 3
<b>38</b> 7		3.5*/3.6*	Knowledge of the reasons for the following responses Stopping charging gump bypass flow		├──	17	3.	ļ	00011 Large Break LOCA / 3
leselected			deselected at random					<b> </b>	00009 Small Break LOCA / 3
99	<u>_</u>	.0/4.2	Ability to operate and/or monitor researing of code safety and PORV		×	1	-		00008 Pressurizer Vapor Space Accident / 3
₽ <b>₽</b>		.6/2.8	Knowledge of the internelationships betweenbreakers, relays and disconnects				02	2	00007 Reactor Trip - Stabilization - Recovery / 1
eselected			deselected at random			<u> </u>			00003 Dropped Control Rod / 1
113		.9/3.2	Knowledge of the operational implications of the following concepts as they apply to theIntegral rod worth		┨			21	00001 Continuous Rod Withdrawal / 1
Question	Points	тр П	K/A Topic(e)	0	NX		ωz	-	APE # / Name / Safety Function
Benk									

For Official Use Only Until After 2/22/02

EAPEs T1 G2

12/10/01

Copý 1 of 3

.

Υ...

Tanta a Maria Codes. Envedor	¥	×	×	<	ļ		KA Topic(a)	ŭ	Points	Question
		~	m	÷	NI 8	2 2	illity to determine and interpretPressurizar level as a function of power level T.ea. Industrian intermediation of mathinction	3.4/3.8	÷	902
000028 Preserviter Level Matunction / z			1	<u> </u>	s.	<u>5                                    </u>				deselected
00035 Fuel Handling Accident, F				: :	-					
000065 Loss of Instrument Air / 8	, ,					- 2	ndomly deselected			deselected
W/E 13 Steam Generator Over-pressure / 4						2	ndomly deselected			deselected
W/F 15 Containment Flooding / 5		52				X :E 5 &	rowiedge of the internelationships betweenfacility's heat removel systems, cluding primary coolant, emergency coolant, decay heat removal systems, and attains between the proper operation of these systems to the operation of the clifty	2.7/2.9		891
					·					
				l	<u> </u>	<u> </u>				
	1			†	<b> </b>					
								_		
irit fotonor Totale.	°	Ē	Ľ	°	-	F		¥	7	

For Official Use Only Until After 2/22/02

EAPEs T1 G3

.

ES-401					P	WR .	RO E	xemi	nation	Outl	ne		Form	ES-401-3	Bank
		-			- 1	Nant -	Sysie	m# - 1	ier 2	G <u>roup</u> T	<u>) 1</u>				Outer
System # / Name	K 1	ĸ	2 K 3	К	K 5	к	A 1	A 2	A 3	A 4	G	K/A Topic(e)	imp.	Points	Question
001 Control Rod Drive									3.08			Ability to monitor automatic operation of theAnticipation of criticality at any time when adding positive reactivity	3.9/4.0	1	866
AND December Compart Rump		Γ			Τ	8 1/						Knowledge of the effect that a loss or malfunction will have on Staring requirements	2.6/2.9	1	867
003 Reactor Coolant Pump	+		╈	1	$\square$						1				
004 Chemical Volume Control		2.0	6									Knowledge of bus power supplies tocontrol instrumentation	2.6*/2.7	1	885
	Γ		Τ									Ability to predict the impacts of the following maifunction or operationand based on those predictions, use procedures to correct, control or mitigate the consequences of I OCA	4.6/4.8	1	540
013 Engineered Safety Features Actuation		+-	+-	+	┢		╈	2.0	╢──	┼──	-				
014 Rod Position Indication	1.0	2										Knowledge of physical connections and/or cause and effect relationshipsNIS	3.0/3.3		893.1
				4.0								Knowledge of design feature(s) and/or interlock(s) which provide forSource- range detector shutoff at high powers		1	878
	1	1			T					T		Knowledge of the effect that a loss or malfunctionwill have onNatural circulation indications	3.5*/3.7*	1	911
017 In-core Temperature Monitor		╀─		╨	╀─	+	┼──	╋	+	╋	+				l .
				1						Í.		A Menutodae of the bases for originitizing safety functions during abnormal / eme	3.0/4.0	۱ ا	858
022 Containment Cooling	+	+	+		┢	┢	╞	t	┢	1	4.2	Ability to predict the impacts of the following malfunction or operationand based on those predictions, use procedures to correct, control or mitigate the			
025 ice Condenser		<u> </u>		<b>_</b>		_	1	2.0	2	<b>_</b>		consequences of High/low floor cooling temperature	2.772.5	<u>├</u>	081
026 Containment Sprav			3.0	2								Knowledge of the effect that a loss or maifunctionwill have onRecirculation spray system	4.2*#4.3	<u> </u>	102
			T		Τ						I	Knowledge of physical connections and/or cause and effect relationshipsMFW	2.6*/2.6	1	41 <u>5.1</u>
056 Condensate	1.0	3	+-	┢	1	$\uparrow$	1	┢		1-	t	Knowledge of physical connections and/or cause and effect	2 1/2 2		014 1
059 Main Feedwater	1.0	3		_	┢	-	+	+-	+	+	+	relationshipsS/G3	3, 1/0.0		014.4
													A 246.4	{ .	101.1
061 Auxillary/Emergency Feedwater	+	+	3.0	2	+-	+	-	_	┢	+	+	Knowledge of the effect that a loss of mainarchionwill have onoro	9.219.7		10117
063 DC Electrical										4.0	3	Ability to manually operate and/or monitor in the control roomBattery discharge rate	3.0*/3.1	ļ	881
			Τ			Τ	Γ					Ability to manually operate and/or monitor in the control roomStoppege of release if limits are exceeded	3.9/3.8		407
068 Liquid Rad Waste	+-	+	-†-	╉─	╉	┿	╉	+-	╉		┭				
071 Waste Gas Disposal	1.0	6										Knowledge of physical connections and/or cause and effect relationships ARM and PRM systems	3.1*/3.1	<sup>1</sup>	771.1
		T			Γ			20				Ability to predict the impacts of the following malfunction or operationand based on those predictions, use procedures to correct, control or mitigate the consequences ofDetector failure	2.8/2.9		860
072 Area Radiation Monitoring	+	-1-	+	+-	┿	+	╈	1	1	$\uparrow$	1			1	
022 Containment Cooling		2.9	01						$\perp$			Knowledge of bus power supplies to containment cooling fans	3.0*/3.1		1 698
								24				Ability to manually operate and/or monitor in the control roomLoss of condensate pumps	2.6/2.8*		1 649.1
056 Condensate		╡	2	3	1	0	1	0	4	1	2	1 Group Point Tota	11	1	9
INA Category rotain:	_		-				_								

						l		l	l						
															:
System # / Name	X 1	Ê	ŵ	Ē	L <u>ê</u>	ê	Æ	Í.	l.	-	Ļ	K/A Topic(a)	â	Pointa	Question
102 Reactor Coolant					ļļ		N	8		<u> </u>	0 7 8	Sitity to predict the impacts of the following mailfunction or operationand need on those predictions, use procedures to correct, control or mitigate the meequences ofLoss of coolernt pressure 4	1.2/4.4	<u> </u>	173
nat Emanancy Core Cooline											3 4 12 X	cowledge of radiation exposure limits and contamination control, including missible levels in excess of those authorized	2.5/3.1	<u> </u>	<u>8</u>
nan Pressuiden Pressure Control			_	9							2 2	nowledge of design feature(s) and/or interlock(s) which provide for Spray live wam-up	2.7/2.9		376
n4 Brassurizar Laval Control					8		_				a <b>T</b>	rowiedge of the following operational implicationsIndicated charging flow: as flow plus actual charging flow	2.9/3.2	-	377
113 Descion Brokention					<u> </u>						-	nowledge of the following operational implications DNB	3.3/3.8		<sup>55</sup>
014 Rod Position Indication	1.02										<del>.</del>	nowledge of physical connections end/or cause and effect relationshipsNIS	3.0/3.3	<u> - </u>	393.1
															• .
	ļ		3									nowledge of the affect that a loas or maifunction will have on Recirculation prevention	4.2*/4.3		963 2
199 Containment Purce							_	_				nowledge of the effect that a loss or maifunction	lara.at	-	444.4
	سريد													:	•
							5					billy to predict and/or monitor changes in parameters (to prevent exceeding seign limita) associated with operating theS/G wide and narrow range level uring start up, shut down and normal operation	3.6/3.8	<u> .</u>	400
		ľ.													
			3									nowledge of the effect that a loss or malifunctionwill have onMain ondenses	2.5/2.7		547
02 AC Electrical Distribution				4.05								nowledge of design fasture(s) and/or interlock(s) which provide forperaileding f AC sources (synchroscope)	2.7*13.2	<u> </u>	880
									•	8		willy to manually operate and/or monitor in the control roomBettery ischarge rate	3.0*/3.1	_	841
os, br. Electron 054 Emergency Diesel Generator							1. 86					Usity to predict and/or monitor changes in parameters (to prevent exceeding early finite) associated with operating the Maintaining minimum load on the DVG (to prevent reverse power)	3,1/3.4	_	748.1
		5													
								2.01				While to predict the impacts of the following mailfunction or operation and seed on these predictions, use procedures to correct, control or mitigate the consequences of Cross connection with IAS	2.9/3.2	1	900
or a succorright											4.12	knowledge of general crew operating responsibilities during emergency perations	3,4/3.9		460
	t	I	Ι	J	Ţ								3		 、

SYSTEMs T2 G2

K/A Category Totals

0 3 2

For Official Use Only Until After 2/22/02

e
5
Ξ.
18
ŏ

System # / Name	ž I	2 K	3 K	¥	¥ N	<	<b>A</b> 2	A 3	• •	0	K/A Topic(a)			Guestion	-
Restonel Heet Removal							2.02	i.		< 0 0	Usity to pradict the impacts of the following mailtunction or operationand based in these predictions, use procedures to corned, control or mitigate the consequences of Pressure transferit protection during cold shupdown 3.50;	3.7		37.1	
n Anna Anna Anna Anna Anna Anna Anna An			į.	;	:			Ċ							
Commonset Condina Water											andomly deserviced	$\neg$	0	eselected	
	<u> </u> -					<u> </u>				<u> </u>	andomly deselected		8	eselected	
						<u> </u>	<b> </b>			<u> </u>	rowiedge of the effect that a loss or mailtunction will have on Hydrogen ecombines	5.5	4	67.1	
Hydrogen recombiner and rulys control	+	+	╉──	+	5 	<u> </u>	201				Ability to predict the impacts of the tokowing methurchion or operationand besed on those predictions, use procedures to correct, control or miligate the consequences ofDropped fuel element	4.4		37.1	
					-	<u> </u>					andomly deserved			lesefected	
	$\mathbf{t}$	1	-						1 03		Addity to menuality operate and/or monitor in the control roomT/G controls 	R.6"		1	_
Main Turbine Generator	÷.			1.						Ŧ					
			<b>•</b>	5				_			$k$ toowadge of design feature(a) and/or interfoot(a) which provide forMenuel / $\frac{2.7}{2.7}$	6.2		83	
Instrument Art				1	<del>                                      </del>						Ability to predict the Impacts of the following mailfundion of operationand based on those products use in procedures to correct, correct or misgate the construences ofContainment execution (including recognition of alem) 3.5.	*/3.6*	Ŧ	358.1	1
Containment	1.	╉┮	┝	┢╸	┞╺	┨╼		Ľ	Ľ	ſ	Group Point Total:	-	-		
. Category 1 otals:				1		=	물	뢼	뛽	I		$\left  \right $			
Svetem / Toolc			Reco		ped P	teplac	ement	ğ			Reason Reaconterior and the state of MARY to	2	Į-		
Sistem Generation					035	20.24					0355, 25, was replaced by a part restrict priority are segment or with the model the impact of the fullowing mathemation or operation. Fand these of modes predictions, use proceedures to correct, control or majors the SIG level mape used to control truthme per (4,4,4,4,1). The plant recently changed the SIG level mape used to control truthme that the applicants had matematic the impact of the drange uppediction to ensure that the applicants had matematic the impact of the drange on plant operations. Replaced with (KI 055A1 (01 'Aubity) to predict and to control program the restruction of many and the impact of and to control program to there are accessing delayin finitely associated with operations the area accessing the storic during statutus, shufdown and normal operations (2,43,43, wide and narrow range development) and the operations.	6 6 6 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7			
078 Bistion Air	·			ž	9	Ě.	Ξ				KN. O'PAS.01 Ability to predict the impacts of the fallowing meMunction or operation. based on those predictions, use procedures to controt, control of militians the consequ- ofControl with M.S. This is considered to be a paint specific priority due control change in the system line up procedure. This was also randomly selected and require a replecement.	and braine brai braine braine braine braine braine braine braine braine braine	-		
			1									+	Τ		
												╉			
		1								Τ		╀	Γ		
	_														

SYSTEMs T2 G3

٠

й					
-1* -	است محمد با م	syngen gegenen generation of the state of			
			_		
Category	K/A#	Торіс	lmp.	Points	Question
	والمحمو محاصرت والاسميو	and a strange of the second second second second second second second second second second second second second			
			3 1/3 2	1	143.
	2.1.21	Ability to perform specific system and integrated plant procedures during all modes			
Conduct of	2.1.23	of operation	3.9/4.0	1	331.
Operations	2 1.31	Ability to locate switches, controls and indications and to determine if they are correctly reflecting the desired plant lineup	4.2/3.9	1	164.
operations					
			L		
			4	4	
		(multi unit) Ability to explain the variation in control board layouts, systems,	2.8/3.0*	1	260.
	2.2.4				
	2.2.33	Knowledge of rod control programming	2.5/2.9	1	563.
Faultanent					
Equipment	t with the second second second second second second second second second second second second second second s				
Control					
			<u> </u>		ļ
			3	3	
				<b></b>	
			a fact server they	- aldrer I. e. e. Meland	
	2.3.2	Knowledge of facility ALARA program	2.5/2.9	1	12
		Knowledge of radiation exposure limits and contamination control including			702
Radiation	2.3.4	permissible levels in excess of those authorized	2.5/3.1	╞╌───	703.
Control					
					1
				<u> </u>	
			3		3
		V-aviadae of fire protection procedures	2.9/3.4		1 9
	2.4.25	Knowledge of facility protection requirements including fire brigade and portable fire	B		1 8
	2.4.26	fighting equipment usage	2.9/3.3		
Emergency	6 . M. S	and the second of the second second second second second second second second second second second second second			1
Broaduree					<u> </u>
Fracedures				ļ	ļ
and Plan					
					┨────
				3	3
		Tier 3 Point Tot	al <u>1</u>	3 1	<u> </u>

Copy 1 of 3

#### ..... Exam Level: SRO Date of Exam: 2/22/02 Facility: McGuire Point K/A Category Points Α A A G κ Α κ κ κ κ κ Group Tier Target \* Total Emergency & Abnormal Tier Plant **Evolutions** Totals Plant Systems Tier Totals Cat 3 Cat 4 Cat 2 Cat 1 Generic Knowledge and Abilities Note: 1. Ensure that at least two topics from every K/A category are sampled Totals within each tier (i.e., the "Tier Totals" in each K/A category shall not be less than 2. The point total for each group and tier in the proposed outline must match that 3. Select topics from many systems; avoid selecting more than two or three K/A topics from a system unless they relate to plant-specific priorities. 4. Systems /evolutions within each group are identified on the associated outline. 5. The shaded areas are not applicable to the category/tier. 6. The generic K/As in Tiers 1 and 2 shall be selected from Section 2 of the K/A Catalogue, but the topics must be relevant to the applicable evolution or system. <sup>7.</sup> On the following pages, enter the K/A numbers, a brief description of each topic, the topic's importance ratings for the SRO license level, and the point totals for each system and category. K/As below 2.5 should be justified on the basis of plant specific priorities. Enter the Tier totals for each category in the Table above.

Copy 1 of 3

AcGuire Sample Plan

K/A Category Totals		000078 High Reactor Coolent Activity / 9	00074 (W/E0e&E07) Inad. Core Cooling / 4		000068 Control Room Evac. / 8	000067 Plant Fire On-ette / 9	000002 Loss of Nuclear Service Water / 4		000017 Loss of Vitel An Fien Inst. Bus. / B		nonnst I nes of Condenser Vacuum / 4	WEAR BCS Overcooling - PTS / 4	000040 (W/E12) Steam Line Rupture - Excessive Heat Transfer / 4	000028 Loss of Component Cooling Water / 8	000024 Emergency Boration / 1	UUVV1371 / AV-T millioningsonia ra			w/mA4 i DCA (putalda Containment/ 3	000011 Large Break LOCA / 3		00001 Continuous Rod Withdrawal / 1	E/APE # / Name / Safety Function	and the second se
3																. <u>\$</u> .		. :				.21	2 K	
-			2.06	1			3					ω			3.0				3	3.0			2 K 3	
•					1		4		5			ω			Ñ			2	*	7			8 A 1	
2	;	2.0			÷			4 4 8	-		2.02		2.02				2.09						A 2	i
Ê	:	-				<u>د</u> ب								2.23		·							G	
2 Group Point Total		Ability to determine and interpret location or process point that is causing an alarm	Knowledge of the internetationahips betweenturbine bypass and stmospheric dump valves		Ability to operate and/or monitor borto acid transfer pump	Ability to perform procedures to reduce excessive tevels of radiation and guard patient personnel exposure	Knowledge of the reasons for the following responses Effect on the nuclear service water discharge flow header of a loss of CCW		Ability to operate and/or monitor RWST and VCT valves	Knowledge of the operational implications of the following concepts Effect of battery discharge rates on capacity	Ability to determine and interpretconditions requiring a reactor and/or turbine trip	Knowledge for the reasons for the following responsesmanipulation of controls required to obtain desired operating results during abnormal and emergency situations	Ability to determine and interpretconditions requiring a reactor trip	Ability to track limiting conditions for operations	Knowledge of the reasons for the following responsessctions contained in EOP for emergency borstion		Ability to determine and interpretwhen to secure RCPs on high stator temperature		Knowledge for the reasons for the following responsesRO or SRO function within the control room team as appropriate to the assigned position in such as way that procedures are achieved to and the limitations in the facilities license and amendments are not volsited.	Knowledge of the reasons for the following responsesStopping charging pump bypass flow		Knowledge of the openational implications of the following concepts as they apply to the Integral rod worth	KIA Topic(a)	
Ĩ		2.7/3.2	3.5*/3.6		3.7/3.9	2.9/3.3	3.5/3.7		3.5/3.6	3.3/3.7	3,9/4.1	3.7/3.8	4.6/4.7	2.6/3.8	4.214.4		3.4/3.5		3.6/3.8	3.5*/3.6*		2.9/3.2	Imp.	
Ĩ																	_		_	_		<b>_</b>	Points	
24		1 380	1 907		1 905	1 908	1 894		1 874	1906	1 453.1	1 888	593	896	181		870		359.2	387		913	Question	

EAPEs T1 G1

For Official Use Only Until After 2/22/02

91. 1	91	91		2	7	2	£	2	E	ICA Category Totals
			letoT toto 9 augro Poine Total					r 1		8 \ 11A Inemittani to aso.1 250000
hetreleaseb			E-11-11 - E (11-1E)					1		
<del>1</del> 89	<del>ار</del> م	5.9/3.1	bre anotialmit				3.10	I I		9 Note the Containment Redistion / 9
			the effects of temperature, presente, and reactivity changes and operating						1	
			Knowledge for the rescars for the month of any statement of adding the source of the statement of the statem					1		
000		0.6.0.5	notection of the standard of the standard activity of the standard of the stan			10.1				T i annelA metey2 MSIA 180000
308	ľ	80180						! I		
								┟──┨		
deselected			mobrer te betoeleeeb							91. Ing atzewing augenen Bietrobiere anonen
							20°E		_	000058 Loss of DC Power / 6
106	ĩ	2.4/0.4	In EQ2 for loss of de ressons for the rower gradients				<b>1</b>	1		
			badistrico anothe associate pairwill offices							
								· ·		
			1						-	and the second second second second second second second second second second second second second second second
			ng the state of th							1
										-
									70'1	
351	h j	3.2/3.5	apply to the						CU 1	f ) and and a diversion of the second
'			Verti se sideondo privolioj erit to ancitanigmi (agotterano erit to ancieturo).		Į –		Į.			
			and the second second second second second second second second second second second second second second second	ф	. ***	к ( т				The second second second second second second second second second second second second second second second s
1.78	Ti Ti	0.517.5	apply to the Effects of voltage changes on performance		T		T		ro.r	V IN egnast etsibernetini to secial Conge
			Knowledge of the operational implications of the following concepts as they							
				Ļ	<u> </u>	I	<b>_</b>		1011	1 ( IN ABURN ADDOR 10 \$507 750000
£06	L.	1.5/8.5	apply to the			l			101	Z / IN sound sound by see 1 (see see
			vert as steepen involue of the following of the topology and to experiment							
			and the second second second second second second second second second second second second second second second			-	1	5 35 44 F		
										· · · · · · · · · · · · · · · · · · ·
1.012		**//`S	កលវ័ងមាបុទរាក	1.1		Τ				000025 Loss of RHR System / 4
	ľ		finemuteri bra roivariera reactor behavior and instrument	l I						
1		1	shirity to evaluate plant performance and make operational judgments	1						
158	i i	8°£/6'Z	simit nittiw benlatnian	1	140.S		1			S / Directed Inside Contrast Of and Loging
			ed nso level technication processory for the processory of while a				1			
	<u> </u>					1				
							, <b>-</b>			ANERS FOCK COOLOGUU - Debugget -
129	r	0.4/9.0	eiture modes, and automatic and manual features	ł	1			1.5		• • • • • • • • • • • • • • • • • • •
		Í	Crowledge of the interestions including instrumentation, submitting interforms, interfo	1			1	1		
		L		<u>,</u>	-	+	+	+	<b></b>	000000 Small Break LOCA / 3
betoeleset	1			1	1	1		1		
1	1								L	
68	1	Z'#/0'1	VROP bits select monitor monitor measure of code safety and PORV	/	T	201	·			000008 Presentizer Vapor Space Accident / 3
	T				1					l · · · · · · · · · · · · · · · · · · ·
		1			╋┯	_	┢	170-		LI ( AIRAODEN - HODEZINGING - CULL JOIDEEN /00000
104	1	0.540.0	ערסאנונאסנוג ערסאנונאלים פין לוא ונופוניםאנוסטופעולים המאפפעוייייסטאנעפערי נפולא פרעי	2		1	1	1000		Planaad - adia-marta
	1		has make statend, cannot evidential additional addition	1	1	1		1		
<b>—</b> —		<u> </u>	(-)	1_	1, .	1	1.		1. 2	EVER & / NEW / Steps / Puccou
Cuestion 0	strilog	, dmi	(a)olooT A\N	Ű	1.	<u> </u>	1.	6 7	Ľ	
yueg										constant as an an an an an an an an an an an an an

Copy	
-	
đ	.`
ω	

.

	l									
and the second se						ĺ				Bank
E/APE # / Name / Safety Function	→ <b>⊼</b>	~ 7	ωΧ	- '		-	K/A Topic(s)	ġ	Points	Question
nnnore Pressurizer ( evel Malfunction / 2		-		N)	8	৭≥	bility to determine and interpretPressurtzer level as a function of power level r T-ave. including interpretation of mait/unction	.4/3.8	_	902
						;				depelected
000035 Fuel Hendling Accident / 8										
The second second second second second second second second second second second second second second second se	_	_	_	_		_				
W/E 13 Steam Generator Over-pressure / 4					-	3	andomly deselected			deselected
		ა ა				3355	nowledge of the interrelationships betweenfacility's heat removal systems, including primary coclant, emergency coolant, decay heat removal systems, and lations between the proper operation of these systems to the operation of the vality.	. 7/2.9	<u> </u>	891
THE IS COMMINSING COMMINSION										
										-
									ł	
		$\rightarrow$		$ \rightarrow $	<u> </u>					
							A Daliet Test			

EAPEs T1 G3

KIA Category

For Official Use Only Until After 2/22/02

8-401 7 ml					ः  }}	ីខ្មែរ ភាពទំ	() 37 51 ()	tola. Testi	don ( ar 2 G	utiin Ale roup			Bank
System # / Name	к 1	К 2	K 3	к 4	K 5	К 6	A 1	A 2	A 3	A 4	G	K/A Topic(s) Imp. Points (	Question
101 Control Rod Drive									3.08			Ability to monitor automatic operation of theAnticipation of criticality at any time when adding positive reactivity 3.9/4.0 18	66
												Knowledge of design feature(a) and/or interpol(d) which provide for a first and a state of the s	03 2
						6 14	-					Knowledge of the effect that a loss or malfunction will have onStaring requirements 2.6/2.9 1.84	67
	語を				l le							Structure of the effect that a case or mail under the full have only Signature (1993)	(a. 24) 15.1 <sup>-344</sup>
103 Reactor Coolant Pump					「「「「」」				34	調査		Knowledge of the effect that a loss or maturation will have onPumper 2.8/3.1 16	13
04 Chemical Volume Control	. /	2.06	2.11-198		1, escato	0.04	- Marine - Contraction - Contr				<i></i>	Knowledge of bus power supplies tocontrol instrumentation 2.61/2.7 18	85
104 Chemical Volume Control		2.00	<u> </u>					2.01				Ability to predict the impacts of the following malfunction or operationand based on those predictions, use procedures to correct, control or mitigate the consequences ofLOCA 4.6/4.8 15	40
		淵影										Knowledge of design feature(a) and/or intercet (a) which provide for	48 M
115 Nuclear Instrumentation		Γ		4.01								Knowledge of design featura(s) and/or interlock(s) which provide for Source- range detector shutoff at high powers 3.1/3.3 1 8	78
Dis Nuclear Instrumentation	4*:	594e	3.03									Knowledge of the effect that a lose or majfunction	197
017 in-core Temperature Monitor			3.01									Knowledge of the effect that a loss or malfunctionwill have onNatural circulation indications 3.5*/3.7* 19	911
022 Containment Cooling											4.22	Knowledge of the bases for prioritizing safety functions during abnormal / 2 emergency operations 3.0/4.0 18	358
122 Containment Cooling		2.01										Knowledge of bus power supplies to containment cooling fans 3.0*/3.1 1	<b>898</b>
		Γ						2.02				Ability to predict the impacts of the following malfunction or operationend based on those predictions, use procedures to correct, control or mitigate the consequences ofHigh/low floor cooling temperature 2.7*/2.5* 1)	681
	1.03	1										Knowledge of physical connections and/or cause and effect relationshipsMFW 2.6*/2.6 14	415.1
056 Condensate								2.04				Ability to manually operate and/or monitor in the control roomLoss of condensate pumps 2.6/2.8* 1	649.1
		Γ										Knowledge of physical connections and/or cause and effect	914.1
059 Mein Feedwater												Knowledge of physical connections and/or cause and anectors and anectors of physical connections and/or cause and anectors of the second structure and anectors	890 <sup>1494</sup>
004 Auvilianu/Emergency Feedwater			3.0	2								Knowledge of the effect that a loss or malfunctionwill have onS/G 4.2/4.4 1	191.1
64 Auxiliar/Emergancy Feedwater				<b>新</b> 新	· 通道 5.0							Control valve is shut	59994 158
065 Liquid Rad Waste										4.03	<u>_</u>	Ability to manually operate and/or monitor in the control roomStoppage of release if limits are exceeded 3.9/3.8 1	407
071 Waste Gas Disposal	1.0	6										Knowledge of physical connections and/or cause and effect relationshipsARM and PRM systems 3.1*/3.1 1	771.1
072 Ares Radiation Monitoring								2.0	2			Ability to predict the impacts of the following mainunction or operationand based on those predictions, use procedures to correct, control or mitigate the consequences ofDetector failure 2.8/2.9 1	860
K/A Category Totals:		4	2	4	3	1	2	0		1	1	1 Group Point Total: 23 23	

.

and a state of the												
System # / Name	K 1 K	2 K 3	K 4	K 5	K 6 X	4	2 4 3	* *	0	K/A Topic(s) Imp.	Points	Question
000 Baserine Contant						2.0	~		~#0	Ability to predict the impacts of the following mathemation or operationand based on these participants, use previously to entred; control or mitigate the consequences of Itses of occent pressure	-	848
004 Frankinancy Conta Cooling									34	Knowłedge of radiation exposure imita and contamination control, including permissible levels in excess of those subhorized		861
	┣	<u> </u>	6							Krowładge of design heaturals) andior interlock(s) which provide forSprey 2.772.9 waw werm-up		876
		<u> </u>		8.5		<u> </u>	<b> </b>			knowledge of the tollowing operational implicationsIndicated cherging flow: seal flow plus schart charging flow		877
	-	<u> </u>		5.01	$\vdash$	<b> </b>	<b> </b>			Knowledge of the following operationel Implications DNB		4
012 MARCON PTOTACION				20	-		<b> </b>			randomly deselected		deselected
		╂—					<u> </u>			innoimty censelected		deselected
	-	-	<b>_</b>		5		<u>                                     </u>			knowledge of the effect that a loss or maihunction will have on Hydrogen 2.6/3.1 recombiners		787.
028 Hydrogen Recombiner and Furge Convol	┼─	<u></u>	<u> </u>		3		<u> </u>		<u> </u>	knowkedge of the effect that a loss or meltiunctionwill have onContrainment even		432.1
029 Containment Purge		n	-			+		ļ				deselected
033 Spent Fuel Pool Cooling		-		1		<u> </u>				Ability to predict the impacts of the following malfunction or operationand based on those predictions, use proceedures to correct, control or mitigate the conservences of Discroped fuel element		137.
034 Fuel Hendling Equipment			<b> </b>	<u> </u>		1 - 2	<u></u>			Ability to predict and/or montor changes in parameters (to prevent exceeding design limits) secondated with operating theS/G wide and namow range level chrine start up. shat down and normal coveribon		400
035 Steam Generator									• •			
	1									Knowledge of the effect that a loss or mailfunctionwill have onMain 2.5727 condenser		1 547
		–	4							Knowłedge of design festure(s) and/or interfock(s) which provide for peraiteling of AC sources (synchroscope)		880
				<u> </u>		8				Ability to predict and/or monitor changes in parameters (to prevent exceeding design limits) associated with operating theMaintaining minimum load on the EDIG (to prevent revente power) 3.1/3.4		1 748.1
use Eliter gand, Dreed Service Lor		L.	- 10 I									
										rendomity deselected	_	deselecto
075 Circulating Water			┣──	<u> </u>		<u> </u>		<b> </b>		Ability to predict the impacts of the following melkunction or operation and based on those predictions, use procedures to correct, control or mitigate the consequences of Cross connection with IAS		8
		┢──	┞──						4	Convietige of general crew operating responsibilities during emergency convirtions		460
086 Fire Protection		+		+		<u> </u>			ŕ	Ability to predict the impacts of the following mailfunction or operationand Ability to prediction use proceeding to control or middle the bread on those of Provisionment association (including recognition of algem) 3 573.		1 855
103 Containment KVA Category Totals:	-		N		۲ آ		ŢŦ	-	Ĩ	Group Point Total:	÷	

For Official Use Only Untit After 2/22/02

SYSTEMs T2 G2

copy 1 of 3

.

System 14 Name	K 1 K 2	¥.	X 4	K 5	K 8 /	<b>×</b>	2 4	4 V 0	0	K/A Topic(s)	Points	CONSTICU	_
						<u> </u>				Ability to predict the impacts of the following maltunction or operationand based on those predictions, use proceedings to compare immigate the consequences of Pressure transient principic during odd shittbown 3.55.7	1	837.1	
005 Keaduai Hart Kemovai Se						à							
Breat and a state of a set of the second frame							-					deselected	
006 Component Cooling Water 041 Steam Dumb/Turbine Bypess Control							┨──┥			andomy developed		deselected	
nais Hain Jurbine Generator	-							4.02		Ability to manually operate and/or monitor in the control roomTVG controls 2.7/2.8* including treaters		11	.,
076 Service Water					_					randomly deedected		deselected	
178 (netrument Åk			4.01							Knowledge of design feature(s) and/or interfock(s) which provide forMenuel / 2.7/2.9. automatic transfers of control		683	- to
K/A Catagory Totals:	0	ľ	-	°	-	-	F	Ļ	°	Group Point 10481: 4			-
						lant &	peche	Prior	ş		admine		
System / Topkc		ž	tumo(	bebre	Repl	Ceme	tt for			Reason Reason Reason Reason River and River Related Ability for	-		
015 Staim Generator				6	5A2.0	~				Ciondo 2. Cover an engloyed on 1 and reporting interval or or operation. and based on those predictions, use proceedures to correct, control or mitigates the consequences of reschor trip function or or pregiot the SIG level may and on those predictions, use proceedures to correct, control or mitigates the consequences of reschor trip during gate and recently charged the SIG level may are don't by a during print start up and studiewns. This was deemed to the a paint-specific priority to ensure that the applicants had meatered the impact of the charges on paint operations. Each of the charge of the charges on paint operations. Each of the charge of the charges on paint operations. Each of the charge of the charges on paint operations. The second during gateway concerning the SIG controls during SIG strains that paint operations of the charge and narrow respectives of the provide during gateway control and the second of the provide with the analytic or track of the charges on paint operations.			
078 Station Air			ž	epilace.	the state	1000	λ.			Kia. O'yaka.01 Aakiy to prediot the imposte of the futurely maillungten or approximation. And beard on those predictions, use proceedures to correct, control or mitigate the consequences of Cross connection with M.S. This is considered to be a plant specific priority due to a recent change in the system line up procedure. This was also rendonly selected and dd nd require a problement.	-		
					11							-	
												1	
			11								٣		
Plant-specific Priority Total: (ilmit 10)						l						1	

SYSTEMs T2 G3

For Official Use Only Until After 2/22/02

$(z_{\rm ex}, T_{\rm e})$					
		a series and a series of the series of the series of the series of the series of the series of the series of the			
					a second
Category	K/A #	Торіс	Imp.	Points	Question
		(b) (b) applying the intervent of the state of the sta			:
		Ability to obtain and varify controlled procedure CODV	3.1/3.2	1	143.1
	2.1.21	Ability to obtain and verify contoined proceeders copy Ability to perform specific system and integrated plant procedures during all modes	0.0/4.0		221.1
Conduct of	2.1.23	of operation Ability to locate switches, controls and indications and to determine if they are	3.9/4.0		
Operations	2.1.31	correctly reflecting the desired plant lineup	4.2/3.9	1	164.1
		and the state of the second like and the second second second second second second second second second second			
	<u> </u>		5	5	
	Total	(multi unit) Ability to explain the variation in control board layouts, systems,	2 9/2 0*	1	260.1
	2.2.4	instrumentation, and procedural actions between units at a facility	2.0/3.0		200.1
	2.2.33	Knowledge of rod control programming	2.5/2.9	1	563.1
Equipment		$\sum_{i=1}^{n} \left( \frac{1}{2} \sum_{i=1}^{n} \frac{1}{2} \sum$			
					, .
Control	North Carlos and	an a the and a set of the set of			
	ļ				
			L		ļ
	Total		4	4	
		Konsulates of facility ALABA program	2.5/2.9	1	124
	2.3.2	Knowledge of radiation exposure limits and contamination control including	2 5/2 4		703.1
Radiation	2.3.4	permissible levels in excess of those authorized	2.5/5.1		h
Control		a the second some and the second second second second second second second second second second second second s	1		
	<b>—</b> —				
	Total		0.000		910
	2.4.25	Knowledge of fire protection procedures	2.9/3.4		
	2.4.26	fighting equipment usage	2.9/3.3	·ــــــــــــــــــــــــــــــــــــ	889
Emergency	and the second s				
Emergency					
Procedures	le s	and the stand should be also be an and the stand stand of the stand stand stand stand stand stand stand stand s			
and Plan			┼┈──		
					1
	Total	91 0.D-1.4 P-4		<u>  </u>	4 7 17
H		Tier 3 Point Tou	ai 14		

#### NRC Written Exam Sample Plan Development Method

The sample plan was developed in accordance with the methodology recommended by the NRC in Attachment 1 of ES-401. The following statements amplify this process.

**Differences of Method:** The sample plan was developed using the random number generation function of Excel instead of using tokens. The random number generation function is programmed to produce an evenly distributed random number between 0 and the number entered into the argument of the function. For example, if the number 20 is entered as the argument, the function produces a resultant between 0 and 20 on an evenly distributed random basis. The result is mathematically equivalent to using the method of selection by tokens.

Initially, all K/A E/APE, System and Generic topics listed in ES-401 are screened and those topics that apply only to B&W or CE are eliminated. All NRC K/A topics and all Westinghouse (WE) E/APEs are retained for sampling. Using the selection methodology described in Attachment 1 to ES-401, an Excel spreadsheet is used to generate the RO examination. When the K/A is randomly selected, the author manually enters the corresponding K/A stem statement, the K/A description and importance rating from NUREG 1122.

SRO Exam Sampling: The SRO examination spreadsheet automatically imports all applicable RO K/As into the corresponding Tiers and Groups in the SRO sample plan. The final outcome results in 89 K/As that are common to both the RO and the SRO sample plans. There are 7 E/APEs and 4 Generic SRO-only K/As that must then be randomly selected to increase the number of questions to 100. These K/As are restricted to those K/As that are identified as having ties to 10CFR55.43(b) in NUREG 1122 for those K/As in Tiers 1 and 2. For Tier 3 (generic K/As), one additional SRO-only K/A is randomly added to each of the four K/A generic categories. It should be noted that there are very few generic K/As that were explicitly correlated to 10CFR55.43 in NUREG 1122 (and no generic K/As in category 2.3 (Radiation Control) although 10CFR55.43(b)(4) states: "Radiation hazards that may arise during normal and abnormal situations, including maintenance activities, and emergency situations.") This seems inappropriate, as one of the primary differences between the jobs of RO and SRO is the SRO responsibility for plant administrative tasks. Therefore, all generic K/As are randomly sampled when adding the fourth K/A to each generic category. These are then reviewed to ensure that an SRO-only question can be drafted to the K/A.

This produces an exam outline with 100 K/As of which 89 are common to both exams and 11 are unique to the SRO exam. Similarly, there will be 11 system K/As that are used on the RO exam but not used on the SRO exam due to the larger number of RO system K/As in the sample plan.

During the exam development process, 25 questions will be written that are unique to the SRO exam. The sampling process only identifies 11 of these questions. The exam authors will identify 14 additional SRO-only questions as they become more familiar

Tier and	Randomly	Reasons for Rejection
Group	Selected K/A	
1 - 1	APE 026 Loss	There is no significant difference between Units 1 and 2 in
	of Component	regards to the Component Cooling Water system.
	Cooling Water	
	G 2.2.4	
1-1	APE 026 Loss	"Knowledge of procedures and limitations involved in
	of Component	initial core loading" does not apply to the CCW system
	Cooling Water	because there are no procedures and limitations on this
	G2.2.31	system that are unique to initial core loading.
1-2	APE 008	This K/A states: "Ability to operate and / or monitor the
	Pressurizer	LPI system for a pressurizer vapor space accident
	Vapor Space	(Relief Valve Stuck Open)". There is no plant requirement
	Accident	to operate the low-pressure injection system under these
	AA1.05	conditions because plant pressure would stabilize above the
	0.01	low pressure system injection point.
2-1	System 004	Kesampled from K6.12 top K6.04 because there is no B11
	CVCS K6.12	Installed at McGuire. No.12 only applies to systems with a
		Boron injection Tank. Approved per tercon with Lee
	0.0	Miller on 10/10/01.
2-1	System 068	System 008 (Liquid Radiological Release) was failed in y
	Liquia Dadialagical	selected to be tested twice. This system is already being
	Radiological	developed is relatively small. The CVCS (NV) system was
	Release	rendomly selected to fill out the sample plan for a total of
		23 PO systems
2.1	System 071	System 071 (Waste Gas Disposal) was randomly selected
2-1	Waste Gas	to be a tested twice. This system is already being tested
	Disposal	once and the number of valid test items that could be
	Disposar	developed is relatively small. The ESFAS system was
		randomly selected to replaced the WGD system and fill out
-		the sample plan for a total of 23 RO systems.
2-1	System 072	System 072 (Area Radiation Monitoring) was randomly
	Area Radiation	selected to be a second system for testing. This system is
	Monitoring	already being tested once and the number of valid test
		items that could be developed is relatively small. The
		Condensate system was randomly selected to replaced the
		ARM system and fill out the sample plan for 23 RO
		systems.
2-1	System 022	This generic K/A "Knowledge of low power and shutdown
	Containment	implications in accident (e.g. LOCA, loss of RHR)
	Cooling G2.4.9	mitigation strategies" does not apply to the containment
		cooling system. The containment cooling system is not
		used to mitigate low power or shutdown accidents.

# **Draft Submittal**

(Pink Paper)

1. Operating Test Simulator Scenarios

# **MCGUIRE EXAM**

# 50-369, 370/2002-301 FEBRUARY 11 - 15, 2002

•

Appendix	D		Scenario Outline Form ES-D-1
Facility	: McGuir	е	Scenario No.: 1 Op-test No.:
Examiner	s:		Operators:
Objectiv compound load due crew wil swap to leak tha	es: 1) Th ed by the to conde 1 deal wi the other t becomes	e crew wi rods not nser dump th a loss train of a LOCA a	.11 deal with minor malfunctions that will be working in automatic. 2) The crew will have to cut by valve being open and power going above 100%. 3)The s of essential bus as a result the crew will have to components. 4) The crew must deal with a small NC and a loss of ECR.
Initial	Condition	<b>18:</b> 100% F	Power/ "B" Train Components in Service/
<b>Turnover</b> auxiliar	: "1A" D/ y steam/	'G Tagged/ Maintain	"1A" AFW pump tagged/ Unit 2 is available for present plant conditions
Event No.	Malf. No.	Event Type*	Event Description
1		RO	Tref failure - fails to 557 degrees
2		BOP	Pressurizer Level Channel 2 fails low
2		N	Place excess letdown in service
3		RO	Atmospheric dump valve fails open
3		R	Reduce turbine load due to dump valve failure
4	· · · · · · · · · · · · · · · · · · ·	BOP	Loss of ETB with failure of D/G to start
5		M(ALL)	LOCA with a failure of ECR
			Post major event failures
			Main Steam isolation fails in automatic
			2 rods fails to insert on trip
			Automatic Phase "A" on "A" train does not work
· · · · · · · · · · · · · · · · · · ·			No automatic Safety Injection
			Sump suction valve fails to open automatically
<u> </u>			
			The loss of ETB is a DAS at MCGuire. It comprises 1% of the important core melt events.

\* (N)ormal, R)eactivity, (I)nstrument, (C)omponent, (M)ajor

NUREG 1021, Revision 8

#### PROGRAM: McGuire Operations Training

MODULE: Initial License Operator Training Class 20

TOPIC: Nuclear Regulatory Commission Simulator Exam

Scenario 1

#### **REFERENCES**:

- 1. McGuire Technical Specifications
- 2. AP/1/A/5500/01 Steam Leak
- 3. AP/1/A/5500/12 Loss of Letdown, Charging or seal Injection
- 4. AP/1/A/5500/14 Rod Control Malfunction
- 5. AP/1/A/5500/07 Loss of Electrical Power
- 6. EP/1/A/5000/E-0 Reactor Trip or Safety Injection
- 7. EP/1/A/5000/E-1 Loss of Reactor or Secondary Coolant
- 8. EP/1A/5000/FR-P.1 Response to Imminent Pressurized Shock
- 9. EP/1/A/5000/FR.Z.1 Response to High Containment Pressure
- 10. EP/1/A/5000/ES-1.3 Transfer to Cold Leg Recirculation
- 11. RP/O/A/5700/00 Classification of Emergency

Author: \_\_\_\_\_\_ Facility Review: \_\_\_\_\_\_ NRC Review: \_\_\_\_\_

February 1, 2002 Rev.1

#### SIMULATOR OPERATOR INSTRUCTIONS

Bench Mark	ACTIVITY	DESCRIPTION
Sim. Setup	Rod Step On	
	IC-142	
	RUN	
	Update Status Board,	See Shift Turnover Information
	Setup OAC	
	Setup ICCM, Turbine Displays, & Trend Recorders.	
	<b>Check</b> Rod Step Counters agree with rod positions	
	(M) EPQ001A	Loss of D/G "1A" Control Power
	Set = 1	
	(LOA) CA009	Rack out breaker for "1A" Auxiliary Feedwater Pump
	Set = Rack Out	
	(MAL) IRE010D14	2 Rods fail to insert when tripped
	(MAL) IRE010H2	
	(M) ISE002A	No automatic S/I both trains
	(M) ISE002B	
	(M) ISE006A	Failure of automatic Main Steam Isolation
	(M) ISE006B	
	(M) ISE003A	Failure of Phase "A" Train "A" to automatically actuate
	(OVR) SV005D	Fails 1SV-47 OPEN
	Off - Insert	
	(M) NI002F	"A" train containment sump valve fails to automatically
	Set = 0	open
	(M) NV020E	Fails 1NV-35 open
	Set = 100	

	Bench Mark	ACTIVITY	DESCRIPTION	
		Freeze.		
		Update Fresh Tech. Spec. Log.		
		Fill out the NLO's Available section of Shift Turnover Info.		
	Prior to Crew Briefing	RUN		
	1. Assign Crew	Positions based on evaluat	Crew Briefing ion requirements	
	2. Review the S	hift Turnover Information w	ith the crew.	
	3. Direct the cre	w to Review the Control Bo	pards taking note of present conditions, alarms.	
	T-0	Begin Familiarization Period		
	At direction of	(MAL) IRE001	Tref fails to 557 degrees	
	examine	Set = 557		
	At direction of	(XMT) ILE002	Pressurizer level channel 2 fails to "0"	
	examiner	Set = 0	INV-1A will not reopen	
		(M) NV020A		
1		Set = 0		
1		Set both to trigger 1		
	At Direction of	(MAL) IDE004A	Fails atmospheric dump valve open	
	Examiner	Set = 100		
		Ramp = 2		
	At direction of examiner	(MAL) EP008B	Trips Operating Train ETB	
	At step 39 of	(M) NC007A	Initiates a small NC system leak	
	AP/07	Set = 1		
		Ramp 300		
	At direction of examiner	(M) NC008A	Initiates LOCA	
			Delete malfunction when BOP opens 1NI-185A	
		Terminate the scen	ario upon direction of Chief Examiner	

Event 1: Tref failure

.

Time	Pos.	Expected Actions/ Behavior	Comments
	RO	<ul> <li>Recognizes Unwarranted Control Rod Insertion and informs Crew.</li> <li>No turbine or reactor power excursion</li> <li>Tref circuit failed to 557 degrees</li> </ul>	
	RO	Places CRD Bank Selector Switch to manual and verifies movement stopped	RO places Rods in Manual Checks rod movement stopped
	SRO	Enters AP/14, Rod Control Malfunctions and directs activities.	
	RO	Performs the following as necessary to maintain Tcolds 555 degrees to 557 degrees • Lower turbine load or • Borate NC system	
	RO	Announce occurrence on page	
	RO	Check all rods – ALIGNED WITH ASSOCIATED BANK	
	RO	Checks "Rod Control Urgent Failure" alarm dark	
	RO	Checks the following normal: Turb Imp Pressure Channel 1 T-ref 1A NC loop T-ave 1B NC loop T-ave 1C NC loop T-ave 1D NC loop T-ave	Go to Enclosure 4 (Response to Continuous Rod Movement)
	SRO	Go to Enclosure 4	
	SRO	<ul> <li>Evaluate rod movement</li> <li>Check the following normal</li> <li>Turb Imp Pressure Channel 1</li> <li>T-ref</li> <li>1A NC loop T-ave</li> <li>1B NC loop T-ave</li> <li>1C NC loop T-ave</li> <li>1D NC loop T-ave</li> <li>Checks to see if failed channel has been identified</li> <li>Exit procedure</li> </ul>	Tref circuit is the failure SRO should notify IAE to investigate and maintain Tcolds 555 degrees to 557 degrees by adjusting control rods in manual or adjusting turbine load or boration/dilution of NC system.

Pos.	Expected Actions/ Behavior	Comments
BOP	On a loss of letdown ensure the following closed: • 1NV-458A • 1NV-457A • 1NV/254	1NV-35A will not close – BOP must attempt to close. Immediate action of AOP.
 SRO	Enters AP/12 Loss of Letdown, Charging or Seal Injection	
BOP	If at any time "REGEN HX LETDN HI TEMP" alarms, close:	BOP will take action if appropriate
	<ul><li>1NV-1A</li><li>1NV-2A</li></ul>	1NV-1A closed due to failure
RO	Stop any power or temperature changes in progress	
RO	Announces occurrence on page	
SRO	IF this AP entered due to loss of letdown only, then go to step 35.	SRO will go to step 35 in this AOP
BOP	Ensures "NC Sys M/U Controller" in AUTO	
BOP	Ensures charging flow going down to maintain Pzr at program level	
BOP	Checks "Letdn Relief Hi Temp" alarm has remained dark	
BOP	Checks 1NV-21A - closed	

Pos.	Expected Actions/ Behavior	Comments
BOP	Checks Pzr heater group supply breakers –	NO, due to level instrument failure
	lioseu	BOP will perform the following:
		<ol> <li>Ensures the following are selected to an operable channel</li> </ol>
		<ul> <li>"Pzr level control select" 1-3 position</li> </ul>
		<ul> <li>"Pzr levei rec select"</li> </ul>
		2. Ensure Pzr level greater than 17%
		<ol><li>Place the following switches in "MAN"</li></ol>
		• A
		• B
		• D
	- 	4 Close the following breakers:
		• A
		• B
		• "D
		5. Close C Pzr heater group supply
	b. Check normal spray available	breaker
	c. Place the following Pzr heater groups in	
	Manual and ON to maximize spray.	
	• A	
	• B	
	• D	
BOb	Checks the following OPEN	NO, go to step 42
	• 1NV-1A	
	• 1NV-2A	
SRO	Checks to see if immediate restoration of normal letdown is possible	Orifice isolation valve NV-35 has not closed. So will go to step 47 to place
	<ul> <li>Both NV 1 &amp; 2 open in the past 30 minutes</li> </ul>	excess letuowit in service.
	<ul> <li>Orifice isolation valves closed before or at the same time as NV 1 &amp; 2.</li> </ul>	guidance that excess letdown is desired.

#### Event 2: Pressurizer Level Channel 2 Failure

Pos.	Expected Actions/ Behavior	Comments
BOP	<ul> <li>Establish excess letdown</li> <li>Adjust charging to minimum while maintaining the following:</li> <li>NC pump seal injection flow greater than 6 gpm</li> <li>Pzr level at program level</li> <li>1. Opens the following:</li> <li>1KC-315B and 1KC-305B</li> <li>Places 1NV-27B to VCT position</li> <li>2. Opens and closes 1NV-26</li> <li>3. Checks the following OPEN:</li> <li>1NV-94AC</li> <li>1NV-95B</li> <li>4. Opens 1NV-24B and 1NV-25B</li> <li>5. Slowly opens 1NV-26 while maintaining excess letdown heat exchanger temp. less than 200 degrees.</li> </ul>	
SRO	Go TO step 47.n	
BOP	<ul> <li>Notified chemistry that excess letdown is in service.</li> <li>Adjust charging flow as desired while maintaining:</li> <li>NC pump seal injection flow greater than 6 gpm</li> <li>Pzr level at program level</li> <li>Operate Pzr heaters as desired</li> </ul>	
SRO	SRO should notify Work Control Center or IAE to investigate and repair failed instrument	Tech Spec. 3.3.1 function 9

Time	Pos.	Expected Actions/ Behavior	Comments
	CREW	Recognizes symptoms of a steam leak <ul> <li>T-ave decreasing</li> <li>Power increasing</li> </ul>	T-ave-Tref annunicator may come in alarm
	SRO	Enters AP/01 Steam Leak	
	Crew RO	Monitors fold out page Reduces turbine load to maintain:	
		<ul> <li>NC loop D/Ts - less than 60 degrees</li> <li>T-ave at T-ref</li> </ul>	
	BOP	Checks Pzr level -stable or going up	
	SRO	Will return to step 3 if Pzr level can not be maintained.	
	RO	Announces occurrence on page	
	RO	Identifies and isolates leak: • Checks S/G PORVs – CLOSED • Checks condenser dump valves –CLOSED • Checks atmospheric dump valves – 1 OPEN • Checks containment conditions – NORMAL • Checks turbine driven CA pump – OFF • Checks steam line drain valves – CLOSED • Checks Unit 2 – steam header pressure	An atmospheric dump valve will be OPEN – RO must select "OFF RESET" on Steam dump interlock Bypass channel A and B. Isolation valve will not close. Must dispatch an operator to fail air to atmospheric dump valve.
	SRO	Exits procedure when leak is isolated.	

#### Event 3: Atmospheric Dump Valve Fails OPEN

Time	Pos.	Expected Actions/ Behavior	Comments
	Crew	Recognizes loss of operating train "ETB"	
	SRO	Checks bus energized and sequencer applying loads. SRO entered AP/07	The diesel will NOT start due to failure
Critical	BOP	If both NV pumps off, Then isolate NORMAL letdown. Start opposite train: • NV pump • KC pump • RN pump Go to step 3	
	SRO	<ul> <li>Verifies NO Safety Injection has occurred</li> <li>If both NV pumps off then isolate:</li> <li>Excess letdown</li> <li>ND letdown</li> <li>If any pump was manually started per step 1 go to step 5</li> </ul>	"A" train NV pump will be on
	SRO	Check D/Gs - OFF	
Critical	ВОР	<ul> <li>Align KC as follows:</li> <li>Places 1KC-51A to AUTO</li> <li>Ensures the following are open</li> <li>1 KC-3A</li> <li>1KC-230A</li> <li>1KC-394A</li> <li>1KC-345A</li> <li>If needed keep thermal barrier valves open raise KC flow to KF hx by opening 1KC-149</li> <li>Ensures KC flow is less than 4000 gpm per operating KC pump</li> </ul>	
	SRO	Checks any charging pump – Running - YES	
	BOP	<ul> <li>Align RN as follows:</li> <li>Check 1A RN pump – Running – YES</li> <li>Close 1RN-43A</li> <li>Throttle 1RN-89A to desired cooling</li> </ul>	
	SRO	Notifies Unit 2 RO to start 2A RN pump	EXAMINER CUE: 2A RN pump is running
	SRO	Checks B/O on 1ETA	NO, go to step 22
	BOP	Checks 1RN-86A – OPEN	
	SRO	Dispatches operator to close: • 1KC-228B • 1KC-18B	

#### Event 4: Loss of Operating Train ETB

Time	Pos.	Expected Actions/ Behavior	Comments
	SRO	Checks 1B ND train – was not in RHR mode	Go to step 30
	SRO	Checks normal letdown – IN SERVICE	No, may have operator place excess letdown back in service.
	SRO	Go to step 36	
	RO	Announces occurrence on page.	
	SRO	Checks D/G on bus that was blacked out - NO	<ul> <li>Place affected D/G Mode Select to "C/R"</li> <li>Depress then release the "RESET" pushbutton for the affected train's sequencer.</li> <li>Start D/G.</li> </ul>
	BOP	Check bus energized and sequencer applying loads	<ul> <li>Place affected D/G Mode Select to "C/R"</li> <li>Ensure normal and standby breaker open to allow auto loading of bus.</li> <li>If bus not energized or sequencer not loading bus then go to Enclosure 1.</li> </ul>
	SRO	Go to Enclosure 1 – Manual Loading of Emergency Bus	
	BOP	<ul> <li>Ensure S/I Reset</li> <li>Check 1ETA – Energized from Offsite Power</li> <li>Go to Step 15</li> </ul>	
	BOP	Check 1ETB – Energized from Offsite Power - NO	Go to step 20
	BOP	Hold "RESET" on "1B D/G LOAD Seq" while completing steps 21 through 23.	

#### Event 4: Loss of Operating Train ETB

Time	Pos.	Expected Actions/ Behavior	Comments
	BOP	<ul> <li>Unload 1ETB bus as follows:</li> <li>1. Open 1B CA pump breaker</li> <li>2. Open the remaining pump breakers on 1ETB</li> <li>NV</li> <li>ND</li> <li>NI</li> <li>KC</li> <li>RN</li> <li>KF</li> <li>Ensure Train B NS is reset and open NS pump breaker</li> <li>3. Open 600v essential transformer feeder breakers:</li> <li>1ELXB</li> <li>1ELXD</li> <li>1ELXF</li> </ul>	
	BOP	<ul> <li>Place "1B D/G Mode Select switch to "C/R"</li> <li>Close "1ETB Emerg Breaker"</li> </ul>	<ul> <li>Breaker will not close.</li> <li>Release "RESET" on "1B" D/G Load SEQ"</li> <li>Stop D/G</li> <li>Return to procedure and step in effect.</li> <li>Go back to step 38 in body of procedure.</li> </ul>
		NC LEAK WILL BEGIN AT THIS POINT	

#### Event 4: Loss of Operating Train ETB

Time	Pos.	Expected Actions/ Behavior	Comments
	BOP	<ul> <li>Report either of the following:</li> <li>Pzr level decreasing</li> <li>Pzr press decreasing</li> <li>Containment Vent Isol (EMF39)</li> <li>"Ice Cond Doors Open" Annunciator</li> </ul>	
	SRO	Go to AP/10 (Case II) NC System Leakage and directs activities	
	BOP	<ul> <li>Report Pzr Level decreasing:</li> <li>Report NV-238 opening</li> <li>Open NV-241 while maintaining 6 gpm Seal Injection Flow</li> <li>Starts additional NV Pump</li> <li>Isolate excess letdown</li> <li>*If Pzr level less than 4% then:</li> <li>Manually Trip Reactor</li> <li>Manually SI</li> </ul>	
	Crew	Returns to step 1 if Pzr level can not be maintained.	
	Crew	Isolated leak if location is known	
	BOP	Reports Pzr Pressure stable or trending to 2235 psig	
	RO	<ul> <li>Reports Main Steam line is INTACT</li> <li>Reactor power at turbine power</li> <li>NC loop T-Ave is stable</li> </ul>	
	SRO	When leak is determined greater than makeup capability, directs crew to trip reactor and initiate Safety Injection	
	RO	Manually trips Reactor (Train A & B)	Two rods fail to insert
Critical	BOP	Manually initiates Safety Injection both trains	

Event 5: LOCA

Time	Pos.	Expected Actions/ Behavior	Comments
	SRO	Go to EP/E-0 and directs activities	
	SRO	Reviews Foldout page with crew	NCP trip criteria based on loss of subcooling
	RO	Report Reactor Trip: • rod bottom lights • reactor trip breakers open • I/R amps decreasing	TWO rods will be stuck
	RO	Reports Turbine Generator tripped TV's or GV's closed	
	BOP	Reports ETA and ETB energized	"B" will be de-energized
	RO	Reports SI status light - LIT	After Immediate Actions are completed by operator they can close MSIV's if they recognize they are open and should be closed.
	BOP	Report LOCA sequencers (A & B) actuated	
	RO	Announce "Unit 1 Safety Injection" on page	
	BOP	Checks ESF Monitor Light Panel Groups 1,2 and 5 DARK Group 3 LIT Checks OAC in service	The "B" side of all panels will be dark
	BOP	Reports all Ss and St components in Group 4 NOT -LIT	If not already done BOP should manually initiate Phase "A" Train "A"
	RO	Reports that CA is running and at least 3 S/G's NR level > 17%	Motor driven pumps are not available.
	BOP	Reports KC pumps running	"A" train only
	BOP	Reports RN pumps running	"A" train only

### Event 5: LOCA

Time	Pos.	Expected Actions/ Behavior	Comments
	SRO	Directs Unit 2 Operator to throttle RN to minimum & start 2A RN pump	EXAMINER CUE: • 2A RN pump is running
	RO	Checks/reports all S/G pressures > 775 psig	
	BOP	Reports Containment pressure has remained less than 3 psig	<ul> <li>NO</li> <li>record approximate time of reactor trip</li> <li>Check row G on Monitor Light Group 4</li> <li>If any row G is dark on energized train</li> <li>Stop all NC pumps</li> <li>Stop all RV pumps</li> <li>Energize H2 igniters by depressing "ON" and Override</li> <li>When time allows check Phase B HVAC equipment per Enclosure 2</li> </ul>
	BOP	<ul> <li>Report NV Pump to Cold Leg Flow gauge - indicating flow - YES</li> <li>checks NC pressure &lt; 1600 psig</li> <li>checks NI pumps indicating flow</li> <li>checks NC pressure – less than 286 psig</li> <li>checks ND pumps – indicating flow to cold legs</li> </ul>	
	SRO	When available notifies OSM or other SRO to implement Generic Enclosure 22	<i>EXAMINER CUE: OSM will ensure Generic Enclosure 22 is implemented.</i>
	RO	<ul> <li>Checks CA flow &gt; 450 gpm and takes control of CA to maintain no load levels</li> <li>checks VI header pressure &gt; 60 psig</li> <li>Maintains N/R level between 32% and 50%</li> </ul>	RO will take control of auxiliary feedwater.
	BOP	<ul> <li>If any NC pump ON, then check Tave stable or trending to 557 degrees</li> <li>If all NC pumps off, then check NC T-colds stable or trending to 557 degrees.</li> </ul>	
	BOP	Reports Pzr PORV & Spray Valves closed	
	BOP	Reports subcooling > 0 degrees based on Core Exit Thermocouples	
	BOP	Reports all main steamlines INTACT	
	RO/ BOP	Report S/G tube rupture parameters indicate that S/G tubes intact	

### Event 5: LOCA

Time	Pos.	Expected Actions/ Behavior	Comments
	SRO	<ul> <li>Checks if NC system is NOT intact:</li> <li>Containment EMFs – normal</li> <li>Ice Condenser Lower Inlet Doors Open alarm – DARK</li> <li>Containment pressure &lt; 1 psig</li> <li>Containment sump level normal</li> </ul>	<ul> <li>Perform the following:</li> <li>If H2 igniters are off then perform the following:</li> <li>Energize H2 igniters by depressing On and Overrride</li> <li>Dispatch operator to stop all NF AHU's</li> <li>Implement F-0 CSFST</li> <li>Go to E-1</li> </ul>
		CSFST will necessitate going to P-1 then Z-1	The crew will only do the first step on P-1 and based on pressure will exit P-1.
	BOP	P-1 – Response to Imminent PTS Check NC pressure – Greater than 286 psig NO	ND pump flow is greater than 500 gpm – Then return to procedure and step in effect. Go to Z-1
	SRO	Will go to Z-1, Response to High Containment Pressure	
	CREW	If loss of emergency coolant recirc has occurred, THEN this procedure may be completed as time allows.	
	Crew	Monitors foldout page	
	BOP	Stop all NC pumps.	
	BOP	Ensure all RV pumps are in manual and off.	
	SRO	Dispatch operator to remove tags and close breakers for the following valves: • 1EMXA-R2A • 1EMXAB1-6B	
	BOP	Check containment pressure – LESS THAN 15 PSIG.	
	BOP	Check any NS pump - ON	
	SRO	The remainder of this EP may be performed as time allows.	
# Event 5: LOCA

Time	Pos.	Expected Actions/ Behavior	Comments
	SRO	ES 1.3 Transfer to cold leg recirc.	
	BOP	Checks containment sump level – greater than 3 feet	
	BOP	Checks KC flow to each ND heat exchanger greater than 5000 gpm	No, on "B" train crew will do RNO
	BOP	Resets Safety Injection and Sequencer	MAKE SURE SIMULATOR RUNNER READY TO DELETE MALFUNCTION FOR 1NI-185A IN NEXT STEP.
Critical	BOP	Align ND system for recirc: Check 1NI-185A OPEN – NO Checks 1A ND pump on – YES Check 1NI-184B OPEN – NO Close 1FW-27A Check any ND pump on	Place the control permissive in "BYPASS" and open 1NI-185A Go to step 6b Go to step 6e
	BOP	Align NV and NI systems for recirc: Check NC pressure less than 1600 psig Close the following: • 1NI-115A • 1NI-144B Close 1NI-147A Close • 1ND-30A Align ND train discharge to NI and NV pump suctions: • Open 1NI-332A • Open 1NI-332A • Open 1ND-58A Close 1NI-100B – can not close • Close 1NV-221A	
	SRO	Check if NS should be aligned for recirc – NO go to step 9	
	SRO	Check is ND aux spray is required – NO go to step 10	

#### Event 5: LOCA

.

Time	Pos.	Expected Actions/ Behavior	Comments
	CREW	If at any time a B/O signal occurs, then restart S/I equipment previously on.	
	SRO	Checks for proper recirc flow and valve alignment Checks the following closed • 1ND-19A • 1NV-151A • 1NV-221A Checks flow indicated from: • NV pump • NI pump • ND pump Checks the following closed: • 1KC-50A • 1KC-1A Check KC flow to ND heat exchanger established	
	SRO	Implement F-0 CSFST	
	SRO	Return to procedure and step in effect.	
		TERMINATE SCENARIO AT DIRECTION OF	F CHIEF EXAMINER

## EXAMINER NOTE: Be sure SRO classifies event at end of scenario.

Classification of event: ALERT

#### SHIFT TURNOVER INFORMATION

.

UNIT 1 STATUS:								
{PRIVATE }Power Level:	100%	NCS [B]	759ppm	Pzr [B]:	759 pp	m	Xe:	OAC
{PRIVATE }Power History	At 100% /:	for 100 da	ys	Core I	Burnup:	200 E	FPD	S
CONTROLLING PRO	CEDURE:	OP/1/A/6 <sup>-</sup>	100/03 Contr	olling Proce	edure for	<sup>r</sup> Unit C	Opera	tion
		D TO ASSI	JME TO SHIF	Т:				
"1A" Diesel G "1A" Auxiliary Unit 2 is availa Reduce powe	enerator tag Feedwater p able for auxi r to 90% to o	ged for ma oump tagg liary steam do turbine	aintenance. ed for oil char n. valve movemo	ge - PM ent test.				
Work Control SRO/O	offsite Com	nunicator	Th	ad				
Unit 2 SRO			Jir	Jim				
NLO'S AVAILABLE								
<u>Unit 1</u>			<u>Un</u>	<u>it 2</u>				
Aux Bldg. R	lobb		Au	x Bldg. Jo	e			
Turb Bldg. F	red		Tu	b/Service	Bldg. M	ike		
Extra(s) Bill, (	Craig, Russ,	Ron						

Appendix	D		Scenario Outline Form ES-D-1			
Facility	McGuir	re	Scenario No.: 2 Op-test No.:			
Examiners:			Operators:			
Objectiv using im orderly steam ge	Objectives: 1) Determine if the crew can deal with a variety of malfunctions using immediate actions and AOP's. 2) Determine if the crew can perform an orderly shutdown of the plant then handle a large STGR without filling the steam generator.					
Initial	Condition	<b>18:</b> 55% Pc	ower/ "B" Train Components in Service/			
<b>Turnover</b> auxiliar	: "1A" D/ y steam/	(G Tagged, Begin loa	/ "1A" AFW pump tagged/ Unit 2 is available for ad increase			
Event No.	Malf. No.	Event Type*	Event Description			
1		RO	Power Range 43 fails high			
2		BOP	Pressurizer Pressure channel 2 fails high			
3		BOP	NC PORV 36 fails to 25% open - must close block valve to isolate			
4		RO	S/G Control Valve failure - normal controller fails			
5		M (ALL)	Steam generator Tube Leak - 40 gallons per minute			
6		N	Removing Feedwater Pump from service			
6		R	Load reduction due to shut down of plant			
7		M (ALL)	SGTR - 430 gpm			
			Post Major Event Failures			
			Failure of automatic feedwater isolation			
			MSIV on ruptured S/G will not close			
			No automatic Safety Injection			
			One reactor trip breaker will not open			
			EMF for ruptured S/G failed as is			

\* (N)ormal, R)eactivity, (I)nstrument, (C)omponent, (M)ajor

NUREG 1021, Revision 8

# PROGRAM: McGuire Operations Training

MODULE: Initial License Operator Training Class 20

# TOPIC: Nuclear Regulatory Commission Simulator Exam

Scenario 2

# **<u>REFERENCES</u>**:

.

mps

Author:	
Facility Review:	
NRC Review"	

February 1, 2002 Rev.1

### SIMULATOR OPERATOR INSTRUCTIONS

_	Bench Mark	ΑCΤΙVITY	DESCRIPTION
	Sim. Setup	Rod Step On	
		IC-143	
		RUN	
		Update Status Board,	See Shift Turnover Information
		Setup OAC	
		<b>Setup</b> ICCM, Turbine Displays, & Trend Recorders.	
	:	<b>Check</b> Rod Step Counters agree with rod positions	
		(MAL) EPQ001A	Loss of D/G "1A" Control Power
		Set = 1	
		(LOA) CA009	Rackout breaker for "1A" Auxiliary Feedwater Pump
		Set = F	
		(M) SM006A	MSIV on ruptured generator fails open
		(M) ISE002A	No automatic S/I both trains
		(M) ISE002B	
		(M) ISE007A	Failure of Feedwater Isolation - both trains
		(M) ISE007B	
		(M) EMF133	Set EMF 33 at 10
		Set = 10	
		(M) EMF173	Fails EMF 24 to "0"
		Set = 1	
		(M) IPE001A	Failure of "A" train reactor trip breaker to open
		(M) IPE002A	

### SIMULATOR OPERATOR INSTRUCTIONS

Bench Mark	ACTIVITY	DESCRIPTION
	Freeze.	
	Update Fresh Tech. Spec. Log.	
·······	Fill out the NLO's Available section of Shift Turnover Info.	
Prior to Crew Briefing	RUN	
1. Assign Crew	Positions based on evaluation	Crew Briefing on requirements
2. Review the S	hift Turnover Information wit	h the crew.
3. Direct the cre	w to Review the Control Boa	ards taking note of present conditions, alarms.
Т-0	Begin Familiarization Period	
At direction of	(MAL) ENB013E	Power Range NI 43 fails high
examiner	Set = 200	
	Ramp = 5	
At direction of	(MAL) NC003F	Pressurizer Pressure Channel 2 fails HIGH and NC POBV NC-36 sticks at 25% open
examiner	Set = 25	Set both to triager 1
	(XMT) NC039	
	Set = 2500	
At direction of	(MAL) IFE009B1	S/G "B" Control Valve Failure
examiner	Set = 0	
	Ramp = 5	
 At direction of	(M) S/G001A	Initiates 50 gpm tube leak on "A" steam generator
examiner	Sel = 50	
	Ramp = 120	
	(M) S/G001A	Initiate once FWPT has been shutdown
	Sel =435	Design basis tube rupture
	Ramp = 120	
	Terminate the scena	rio upon direction of Chief Examiner

## Event 1: Power Range 43 Fails High

.

Time	Pos.	Expected Actions/ Behavior	Comments
	RO	Determines NI-43 has failed high and <b>places</b> rods to manual	Immediate action
	SRO	Entered AP/16 Malfunction of Nuclear Instrumentation	
	RO	Checks S/G levels at programmed level	Should place reg. Valve for "A" and "D" S/G to manual and return to program level
	RO	Announce occurrence over page	
	RO	Checks P/R channels – only one failed	
	RO	Positions "PR to S/G Program level defeat" switch to 41/43 position	
	RO	Secures any power increase.	
	BOP	Performs the following actions at the "Miscellaneous Control and Indication Panel"	
		<ul> <li>Rod Stop Bypass to N43</li> </ul>	
		<ul> <li>Power Mismatch Bypass to N43</li> </ul>	
	BOP	Performs the following actions at the "Detector Current Comparator" drawer	
		Upper Section to N43	
		Check upper section light lit	
	-	Lower Section to N43	
		Check lower section light lit	
	BOP	Performs the following at the "Comparator and Rate" drawer	
		Comparator Channel to N43	
		Check comparator light for N43 lit	
	BOP	Trips bistables for failed channel	
		Remove control power fuses from N43	
-	RO	Checks the following status lights for the failed channel lit:	
		NUC Overpower Rod Stop Bypass	
		P/R Hi Flux Lo Stpt	
		P/r Hi Flux Hi Stpt	
		P/R Hi Flux rate	

Event 1:	Power Range 43 Fails High
----------	---------------------------

Time	Pos.	Expected Actions/ Behavior	Comments
	RO	<ul> <li>Checks the following annunciators lit:</li> <li>P/R Hi Voltage Failure</li> <li>P/R Hi Flux Hi Stpt Alert</li> <li>P/R Hi Flux Rate Alert</li> <li>Checks the following status light lit:</li> <li>P/R Lo Setpoint Train A Trip Blocked</li> </ul>	
	SRO	P/R Lo Setpoint Train B Trip Blocked  If desired to control S/G levels in auto then return affected s/G CF control valves to auto	
	RO	Ensures operable P/R channel selected to record on NIS recorder	
	RO	Adjust control rods to maintain T-ave at T-ref	
	RO	When T-ave within 1 degree of T-red and auto rod control desired then return control rods t auto	
	SRO	Instructs IAE to fail OTDT and OPDT bistables within 6 hours of failure	Tech Spec evaluation Table 3.3.1-1 • 3.3.1.2 • 3.3.1.3 • 3.3.1.6 • 3.3.1.16 b,c,d • 3.3.1.7
	CREW	Ensures proper bistables failed for P/R 43 • NC loop C OPDT Trip • NC loop C OTDT Trip	
1			

Time	Pos.	Expected Actions/ Behavior	Comments
	BOP	Recognizes/reports PZR pressure decreasing	
	SRO	Implements AP/11 Pzr Pressure Anomalies, Case 2 and directs activities	
	BOP	Reports Pzr Pressure decreasing	
Critical	BOP	Determines all channels not the same	Places "Pzr Pressure Control Select" to backup channel – 1-4 position
Critical	BOP	Checks/reports Pzr PORV's Closed	Will try to close – will not close – must close block valve
	BOP	Checks/reports Spray Valves Closed	
	BOP	Reports Pzr PORVs - closed	No for NC-36 will close 1NC-269
	BOP	Reports Spray Valves Closed	
	SRO	Go to Step 9	
	RO	Announce occurrence on page	
	BOP	Checks/reports NV-21A , CLOSED	
	BOP	Checks/reports Pzr A,B & D heaters ON	
	BOP	Checks 1C PZR heater - ON	
	BOP	Checks Pzr pressure going UP	
	SRO	Go to step 21	
	SRO	Ensures "Pzr PRESS REC SELECT" is on an operable channel	
	SRO	Will notify Work control center and/or IAE to investigate and repair	Failure will not be fixed Tech spec issue with two channels of OTdT inoperable.
			Tech Spec 3.0.3 for two channels
			Plus Tech Specs
			• 3.3.1.6
			• 3.3.1.8
			• 3.3.2.1.d
			• 3.3.2.8.b

Event 2 and 3: Pressurizer Pressure Channel 2 Fails High with NC 36 failed to 25%

Time	Pos.	Expected Actions/ Behavior	Comments
	BOP	Refer to annunciator responses	Annunciators on 1AD-4
		• C-2	
	SRO	Goes to AP/06 Loss of Feedwater	
Critical	RO	Places Feed Regulator to Manual	respond in manual then:
		nestores o/a level to program level	<ul> <li>Select ALT on control circuit</li> </ul>
			<ul> <li>Restore to program level</li> </ul>
	RO Checks the following channel indicating the I same:		Immediate Action step
	ļ	Feed flow	
		Steam Flow	
	S/G Level		
	RO Checks S/G CF control valve in manual control		YES
	RO	When the following are met then return affected S/G CF control to automatic	
		1. Selected control channels indicated correctly	
		Feed flow	
	Steam flow		
1		S/G level	
		2. Affected S/G level restored to program level	
L	L	3. Automatic control is desired	
	SRO	Checks the reactor tripped	NO
	RO	Maintains S/G level	Go to step 7
	RO	Controls feed flow to maintain S/G NR level - at programmed level	
	SRO	Checks NC temperature with NC pumps on stable or trending to programmed temperature	
	SRO	Checks procedure enter due to failed controller	
	SRO	Contacts I&E to repair failed controller	Failure will not be repaired
		Exit procedure	

# Event 4: Normal Controller for "B" S/G Fails Low

\_\_\_\_

## Event 5: S/G Tube Leakage on "A" S/G

Time	Pos.	Expected Actions/ Behavior	Comments
	BOP	<ul> <li>Report either of the following:</li> <li>Pzr level decreasing</li> <li>Pzr press decreasing</li> <li>EMF 24 – Blocked - crew will not see</li> </ul>	
	SRO/ BOP/ RO	<ul> <li>Refer to Ann. Response and/or AP 10</li> <li>Notify RP shift</li> <li>RDW shift</li> <li>CT lab</li> <li>Refer to AP/10</li> <li>Have operator secure drains to TB sump.</li> </ul>	
	SRO	Go to AP/10 (Case I) S/G Tube Leakage and directs activities	
	BOP	<ul> <li>Report Pzr Level decreasing:</li> <li>Report NV-238 opening</li> <li>Open NV-241 while maintaining 8 gpm Seal Injection Flow</li> <li>Starts additional NV Pump</li> <li>Reduce letdown to 45 gpm or isolate letdown</li> <li>*If level less than 11% then:</li> <li>Manually Trip Reactor</li> <li>Manually SI</li> </ul>	
	SRO	If primary to secondary leak is greater than 100 gpm, then trip reactor and go to E-0	Leak is < 100 gpm
	RO	Announce occurrence on page	
	SRO	If at any time while in this procedure Pzr level can not be maintained stable then perform step	
	BOP	Checks Pzr pressure – stable or trending to 2235 psig.	
	SRO	If NC leakage exceeds Tech Spec limits then ensure outside air pressure filter train in service.	Tech Spec 3.4.13
	SRO	<ul> <li>Check if unit shutdown is required:</li> <li>1. Leakage in one S/G – greater than 125 gpd</li> <li>2. Reduce load in step 8</li> <li>Ensure reactor power is less than 50% within 1 hour of exceeding 125 gpd</li> <li>Be in Mode 3 within 3 hours of exceeding 125 gpd.</li> </ul>	
	SRO	<ul> <li>Reduce load PER one of the following:</li> <li>AP/1/A/5500/04 Rapid Downpower OR</li> <li>OP/1A/6100/03 Controlling procedure for Unit Operation</li> </ul>	

Time	Pos.	Expected Actions/ Behavior	Comments
	RO	Identify "C" S/G as having excessive leakage	<ul> <li>AP/04 evaluation Rapid Downpower</li> <li>Monitor foldout page</li> <li>determine power reduction rate</li> <li>check control rods in AUTO - YES</li> <li>notify SOC of load reduction</li> <li>initiate turbine load reduction</li> <li>borate the NC system</li> <li>check control rods moving in as required</li> <li>check turbine impulse pressure &gt; 290#</li> <li>May refer to RP/00 Classification of Emergency and RP/10 Immediate NRC Notification Requirements</li> <li>check turbine control in AUTO</li> <li>check Unit 2 aux steam available to supply header</li> <li>check P/R instruments indicate power &lt; 40%</li> <li>Check &lt; P-8</li> <li>all CF flows &lt; 40%</li> <li>Impulse pressure &lt; 290#</li> <li>Once FWPT is removed from service the leak size will increase</li> </ul>
	SRO	When leak is greater than makeup capability, directs crew to trip reactor and initiate Safety Injection	Crew will go back to step 1 of AP/10 when Pzr level begins decreasing
	RO	Manually trips Reactor (Train A & B)	
Critical	BOP	Manually initiates Safety Injection	

# Event 5: S/G Tube Leakage on "A" S/G AP/04 Evaluation – Rapid Downpower

Time	Pos.	Expected Actions/ Behavior	Comments
	SRO	Go to EP/E-0 and directs activities	
	SRO	Reviews Foldout page with crew	
	RO	Report Reactor Trip: • rod bottom lights • reactor trip breakers open • I/R amps decreasing	
	RO	<ul> <li>Reports Turbine Generator tripped</li> <li>TV's or GV's closed</li> </ul>	
	BOP	Reports ETA and ETB energized	
	RO	Reports SI status light - LIT	
	BOP	Report LOCA sequencers (A & B) actuated	
	SRO/ RO	Announce "Unit 1 Safety Injection" on page	
	BOP	Checks ESF Monitor Light Panel • Groups 1,2 and 5 DARK • Group 3 LIT • Checks OAC in service	If not already recognized the crew should initiate feedwater isolation.
	BOP	Reports all Ss and St components in Group 4 NOT -LIT	
	RO	Reports that CA is running and at least 3 S/G's NR level > 17%	
	BOP	Reports KC pumps running	
	BOP	Reports RN pumps running	

•

# Event: SGTR "A" S/G

\_\_\_\_

•

Time	Pos.	Expected Actions/ Behavior	Comments
	SRO	Directs Unit 2 Operator to throttle RN to minimum & start 2A RN pump	EXAMINER CUE: • 2A RN pump is running
	RO Checks/reports all S/G pressures > 775 psig		
	BOP	Reports Containment pressure has remained less than 3 psig	
BOP Report NV Pump to Cold Leg Flow gauge - indicating flow - YES • checks NC pressure < 1600 psig • checks NI pumps indicating flow - NO		Report NV Pump to Cold Leg Flow gauge - indicating flow - YES checks NC pressure < 1600 psig checks NI pumps indicating flow - NO	Crew will ensure ND pump mini-flow valves are open
	SRO	When available notifies OSM or other SRO to implement Generic Enclosure 22	EXAMINER CUE: OSM will ensure Generic Enclosure 22 implemented.
	RO	<ul> <li>Checks CA flow &gt; 450 gpm and takes control of CA to maintain no load levels</li> <li>checks VI header pressure &gt; 60 psig</li> <li>Maintains N/R level between 11% and 50%</li> </ul>	
	BOP	Checks NC pumps ON and Tave stable or trending to 557 degrees	If not stable and decreasing crew will go to Enclosure 3
	BOP Reports Pzr PORV & Spray Valves closed		
	BOP Reports subcooling > 0 deg.		
	BOP	Reports all main steamlines INTACT	
	RO/ BOP	Report S/G tube rupture parameters indicate that S/G tubes NOT intact	Implements F-0 and E-3

Time	Pos.	Expected Actions/ Behavior	Comments
	SRO	Implement CSF Status Trees and go to EP/E-3	
	SRO	Go to EP/E-3 and directs activities	
	SRO	Monitor foldout page	
	RO/ BOP	Identify "A" as the ruptured S/G	
	RO	Check at least one S/G - AVAILABLE FOR NC SYSTEM COOLDOWN	
	RO	Isolate steam flow from ruptured S/Gs as follows: checks ruptured S/G PORV closed	
· · · · · · · · · · · · · · · · · · ·	RO	Check S/G 1B and 1C INTACT	
	RO	Check blowdown isolation valves - CLOSED: • 1BB- 1B • 1BB- 5A	
	BOP	Close steam drain and check "CLSD" light lit for ruptured S/Gs: • 1SM-83A (A SM Line Drain)	
Critical	RO	Close the following on ruptured S/Gs: MSIV MSIV bypass valve	<ul> <li>MSIV on ruptured S/G will not close.</li> <li>RO will close other S/G</li> <li>MSIVs</li> <li>MSIV bypass valves</li> <li>steam dumps</li> <li>Close SM-14,SM-15,AS-12,TL-3</li> <li>SP1 and SP2</li> <li>Dispatch an operator to isolate steam line drains per enclosure 4</li> <li>When cooldown is initiated in subsequent steps then use intact S/G PORVs for steam dump.</li> </ul>

#### Event 6: SGTR on "A" Steam Generator

.

Event:	Pos.	Expected Actions/ Behavior	Comments
	RO	Checks ruptured S/G NR levels greater than 11% Isolates feed flow to "A" S/G Close 1CA-66AC Close 1CA-62A	
	BOP	<ul> <li>Checks Pzr PORV and isolation valves:</li> <li>Power to all Pzr PORvs available</li> <li>All Pzr PORVs CLOSED</li> <li>At least one Pzr PORV isolation valve OPEN</li> </ul>	
	RO	Checks main stream lines intact: • All S/G pressures stable or going up • All S/G pressurized	
	BOP	Reset the following: • S/I • Sequencers • Phase A isolation • Phase B isolation	
	BOP	Established VI to containment 1VI-129B open 1VI-160B open 1VI-150B open Checks VI header pressure > 85 psig.	
	RO	<ul> <li>Controls intact S/G levels:</li> <li>N/R level in all intact S/Gs &gt; 11%</li> <li>Throttles feed flow to maintain intact S/Gs N/R levels between 22% and 50%</li> </ul>	
	BOP	Checks 1ETA and 1ETB energized by offsite power	
	SRO	Checks ruptured S/G identified	
	SRO	<ul> <li>Checks the following closed on ruptured S/G:</li> <li>MSIV</li> <li>MSIV bypass valve</li> </ul>	NO, MSIV open
	SRO	Checks ruptured S/G pressure greater than 280 psig.	

## Event: STGR on "A" S/G

Time	Pos.	Expected Actions/ Behavlor	Comments
	SRO	Checks any NC pump running	
	SRO	When P-11 status light lit then block steamline isolation and maintain NC pressure less than 1955 psig.	
Critical	RO	Initiate a NC system cooldown as follows: Determine required core exit temperature based on lowest ruptured S/G pressure. • COND AVAILABLE FOR STEAM DUMP" status light – LIT • MSIV on intact S/Gs OPEN	<ul> <li>NO</li> <li>If Pzr pressure is greater than 1955 psig, then depressurize to 1900 psig using Pzr PORV.</li> <li>Depress "BLOCK" on low pressure steamline isolation block switches.</li> <li>Maintain NC pressure less than 1955 psig.</li> <li>Ensure Main Steam Isolation reset.</li> <li>Ensure S/G PORVs reset.</li> <li>Dump steam using all intact S/Gs PORVs at maximum rate as follows:</li> <li>Close S/G PORV manual loader on ruptured S/G</li> <li>Place intact S/G PORV manual loaders at 50%</li> <li>Select "MANUAL" on "SM PORV MODE SELECT"</li> <li>Adjust manual loader on intact S/G PORVs as required to control intact S/G depressurization rate at an experimental with a pair papended.</li> </ul>
		<ul> <li>Check low pressure steamline isolation – BLOCKED</li> <li>Check core exit T/Cs – less than required temperature.</li> <li>Stop NC system coodown</li> <li>Maintain core exit T/Cs less than required temperature.</li> </ul>	approximately 2 paig per second.
	SRO	Checks ruptured S/G pressure – stable or going up	
	SRO	Checks NC subcooling based on core exit T/Cs > than 20 degrees	

.

Time	Pos.	Expected Actions/ Behavior	Comments
	BOP	<ol> <li>Depressurizes the NC system</li> <li>Checks ruptured S/G NR level less than 73%</li> <li>Checks normal Pzr spray available</li> <li>Initiates NC depressurization using maximum spray</li> <li>Do not continue in procedure until one of the following satisfied:</li> <li>NC subcooling less than 0 degrees</li> <li>Pzr level greater than 76%</li> <li>Or</li> <li>Both of the following</li> <li>NC pressure less than ruptured S/G pressure</li> </ol>	If crew uses PORV go to step 21.
		Pzr level greater than 11% Go to step 23	
	Crew	Checks for S/I termination criteria 1. NC subcooling greater than 0 degrees 2. Secondary heat sink 3. NC pressure – stable or going up 4. Par level greater than 11%	Must meet all criteria to terminate.
	BOP	<ul> <li>Stop S/I pumps as follows:</li> <li>NI pumps</li> <li>All but one NV pump</li> </ul>	
	BOP	<ul> <li>Isolate NV S/I flowpath</li> <li>Check NV pump – SUCTION ALIGNED TO FWST</li> <li>Check the following valves OPEN: 1NV-150B 1NV-151A</li> <li>Close the following valves: 1NI-9A 1NI-10A</li> </ul>	
		STOP SCENARIO HERE	
		TERMINATE SCENARIO AT DIRECTION O	F CHIEF EXAMINER

# EXAMINER NOTE: Be sure SRO classifies event at end of scenario.

Classification of event: Site Area Emergency

#### SHIFT TURNOVER INFORMATION

# UNIT 1 STATUS: NCS [B] 866 ppm Pzr [B]: 865 ppm Xe: Per OAC {PRIVATE 55% }Power Level: {PRIVATE Reduced power to 20% to add Oil to Core Burnup: 200 EFPDs }Power History: "D" reactor coolant pump. CONTROLLING PROCEDURE: OP/1/A/6100/03 Controlling Procedure for Unit Operation enclosure 4.1 step 3.21. OTHER INFORMATION NEEDED TO ASSUME TO SHIFT: "1A" Diesel Generator tagged for maintenance. "1A" Auxiliary Feedwater pump tagged - PM Unit 2 is available for auxiliary steam. Continue load increase at 2 MW/Min. Conditioned power level 100%. Work Control SRO/Offsite Communicator Thad Unit 2 SRO Jim **NLO's AVAILABLE** Unit 2 Unit 1 Aux Bldg. Joe Aux Bldg. Robb Turb/Service Bldg. Mike Turb Bldg. Fred Extra(s) Bill, Craig, Russ, Ron

Appendix D

Scenario Outline

Form ES-D-1

Op-test No.:

Facility: McGuire

Examiners:

Scenario No.: Spare

Operators:

Objectives: 1) Diagnose failures that are not readily understood such as letdown back pressure instrument and charging line leak. 2)Deal with a small steam generator tube leak after a large steam line break. This exercise will give the candidates opportunity to exercise a variety of AOPs and EOPs.

Initial Conditions: 70% Power/ Increasing Load/ "B" Train Component in service

Turnover: "A" D/G inoperable/ "A" CA pump tagged/Unit 2 is available for auxiliary steam/ Begin load increase to 100%.

Event No.	Malf. No.	Event Type*	Event Description	
1		N	Load Increase	
1		R	Rod Withdrawal/Dilution	
2		BOP	Letdown Back pressure Instrument Failure	
3		RO	Steam Generator Narrow Level Instrument fails low	
4		BOP	Charging Line Leak	
5		RO	Power Mismatch Circuit Failure	
б		M(ALL)	Steam Leak becomes Steamline Break Inside Containment with a SGTR	
		<u> </u>		
		<u>+</u>		
	<u> </u>	<u>+</u>	Post Major Event Malfunctions	
	<u> </u>	<u>+</u>	No automatic spray actuation	
			No Auto Main Steam Isolation - done manually	
	<u> </u>	1	Tube Leak on Faulted Steam Generator	
	<u> </u>	1	No automatic safety injection	
	<b> </b>	+		

(N)ormal, R)eactivity, (I)nstrument, (C)omponent, (M)ajor

NUREG 1021, Revision 8



## PROGRAM: McGuire Operations Training

- MODULE: Initial License Operator Training Class 20
- TOPIC: Nuclear Regulatory Commission Simulator Exam

Spare Scenario

#### **REFERENCES**:

- McGuire Technical Specifications
   AP/1/A/5500/06 Loss of S/G Feedwater
- 3. AP/1/A/5500/12 Loss of Letdown, Charging or Seal Injection
- 4. AP/1/A/5500/14 Rod Control Malfunction
- 5. AP/1/A/5500/10 NC System Leakage Within Capacity of Both Charging Pumps
- 5. EP/1/A/5000/E-0 Reactor Trip or Safety Injection
- 6. EP/1/A/5000/E-2 Faulted Steam Generator Isolation
- 7. EP/1/A/5000/E-3 Steam Generator Tube Rupture
- 8. EP/1/A/5000/FR-Z.1 Response to High Containment Pressure
- 9. RP/O/A/5700/000 Classification of Emergency

Author: Facility Review: NRC Review"

December 6, 2001 Rev.1



# SIMULATOR OPERATOR INSTRUCTIONS



. .

Bench Mark	ACTIVITY	DESCRIPTION
Sim. Setup	Rod Step On	
	IC-144	
	RUN	
	Update Status Board,	See Shift Turnover Information
	Setup OAC	
	Setup ICCM, Turbine Displays, & Trend Recorders.	
	Check Rod Step Counters agree with rod positions	
	(M) EPQ001A	Loss of D/G "1A" Control Power
	Set = Rack Out	
	(LOA) CA009	Rackout breaker for "1A" Auxiliary Feedwater Pump
	Set = Racked Out	
	(MAL) ISE006A	Blocks auto main steam isolation
1	(MAL) ISE006B	
	Block auto	
	(MAL) ISE004B	Failure of Phase "B" train "B" to actuate
	Block auto	
	(M) ISE002A	Failure of automatic Safety Injection – both trains
	(M) ISE002B	



Ē	Bench Mark	ACTIVITY	DESCRIPTION				
Ē	<u>ן</u>	Freeze.					
		Update Fresh Tech. Spec. Log.					
C	ם	Fill out the NLO's Available section of Shift Turnover Info.					
C	Prior to Crew Briefing	RUN					
	<ol> <li>Assign Crew</li> <li>Review the S</li> <li>Direct the cre</li> </ol>	Crew Briefing         1. Assign Crew Positions based on evaluation requirements         2. Review the Shift Turnover Information with the crew.         3. Direct the crew to Review the Control Boards taking note of present conditions, alarms.					
C	] Т-О	Begin Familiarization Period					
	At direction of examiner	(XMT) NV030 Set = 0	Fails NV letdown back pressure regulator – causes a loss of letdown				
C	At direction of examiner	(XMT) CF020 Set = 0 Ramp = 5	Steam Generator "B" Narrow Range Instrument Fails				
Ē	At direction of examiner	(MAL) NV008C Ramp = 10 Set = 25	Initiates leak on charging line				

\_\_\_\_

\_

. .



\_\_\_\_\_\_

	Bench Mark	ACTIVITY	DESCRIPTION
	At direction of	(MAL) IRE001	Power Mismatch Circuit Failure
	examiner	Set = 557	
	At direction of	(MAL) SM007A	Initiates a Steam Leak
	examiner	Set = 3e4	
		Ramp 200	
	At direction of examiner	(MAL) SM007A	Initiates Steam Break
		Set = 4e6	
		Set to trigger 1	Initiates a SGTR
		(MAL) SMUUTA	
		Set to trigger 1	
		Set to trigger i	
		Terminate the scenar	io upon direction of Chief Examiner
L			



# EVENT: Normal Operations – Turbine Load Decrease

Time Pos.	Expected Actions/ Behavior	Comments
SRO	Notifies SOC of load increase	
RO		
SRO	Increases load per OP/1/A/6300/001A and	
RO	OP/1/A/6100/03	
	Determines load changing rate	
RO	Depress the "LOAD RATE" pushbutton	
RO	Set the selected rate of load change in the "Variable Display" window	
RO	Depress the "ENTER" pushbutton	
RO	Depress the "REFERENCE" pushbutton	
RO	Set in the desired load	
RO	Depress the "ENTER" pushbutton	· · · · · · · · · · · · · · · · · · ·
RO	Depress the "GO" pushbutton	
RO	Verify that the load starts to change at the selected rate	

Event: Normal Operations Rod Insertion

Time.	Pos.	Expected Actions/ Behavior	Comments
	SRO	<ul> <li>Provide guidance to RO on expectations for rod withdrawal on load increase.</li> <li>maintains control rods within insertion limits</li> <li>AFD within target band</li> </ul>	SRO should provide some general guidance as to using rods to maintain Tave within a pre-determined range of Tref.
	RO	Will withdraw rods as necessary based on instructions from SRO	
	BOP	Will dilute NC system per guidance provided	



I DEPENDENCE	COMPAREMENTS		And the second of the second states in the second
	Pop	Expected Actions/ Benavior	
	SRO	Enters AP/12 Loss of Letdown, Charging or Seal Injection	
	BOP	On a loss of letdown ensure the following	Immediate action step
		• 1NV-458A	
		• 1NV-457A	
		• INV-35A	
:	BUP	If at any time "REGEN HX LETDN HI TEMP" alarms, close:	BOP will take action it appropriate
		• 1NV-1A	
		• 1NV-2A	
	RO	Stop and power or temperature changes in progress	
	RO	Announces occurrence on page	·
	BOP	Checks "1B" NV pump - ON	
	BOP	Checks to following NV pump parameters stable:	
		Motor AMPs	
		Charging header pressure	
		Charging flow	
	BOP	Checks seal injection flow parameters:	
		Seal flow to each NC pump > 6 gpm	
		<ul> <li>Seal Water Inj Filter Hi D/P alarm - DARK</li> </ul>	
	SRO	IF this AP entered due to loss of letdown only, then go to step 35.	SRO will go to step 35 in this AOP
	BOP	Ensures "NC Sys M/U Controller" in AUTO	
	BOP	Ensures charging flow going down to maintain Pzr at program level	
	SRO	NOTE: A failure of the letdown pressure instrument may cause loss of letdown.	
	BOP	Checks "Letdn Relief Hi Temp" alarm has remained dark	No, crew should evaluate note prior to step 37.
	BOP	Checks 1NV-21A - closed	

#### Event: Letdown Back Pressure Instrument Failure







# Event: Letdown Backpressure Instrument Failure

である	Po	Expected Actions/ Behavior	Comments
<u> </u>	BC	P Checks Pzr heater group supply breakers – closed YES	
	BC	<ul> <li>P Checks the following OPEN</li> <li>1NV-2A</li> <li>1NV-2A</li> </ul>	NO, go to step 42
	SĒ	<ul> <li>Checks to see if immediate restoration of normal letdown is possible</li> <li>Both NV 1 &amp; 2 open in the past 30 minutes</li> <li>Orifice isolation valves closed before or at the same time as NV 1 &amp; 2.</li> </ul>	res, go to step 46.
	BC	<ul> <li>P Establish normal letdown</li> <li>1. Ensures 1NV-459 is closed</li> <li>2. Place 1NV-124 in manual between 10-20% open</li> <li>3. Establish cooling to Regenerative Hx by performing the following concurrently:</li> <li>Throttle open 1NV-238</li> <li>Throttle 1NV-241 to establish approximately 8 gpm seal injection</li> <li>4. Check the following OPEN</li> <li>1NV-1A</li> <li>1NV-2A</li> <li>5. Open letdown line isolation valves:</li> <li>1NV-7B</li> <li>1NV-7B</li> <li>1NV-2A</li> <li>1NV-35A</li> <li>1. Establish desired letdown rate by completing the following concurrently:</li> <li>Slowly throttle open 1NV-459</li> <li>Adjust 1NV-124 to maintain letdown pressure between 250 and 350 psig.</li> <li>2. Do not continue until desired flow rate is established.</li> <li>3. Adjust charging flow as desired</li> <li>4. Crew may stay on variable orifice or swap to 75 gpm orifice.</li> </ul>	Crew should determine normal letdown control is not available and establish excess letdown. 1. Opens the following • 1KC-315 • 1KC-305 2. Places 1NV-27B to VCT position 3. Opens and closes 1NV-26 4. Checks to following OPEN • 1NV-94 • 1NV-95 5. Opens 1NV-24 and 1NV-25 6. Stowly opens 1NV-26 7. Notifies chemistry that excess letdown is in service.
ŀ	SF	C End of Procedure	
1			

7

Time	Pos.	Expected Actions/ Behavior	cue Commenta
	BOP	Refer to annunciator responses	Per annunciator response and AP/06
		• A-3	operable channel
		• B-3	
	RO	Places Feed Regulator to Manual	Immediate Action step
		Restores S/G level to program level	
	RO	Checks the following channel indicating the same:	Immediate Action step
		Feed flow	
		Steam Flow	
		S/G Level	
	RO	Checks S/G CF control valve in manual control	YES
	RO	When the following are met then return affected S/G CF control to automatic	
		1. Selected control channels indicated correctly	
		Feed flow	
		<ul> <li>Steam flow</li> </ul>	
		• S/G level	
		2. Affected S/G level restored to program level	
		3. Automatic control is desired	
	SRO	Checks the reactor tripped	NO
	RÖ	Maintains S/G level	Go to step 7
	RO	Controls feed flow to maintain S/G NR level - at programmed level	
	SRO	Checks NC temperature with NC pumps on stable or trending to programmed temperature	
	SRO	Checks procedure enter due to failed controller	
	SRO	Contacts I&E to repair failed controller	Failure will not be repaired
		Exit procedure	

# Event 2: Steam Generator "B" Narrow Range Level Failure







Time Pos.	Expected Actions/ Behavior	Comments
BOP	Report either of the following: Pzr level decreasing Pzr press decreasing Containment Vent Isol (EMF39) "Ice Cond Doors Open" Annunciator	
SRO	Go to AP/10 (Case II) NC System Leakage and directs activities	
BOP	Report Pzr Level decreasing: Report NV-238 opening Open NV-241 while maintaining 6 gpm Seal Injection Flow Starts alternate NV Pump Reduce letdown to 45 gpm or isolate letdown *If Pzr level less than 11% then: Manually Trip Reactor Manually SI	
RO	Announce Occurrence on page	
SRO	If Pzr level can not be maintained go to step 1	
SRO	If location of leak is known, than initiate actions to isolate leak.	Crew may go to step 18
ВОР	Reports Pzr Pressure at or increasing to 2235 psig	
RO	Reports Main Steam line is INTACT • Reactor power at turbine power • NC loop T-Ave is stable	
SRO	Refer to RP/000	
SRO	Ensures OP/O/A/6450/11 done if NC leakage exceeds Tech Spec leakage	
SRO	Ensures VCT aligned to FWST if VCT level goes below 16%	

# Event 3: NC System Leakage – Charging Line Leak AP-10 Evaluation



.

Time	Pos.	Expected Actions/Behavior	Comments & A water
	BOP	Checks the following EMFs normal:	
		• 1EMF-38L	
		• 1EMF-39L	
		• 1EMF-40	
		• 1EMF-41	
		• 1EMF-46A	
		• 1EMF-46B	
	BOP	Checks NC pump thermal barrier KC outlet flow computer alarms NORMAL	GO to step 17
	SRO	If leak is suspected on letdown line near demineralizers	It should not be suspected there.
	SRO	If leak on letdown line, then isolate leak as follows:	Leak is not on letdown line.
		If leak is on normal charging line then isolate as follows:	
		1. close letdown isolation valves	
		• 1NV-458A	
		• 1NV-457A	
		• 1NV-35A	
		• 1NV-1A	
		• 1NV-2A	
		2. Isolate charging:	
		Close 1NV-244A	
		Close 1NV-245B	
		<ul> <li>Manually throttle 1NV-238 to maintain 6-10 gpm seal injection flow per NC pump.</li> </ul>	Crew should have already established excess letdown
	SRO	Checks the following NORMAL:	
		Pzr Safeties	
		Pzr PORvs	
		PRT Conditions	
	SRO	Checks CLAs level NORMAL	
	SRO	Checks the NCDT NORMAL	······································
	SRO	Checks the containment floor and equipment sumps NORMAL	





-

\_...

ine: Pos	Expected Actions/ Behavior
SRO	Checks VCT intact
SRO	Checks NV pump suction – aligned to VCT
SRO	Verifies leak has been identified
SRO	Verifies leak has been isolated.
SRO	Exits procedure

## Event 4: Power Mismatch Circuit Failure

Time Po	e Expected Actions/ Behavior	Comments
R	<ul> <li>Recognizes Unwarranted Control Rod Insertion and informs Crew.</li> <li>No turbine or reactor power excursion</li> <li>Tref normal</li> </ul>	
R	O If more than one rod dropped – trip Rx	
R	O Places CRD Bank Selector Switch to manual and verifies movement stopped	RO places Rods in Manual
SF	O Enters AP/14, Rod Control Malfunctions and directs activities.	
R	<ul> <li>Perform the following to maintain T-colds 555 to 557 degrees.</li> <li>Lower turbine load or raise T-cold Or</li> <li>Borate the NC system to lower T-cold</li> </ul>	
R	Announce occurrence on paging system	
R	O Check all control banks aligned with associated bank	
R	O Checks Rod Control Urgent Failure alarm DARK	
R	<ul> <li>Checks to following reactor control instruments NORMAL</li> <li>Turb Imp Press Ch 1</li> <li>T-ref indication</li> <li>"1A" NC loop T-ave</li> <li>"1B" NC loop T-ave</li> <li>"1C" NC loop T-ave</li> <li>"1D" NC loop T-ave</li> </ul>	
R	Check Nuclear power P/R Channels - NORMAL	
SR	O Will go to enclosure 4 based on unwarranted rod movement.	
CRE	<ul> <li>W Evaluates the following prior to any control rod withdrawal:</li> <li>Ensures no inadvertent mode change will occur.</li> <li>Ensures rods are withdrawn in a deliberate manner.</li> </ul>	

#### Event 4: Power Mismatch Failure



lime IRO	Expected Actions/ Behavior	Comments .
RO	Checks the following normal: Turb Imp Press Ch 1 T-ref indication	
BOF	Checks the following channels - NORMAL	
SRC	Checks if failed channel – HAS BEEN IDENTIFIED.	
RO	When the problem is repaired then Ensure T-ave at T-ref +/- 1 degree and auto rod control is desired, then return rod control to auto.	
SRC	Exits procedure	



# Event: Steam Line Break Inside Containment with SGTR

E-0 Evaluation

Time Rost	Expected Actions/ Behavior	Cômments
SRO	Go to EP/E-0 and directs activities	
SRO	Reviews Foldout page with crew	
RO	Report Reactor Trip: • rod bottom lights • reactor trip breakers open • I/R amps decreasing	
RO	Reports Turbine Generator tripped     TV's or GV's closed	
BOP	Reports ETA and ETB energized	
RO	Reports SI status light - LIT	
BOP	Report LOCA sequencers (A & B) actuated	
SRO/ RO	Announce "Unit 1 Safety Injection" on page	
ВОР	Checks ESF Monitor Light Panel Groups 1,2 and 5 DARK Group 3 LIT Checks OAC in service	Crew should take actions to correct Phase "B" alignment.
BOP	Reports all Ss and St components in Group 4 NOT -LIT	
RO	Reports that CA is running and at least 3 S/G's NR level > 17%	
BOP	Reports KC pumps running	
ВОР	Reports RN pumps running	



## Event: Steam Line Break Inside Containment

-

Time		Expected/Actions/ Behavion	Commenta
	SRO	Directs Unit 2 Operator to throttle RN to minimum & start 2A RN pump	EXAMINER CUE: • 2A RN pump is running
	RO	Checks/reports all S/G pressures > 775 psig	
	BOP	Reports Containment pressure has remained less than 3 psig	NO
	BOP	Report NV Pump to Cold Leg Flow gauge - indicating flow - YES checks NC pressure < 1600 psig checks NI pumps indicating flow - NO	
	SRO	When available notifies OSM or other SRO to implement Generic Enclosure 22	
	RO	<ul> <li>Checks CA flow &gt; 450 gpm and takes control of CA to maintain no load levels</li> <li>checks VI header pressure &gt; 60 psig</li> <li>Maintains N/R level between 11% and 50%</li> </ul>	
	BOP	Checks NC pumps ON and Tave stable or trending to 557 degrees	If not stable and decreasing crew will go to Enclosure 3
	BOP	Reports Pzr PORV & Spray Valves closed	
	BOP	Reports subcooling > 0 deg.	
	BOP	Reports all main steamlines INTACT	NO, crew will go to E-2 and implement F-0 – Crew should go to Z-1


## Event: Steamline Break Inside Containment with SGTR

Z -1 Evaluation

Time	052	Expected Actions/ Behavior	Comments
CR	εw	If loss of emergency coolant recirc has occurred, THEN this procedure may be completed as time allows.	
CR	REW	Monitors foldout page	
В	OP	Stop all NC pumps	
B	OP	Ensure all RV pumps are in manual and off.	
SF	RO	Dispatch an operator to remove tags and close breakers for the following valves:	
		• 1NI-178B	
ВС	OP	Checks containment pressure - LESS THAN 15 PSIG.	
BC	OP	Check any NS pump - ON	
SF	20	The remainder of this EP may be performed as time allows.	



Tíme	Pos.	Expected Actions/ Behavior	Comments
	Crew	Monitors foldout page	
	Crew	Maintains one S/G available for NC system cooldown	
	SRO	Checks the following closed:	
		• All MSIVs	
		All MSIV Bypasses	
	SRO	Check at least one S/G pressure – stable or going up	
	RO	Identifies faulted S/G;	
		<ul> <li>Any S/G pressure – going down in an uncontrolled manner</li> </ul>	
		Any S/G depressurized	
	RO	Checks faulted S/G PORV closed	
	RO	Isolates faulted S/G as follows for "A" S/G:	
		<ul> <li>Check S/G A FDW Isolated status light LIT</li> </ul>	
		Close 1CA-66A	
		Close 1CA-62A	
		<ul> <li>Check closed 1BB-1A &amp; 1BB-5A</li> </ul>	
		Close 1SM-83	
	SRO	Checks if S/G tubes INTACT	NO, 1EMF-24 will indicated a tube leak
		Checks EMFs normal	
		• 1EMF-24	
		• 1EMF-25	
		• 1EMF-26	
		• 1EMF-27	
	SRO	Go to EP-E-3 Steam Generator Tube Rutpure	

#### Event: Steam Line Break Inside Containment E-2



# Event: STGR on "A" S/G E-3 Evaluation

Time	Pos.	Expected Actions/ Behavior Comments
	SRO	Implement CSF Status Trees and go to EP/E-3
	SRO	Go to EP/E-3 and directs activities
	SRO	Monitor foldout page
	RO/ BOP	Identify "A" as the ruptured S/G
	RO	Check at least one S/G - AVAILABLE FOR NC SYSTEM COOLDOWN
	RO	Isolate steam flow from ruptured S/Gs as follows: • checks ruptured S/G PORV closed
	RÖ	Check S/G 1B and 1C INTACT
	RO	Check blowdown isolation valves - CLOSED: • 1BB- 1 • 1BB- 5
	BOP	Close steam drain and check "CLSD" light lit for ruptured S/Gs: • 1SM-83 (A SM Line Drain)
	RO	Close the following on ruptured S/Gs: MSIV MSIV bypass valve
	RO	Checks ruptured S/G NR levels greater than 11% (32% ACC) Isolates feed flow to "D" S/G Closed 1CA-66A Closed 1CA-62A



---

Event: SGTR on "D" Steam Generator

<b>)</b>

Event:	Pos:	Expected Actions/ Behavior	Commenta
	BOP	Checks Pzr PORV and isolation valves: Power to all Pzr PORvs available All Pzr PORVs CLOSED At least one Pzr PORV isolation calve OPEN	
	RO	<ul> <li>Checks main stream lines intact:</li> <li>All S/G pressures stable or going up</li> <li>All S/G pressurized</li> </ul>	NO, "A" depressurizing or depressurized
	BOP	Reset the following: • S/I • Sequencers • Phase A isolation • Phase B isolation	
	BOP	Established VI to containment • 1VI-129B open • 1VI-160B open • 1VI-150B open • Checks VI header pressure > 85 psig.	
	RO	<ul> <li>Controls intact S/G levels:</li> <li>N/R level in all intact S/Gs &gt; 11% (32% ACC)</li> <li>Throttles feed flow to maintain intact S/Gs N/R levels between 22% and 50%</li> </ul>	
	BOP	Checks 1ETA and 1ETB energized by offsite power	
	SRO	Checks ruptured S/G identified	
	SRO	Checks the following closed on ruptured S/G: MSIV MSIV bypass valve	
	SRO	Checks ruptured S/G pressure greater than 280 p <del>s</del> ig.	NO, crew should go to ECA 3.1

Note to Examiner: Be sure SRO classifies event at end of scenario.

Classification of Event: Site Area Emergency



#### SHIFT TURNOVER INFORMATION



### UNIT 1 STATUS:

 Power Level:
 100%
 NCS [B]
 66 ppm
 Pzr [B]:
 66 ppm
 Xe:
 2895pcm

 Power History:
 At this power for 400 days
 Core Burnup:
 440 EFPDs

CONTROLLING PROCEDURE: OP/1/A/6100/03 Controlling Procedure for Unit Operation

## OTHER INFORMATION NEEDED TO ASSUME TO SHIFT:

"1A" Diesel Generator tagged for maintenance. "1A" Auxiliary Feedwater Pump Tagged for PM Unit 2 is available for auxiliary steam

Begin load reduction to take the plant to mode 6 to begin refueling outage. Reactor group has determined it will take 300 gallons of boric acid for the shutdown. Insert 50 gallons of acid to begin shutdown and use rods for AFD control. Begin load reduction at 2 MW/min.



Work Control SRO/Offsite Communicator	Thad
Unit 2 SRO	Jim
NLO's AVAILABLE	
<u>Unit 1</u>	<u>Unit 2</u>
Aux Bldg. Eric	Aux Bldg Bill
Turb Bidg. Fred	Turb/Service Bldg Buster
Extra(s) Mark, Bruce	

