

August 27, 1998

Mr. Roger O. Anderson, Director
Nuclear Energy Engineering
Northern States Power Company
414 Nicollet Mall
Minneapolis, Minnesota 55401

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINAL FINDING OF NO SIGNIFICANT
IMPACT - MONTICELLO NUCLEAR GENERATING PLANT (TAC NO. M96238)

Dear Mr. Anderson:

Enclosed is a copy of an "Environmental Assessment and Final Finding of No Significant Impact" related to a proposed amendment to Facility Operating License No. DPR-22 for the Monticello Nuclear Generating Plant (MNGP). The assessment is based on the information provided in your amendment request dated July 26, 1996, as revised December 4, 1997. The amendment would change the maximum reactor core thermal power level specified in the Facility Operating License from 1670 megawatts-thermal (MWt) to 1775 MWt (an increase of 6.3 percent) as part of the MNGP's power rerate program. The staff's draft environmental assessment was published in the *Federal Register* on January 27, 1998 (63 FR 3929), for public comment. No comments were received.

This final environmental assessment and finding of no significant impact is being forwarded to the Office of the Federal Register for publication.

Sincerely,

ORIGINAL SIGNED BY

Tae Kim, Senior Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-263

Enclosure: Environmental Assessment

cc w/encl: See next page

DISTRIBUTION:

Docket File	PUBLIC	MMalloy
PD#3-1 Reading	EAdensam	OGC
ACRS	MKunowski, RIII	CCraig

DOCUMENT NAME: G:\WPDOCS\UPRATE\MON96238.EA *See previous concurrence
To receive a copy of this document, indicate in the box C=Copy w/o attachment/enclosure E=Copy with attachment/enclosure N = No copy

OFFICE	PM:PD31	E	LA:PD31	E	PGE*	OGC*	D:PD31	E
NAME	TJKim:db		CJamerson		RArchitzel for TEssig	MYoung	CACarpenter	
DATE	08/26/98		08/26/98		08/26/98	08/20/98	8/26/98	

OFFICIAL RECORD COPY

9809030213 980827
PDR ADOCK 05000263
P PDR

Mr. Roger O. Anderson, Director
Northern States Power Company

Monticello Nuclear Generating Plant

cc:

J. E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N. W.
Washington DC 20037

Kris Sanda, Commissioner
Department of Public Service
121 Seventh Place East
Suite 200
St. Paul, Minnesota 55101-2145

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
2807 W. County Road 75
Monticello, Minnesota 55362

Adonis A. Neblett
Assistant Attorney General
Office of the Attorney General
445 Minnesota Street
Suite 900
St. Paul, Minnesota 55101-2127

Plant Manager
Monticello Nuclear Generating Plant
ATTN: Site Licensing
Northern States Power Company
2807 West County Road 75
Monticello, Minnesota 55362-9637

Mike McMullen [5]
Environmental Review Coordinator
EPA Region 5
77 West Jackson Boulevard
Chicago, IL 60604-3507

Robert Nelson, President
Minnesota Environmental Control
Citizens Association (MECCA)
1051 South McKnight Road
St. Paul, Minnesota 55119

Commissioner
Minnesota Pollution Control Agency
520 Lafayette Road
St. Paul, Minnesota 55119

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Commissioner of Health
Minnesota Department of Health
717 Delaware Street, S. E.
Minneapolis, Minnesota 55440

Darla Groshens, Auditor/Treasurer
Wright County Government Center
10 NW Second Street
Buffalo, Minnesota 55313

UNITED STATES NUCLEAR REGULATORY COMMISSION
NORTHERN STATES POWER COMPANY
DOCKET NO. 50-263
MONTICELLO NUCLEAR GENERATING PLANT
ENVIRONMENTAL ASSESSMENT AND FINAL FINDING OF
NO SIGNIFICANT IMPACT

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. DPR-22, issued to Northern States Power Company (NSP), for operation of the Monticello Nuclear Generating Plant (MNGP) located in Wright County, Minnesota.

ENVIRONMENTAL ASSESSMENT

Identification of the Proposed Action:

By letter dated July 26, 1996, as revised December 4, 1997, NSP requested an amendment to License No. DPR-22 for MNGP that would increase the maximum power level from 1670 megawatts-thermal (MWt) to 1775 MWt. This change is approximately 6.3 percent above the current maximum license power level and is considered an extended power rerate.

The Need for the Proposed Action:

NSP has projected the need for additional generation resources through a comparison of needs to available resources. NSP has projected a shortfall of generating capacity in the future. The proposed action would provide increased reactor power, thus adding an additional 26 MW of reliable electrical energy generating capacity without major hardware modifications to the plant. Hardware changes are not needed because of improvements in technology, performance, and design. These improvements have resulted in a significant increase in the

difference between the calculated safety analysis results and licensing limits established by the original license.

Environmental Impacts of the Proposed Action:

The issuance of the operating license for MNGP stated that any activity authorized by the license is encompassed by the overall action evaluated in the Final Environmental Statement (FES), which was issued in November 1972. The license for MNGP allowed a maximum reactor power level of 1670 MWt. NSP submitted an environmental evaluation supporting the proposed power rerate action and provided a summary of its conclusions concerning both the radiological and nonradiological environmental impacts of the proposed action. The evaluations performed by the licensee concluded that the environmental impacts of power rerate are well bounded or encompassed by previously evaluated environmental impacts and criteria established by the staff in the FES. A summary of the nonradiological and radiological effects on the environment that may result from the proposed amendment is provided below.

Nonradiological Impacts

Land Use

Power rerate does not modify land use at the site. No new facilities, access roads, parking facilities, laydown areas, or onsite transmission and distribution equipment, including power line right of way, are needed to support the rerate or operation after rerate. No change to above or below ground storage tanks would occur as a result of power rerate and the rerate does not affect land with historical or archeological sites.

Based on the operating history at the MNGP, the effects of drift, icing, and fog have been negligible. The frequency of fog and drift were provided by the licensee at the time of original licensing and the impacts of that frequency of drift and fog are bounded by the

evaluation contained in the FES. The FES assumed cooling tower operation of 7 months, with the total fogging time estimated at 45 hours per year. If the cooling tower fogging rate is assumed to increase proportional to the proposed power increase, the amount of fogging due to power rerate could increase by approximately 6.3 percent above the normal summer operating period of 4 months. Additionally, the licensee determined that power rerate may involve an extra week of cooling tower operation. Taking into account the additional fogging rate and the additional cooling tower operation, the conditions at power rerate are still bounded by the FES.

The increase in power level would cause a current and magnetic field increase on the onsite transmission line between the main generator and the plant substation. The line is located entirely within the fenced, licensee-controlled boundary of the plant, and it is not expected that members of the public or wildlife would be affected. Exposure from magnetic fields from the offsite transmission system is not expected to increase significantly.

Water Use

Power rerate does not involve a significant increase in water use at MNGP. Both ground and surface water appropriation limits are established by the Minnesota Department of Natural Resources. Operating history shows that over the last 5 years MNGP has used less than 13 million gallons of ground water per year. The annual limit established in the permit for groundwater use is 15 million gallons. Power rerate is not expected to change the groundwater usage and, therefore, operation within the allowable limit would continue. Under the surface water appropriation limit, MNGP may withdraw a maximum of 645 cubic feet per second (cfs) from the Mississippi River. There are special restrictions when the river flow is particularly high or low; however, power rerate is not expected to change the surface water requirements of the plant and, therefore, current appropriation limits would be maintained. Power rerate would result in an increase in the evaporation rate of the cooling towers resulting in an increase in

evaporative losses from the river. Assuming the evaporation rate of the cooling towers increases linearly in proportion to the power increase, the evaporation rate would increase to 4400 acre-ft/yr [acre-foot per year]. The value assumed in the FES was 5000 acre-ft/yr evaporative losses; therefore, the FES is still bounding.

Discharges to the water are governed by the National Pollutant Discharge Elimination System (NPDES) permit, issued by the State of Minnesota. Temperature and effluent limits at certain points are established in the permits. As a result of power rerate, a slight increase in circulating water discharge temperature is projected to occur. This is due to an increase in heat rejected by the condenser due to the increased power levels and increased steam flow. A conservative estimate by the licensee predicts a maximum 1.7 °F [degrees Fahrenheit] increase in the temperature of the water entering the discharge canal. This increase would not result in exceeding the limits delineated in the FES or the limits established by the State in the permit. Additionally, temperature monitoring is continuous and this maximum temperature increase would occur only at certain times of the year with certain river flows. In the past, when MNGP has approached the limit designated in the NPDES permit, NSP has reduced power at the plant to maintain compliance; this will continue in the future. The slight increase in temperature does not require any changes to permit requirements and would not result in any significant impacts to the environment that are different from those previously identified or change the previous Clean Water Act Section 316(a) demonstration concerning thermal plume in the Mississippi River.

Power rerate would not introduce any new contaminants or pollutants and would not significantly increase the amount of potential contaminants previously allowed by the State. NSP will continue to adhere to effluent limitation and monitoring requirements as part of compliance with the NPDES permit. As a result of the additional week of cooling tower

operation, a slight increase in normal bromine and sodium hypochlorite injection may be required; however, the effluent concentrations would continue to be well below the NPDES permit limits. Continuous flowrate monitoring at designated points will continue.

Over the years of operation, a number of modifications to the intake structure have been implemented to reduce cold shock, impingement, and entrainment of organisms and fish. Because the discharge canal inlet temperature is expected to increase 1.7 °F at power rerate, the overall discharge canal temperature is not significantly increased; therefore, the temperature decrease during cold shock is not significantly changed.

Additionally, impingement and entrainment mortality of drift organisms is not increased above what was previously evaluated by the staff.

Other Impacts

No significant increases or changes to the noise generated by MNGP are expected as a result of power rerate; therefore, the FES remains bounding. A small number of endangered and threatened species exist within the licensee-controlled area at MNGP. Using information from the Minnesota Department of Natural Resources, the licensee performed a biological assessment of the impact of power rerate on these species. The assessment did not identify any impacts. Power rerate would not result in any significant changes to land use or water use, or result in any significant changes to the quantity or quality of effluents; therefore, no effects on the endangered or threatened species or on their habitat are expected as a result of power rerate.

The proposed power rerate would not change the method of generating electricity nor the method of handling any influent from the environment or nonradiological effluents to the environment. Therefore, no changes or different types of nonradiological environmental impacts are expected.

Radiological Impacts

MNGP has a number of radioactive waste systems designed to collect, process, and dispose of solid, liquid, and gaseous radioactive waste. No changes to these systems are required for power rerate conditions. The licensee considered the effect of the higher power level on solid radioactive wastes, liquid radioactive wastes, gaseous radioactive wastes, and radiation levels.

As a result of power rerate, a slight increase in solid waste from the reactor water cleanup (RWCU) system demineralizers and condensate demineralizers would occur. This is due to more frequent filter backwashes. Additional RWCU filter backwashes would result in less than 1 cubic meter of additional resin waste per year; condensate demineralizer filter backwashes are estimated to result in an additional 4 cubic meters of resin waste per year. Therefore, the projected increase in spent resin volume is less than 6 cubic meters per year, which would bring the total generation rate to approximately 55 cubic meters per year.

In addition to the solid process waste, there are solid reactor system wastes generated from the plant. These include irradiated fuel assemblies and control blades. Due to extended burnup and the higher enrichments, the number of irradiated fuel assemblies is not expected to significantly increase the volume of waste; however, the activity of the waste generated from spent control blades and incore ion changers may increase slightly. This is due to the higher flux conditions expected under power rerate. Improvements in technology and longer fuel cycles are expected to offset this slight increase. The increase in waste would be insufficient to impact the amount of waste generated at the site. Further, the licensee believes ongoing efforts at MNGP to reduce radioactive wastes will balance the slight increase in waste that would be generated as a result of power rerate.

The FES and Technical Specifications allow MNGP to discharge a limited amount of liquid radioactive waste. The FES concluded that, based on the allowed amounts, no adverse environmental impact would result from release of the allowable radioactive waste. However, since 1972, an administrative limit of zero radioactive liquid release has been imposed by NSP. MNGP expects to keep the zero release administrative limit and remain well within the bounds of the FES.

A slight increase in input to the liquid radioactive waste system is expected due to the increase in backwash frequency of the RWCU and condensate demineralizer system. However, the liquid radioactive waste input will be recycled instead of discharged and will not result in a significant increase in volume of liquid radioactive waste. Other sources of liquid radioactive waste such as valve packings, pump seal flows, drain waste, etc., are not expected to change or increase as a result of power rerate. Based on the above, it does not appear that power rerate will cause an increase in liquid radioactive waste above the presently allowed limits and will not affect compliance with the limits of 10 CFR Part 20 or Appendix I of 10 CFR Part 50.

Gaseous radioactive waste effluents consist of two pathways: reactor building ventilation system and offgas system pathway. Operational experience at MNGP shows a 4-year average release of 688 Ci/yr [curies per year] noble gas and 0.22 Ci/yr iodine and particulate release. The FES assumed release rates of 110,376 Ci/yr for noble gases and 0.75 Ci/yr for iodine and particulate releases. Assuming power rerate increases the offgas release rate linearly in proportion to the core thermal power increase, the increase in offgas stack release would be well below that assumed in the FES. Assuming the radioactivity of the reactor coolant system increases in a linear fashion proportional to the power increase, the reactor building release rate is well below that assumed in the FES. Based on the above,

power rerate has an insignificant effect on the present production and activity of gaseous effluents released through the reactor building ventilation system and the offgas system pathways and the dose from effluent releases is well within the bounds of Appendix I to 10 CFR Part 50 and 10 CFR Part 20. The changes in core flux profile would result in increased consequences of a fuel defect for a bundle in a non-leak location; however, this continues to be bounded by the consequences for the peak bundle and those limits are not changed.

Power rerate does not introduce any new or different radiological release pathways and does not increase the probability of an operator error or equipment malfunction that would result in a radiological release. Thus, there will be no significant increase in the types or amounts of radiological effluents.

Tables S-3 and S-4 of 10 CFR 51.51 and 10 CFR 51.52, respectively, outline the environmental effects of uranium fuel cycle activities and fuel and radioactive waste transportation. The environmental evaluation supporting Table S-3 assumed a reference reactor with a specific capacity factor that results in an adjusted daily electricity production during a reference year. An average burnup and enrichment are also assumed. MNGP will not exceed the assumption of the reference reactor year, but will exceed the average burnup and fuel enrichment criteria as a result of power rerate. The environmental impacts of the higher burnup and enrichment values were documented in NUREG/CR-5009, "Assessment of the Use of Extended Burnup Fuels in Light Water Power Reactors," and discussed in the Environmental Assessment and Finding of No Significant Impact, which was published in the FEDERAL REGISTER on February 29, 1988 (53 FR 6040). The staff concluded that no significant adverse effects will be generated by increasing the burnup levels as long as the maximum rod average burnup level of any fuel rod is no greater than 60 Gwd/MtU [gigawatt-days per metric ton of uranium]. The staff also stated that the environmental impacts summarized in Tables S-3

and S-4 for a burnup level of 33 Gwd/MtU are conservative and bound the corresponding impacts for burnup levels up to 60 Gwd/MtU and uranium-235 enrichments up to 5 weight percent. These conclusions are applicable to MNGP since the burnup levels and enrichment amounts bound the values that will occur during Monticello rerate. Based on the above, there are no adverse radiological or nonradiological impacts associated with the use of extended fuel burnup and/or increased enrichment and, therefore, power rerate will not significantly affect the quality of the human environment.

Alternatives to the Proposed Action:

As an alternative to the proposed action, the staff considered denial of the proposed action (no-action alternative). Denial of the proposed action would result in no change in current environmental impacts of plant operation but would restrict operation to the currently licensed power level. The environmental impact of the proposed action and the alternative action are similar.

Alternative Use of Resources:

This action does not involve the use of any resources not previously considered in the Final Environmental Statement for the MNGP.

Agencies and Persons Consulted:

In accordance with its stated policy, on August 10, 1998, the NRC staff consulted with the Minnesota State official, Mr. Timothy Donakowski, of the Minnesota Department of Public Health, regarding the environmental impact of the proposed action. The State official had no comments.

FINAL FINDING OF NO SIGNIFICANT IMPACT

The staff has reviewed the proposed power rerate for the MNGP relative to the requirements set forth in 10 CFR Part 51. On January 27, 1998, the staff published a draft

Environmental Assessment in the FEDERAL REGISTER (63 FR 3929), for public comment.


No comments were received.

Based upon the environmental assessment, the Commission concludes that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the Commission has determined not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the licensee's submittals dated July 26, 1996, and December 4, 1997, which are available for public inspection at the Commission's Public Document Room, The Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Minneapolis Public Library, Technology and Science Department, 300 Nicollet Mall, Minneapolis, Minnesota 55401.

Dated at Rockville, Maryland, this 27th day of August 1998.

FOR THE NUCLEAR REGULATORY COMMISSION



Cynthia A. Carpenter, Director
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation