

DISTRIBUTION:

Docket JRBuchanan
NRC PDR ACRS (16)
Local PDR File
ORB#3 Rdg Xtra Copies
NRR Rdg
DEisenhut
BGrimes
RVollmer
STSG
Tippolito
RBevan
SSheppard
OELD
OI&E (5)
BJones (4)
TERA

MARCH 13 1979

Docket No. 50-254

Mr. C. Reed
Assistant Vice President
Commonwealth Edison Company
P. O. Box 767
Chicago, Illinois 60690

Dear Mr. Reed:

On February 23, 1979 the Commission issued Amendment No. 50 to License No. DPR-29 for the Quad Cities Nuclear Power Station Unit No. 1. This amendment authorized operation using 192 assemblies of replacement 8x8R fuel, incorporated revised MCPR limits in response to the plant specific analysis for Reload 4, and modified License Condition 3.C to revise the end-of-cycle coastdown limits appropriate to the analyzed conditions for core Reload 4. However, there was an error on page 3.2/4.2-5 to the Appendix A Technical Specifications transmitted with the amendment. Please replace page 3.2/4.2-5 with the enclosed corrected page.

We regret any inconvenience caused by this administrative error.

Sincerely,

Original signed by

Thomas A. Ippolito, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Enclosure:
Technical Specification page
3.2/4.2-5

cc w/enclosure:
see next page

*Concl.
CCP*

79040201487

OFFICE >	ORB#3 <i>prh</i>	ORB#3 <i>prh</i>	ORB#3 <i>prh</i>			
SURNAME >	<i>M. Kucur</i> SSheppard	RBevan:acr	Tippolito			
DATE >	3/12/79	3/12/79	3/12/79			

Mr. Cordell Reed

cc w/enclosures:

Mr. D. R. Stichnoth
President
Iowa-Illinois Gas and
Electric Company
206 East Second Avenue
Davenport, Iowa 52801

Mr. John W. Rowe
Isham, Lincoln & Beale
Counselors at Law
One First National Plaza, 42nd Floor
Chicago, Illinois 60603

Mr. Nick Kalivianakas
Plant Superintendent
Quad-Cities Nuclear Power Station
22710 - 206th Avenue - North
Cordova, Illinois 61242

Anthony Z. Roisman
Natural Resources Defense Council
917 15th Street, N. W.
Washington, D. C. 20005

Moline Public Library
504 - 17th Street
Moline, Illinois 61265

Illinois Department of Public Health
ATTN: Chief, Division of Nuclear
Safety
535 West Jefferson
Springfield, Illinois 62761

Mr. Marcel DeJaegher, Chairman
Rock Island County Board
of Supervisors
Rock Island County Court House
Rock Island, Illinois 61201

Director, Technical Assessment Division
Office of Radiation Programs (AW 459)
US EPA
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: EIS COORDINATOR
230 South Dearborn Street
Chicago, Illinois 60604

Susan N. Sekuler
Assistant Attorney General
Environmental Control Division
188 W. Randolph Street
Suite 2315
Chicago, Illinois 60601

3.2 LIMITING CONDITIONS FOR OPERATION BASES

In addition to reactor protection instrumentation which initiates a reactor scram, protective instrumentation has been provided which initiates action to mitigate the consequences of accidents which are beyond the operator's ability to control, or terminates operator errors before they result in serious consequences. This set of specifications provides the limiting conditions of operation for the primary system isolation function, initiation of the emergency core cooling system, control rod block, and standby gas treatment systems. The objectives of the specifications are (1) to assure the effectiveness of the protective instrumentation when required by preserving its capability to tolerate a single failure of any component of such systems even during periods when portions of such systems are out of service for maintenance, and (2) to prescribe the trip settings required to assure adequate performance. When necessary, one channel may be made inoperable for brief intervals to conduct required functional tests and calibrations. Some of the settings on the instrumentation that initiates or controls core and containment cooling have tolerances explicitly stated where the high and low values are both critical and may have a substantial effect on safety. It should be noted that the setpoints of other instrumentation, where only the high or low end of the setting has a direct bearing on safety, are chosen at a level away from the normal operating range to prevent inadvertent actuation of the safety system involved and exposure to abnormal situations.

Isolation valves are installed in those lines that penetrate the primary containment and must be isolated during a loss-of-coolant accident so that the radiation dose limits are not exceeded during an accident condition. Actuation of these valves is initiated by the protective instrumentation which senses the conditions for which isolation is required (this instrumentation is shown in Table 3.2-1). Such instrumentation must be available whenever primary containment integrity is required. The objective is to isolate the primary containment so that the guidelines of 10 CFR 100 are not exceeded during an accident.

The instrumentation which initiates primary system isolation is connected in a dual bus arrangement. Thus the discussion given in the bases for Specification 3.1 is applicable here.

The low-reactor water level instrumentation is set to trip at >8 inches on the level instrument (top of active fuel is defined to be 360 inches above vessel zero) after allowing for the full power pressure drop across the steam dryer the low level trip is at 504 inches above vessel zero, or 144 inches above top of active fuel. Retrofit 8x8 fuel has an active fuel length 1.24 inches longer than earlier fuel designs, however, present trip setpoints were used in the LOCA analysis (NEDO 24146). This trip initiates closure of Group 2 and 3 primary containment isolation valves but does not trip the recirculation pumps (reference SAR, Section 7.7.2). For a trip setting of 504 inches above vessel zero and a 60-second valve closure time, the valves will be closed before perforation of the cladding occurs even for the maximum break, the setting is, therefore, adequate.

The low-low reactor level instrumentation is set to trip when reactor water level is 444 inches above vessel zero (with top of active fuel defined as 360 inches above vessel zero, -59" is 84 inches above the top of active fuel). This trip initiates closure of Group 1 primary containment isolation valves (reference SAR Section 7.7.2.2) and also activates the ECC subsystems starts the emergency diesel generator, and trips the recirculation pumps. This trip setting level was chosen to be high enough to prevent spurious operation but low enough to initiate ECCS operation and primary system isolation so that no melting of the fuel cladding will occur and so that postaccident cooling can be accomplished and the guidelines of 10 CFR 100 will not be exceeded. For the complete circumferential break of a 28-inch recirculation line and with the trip setting given above, ECCS initiation and primary system isolation are initiated and in time so meet the above criteria (reference SAR Sections 6.2.7.1 and 14.2.4.2). The instrumentation also covers the full spectrum of breaks and meets the above criteria (reference SAR Sections 6.2.7.1).