

October 6, 1987

Distribution:

Docket File	TBarnhart (4 cys for each docket)
PDIII-2 r/f	WJones
NRC & Local PDRs	EButcher
LLuther	ACRS (10)
MGrotenhuis	GPA/PA
OGC-Beth.	ARM/LFMB
DHagan	PDIII-2 Plant File
EJordan	JPartlow

Docket Nos. 50-254/265

Mr. D. L. Butterfield, Jr.  
Nuclear Licensing Manager  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dear Mr. Butterfield:

SUBJECT: TEMPORARY WAIVER OF COMPLIANCE FOR TECHNICAL SPECIFICATION  
3.5.G.2 RE: DISCHARGE PIPE PRESSURE FOR CORE AND CONTAINMENT  
SYSTEMS

Re: Quad Cities Nuclear Power Station, Unit Nos. 1 and 2

By letter dated October 6, 1987, you requested a temporary waiver of compliance from Technical Specification 3.5.G.2 which requires a certain discharge pipe pressure for systems listed in 3.5.G.1. Your letter provided an amendment request and a discussion of the circumstances. We have reviewed your request and find that your current practice with respect to Technical Specification 3.5.G.2 adequately meets the safety intent of the specification and is therefore acceptable on an interim basis. This letter confirms our oral approval for the temporary waiver of compliance to extend for two months from the date of this letter. By that time the formal modification to the Technical Specification is expected to be issued.

Sincerely,

151

Gary Holahan, Assistant Director  
for Regions III & V Reactors  
Division of Reactor Projects III,  
IV, V and Special Projects

cc: A. B. Davis  
C. Norelius  
M. Ring  
W. Forney  
T. Ross

cc: (See Attached List)

8710150142 871006  
PDR ADDCK 05000254  
PDR

OFC	: PDIII-2	: PDIII-2	: PDIII-2	:	:	:
NAME	: MGrotenhuis/ww	: DMVier	: GHolahan	:	:	:
DATE	: 10/6/87	: 10/6/87	: 10/6/87	:	:	:

Mr. L. D. Butterfield, Jr.  
Commonwealth Edison Company

Quad Cities Nuclear Power Station  
Units 1 and 2

cc:

Mr. Stephen E. Shelton  
Vice President  
Iowa-Illinois Gas and  
Electric Company  
P. O. Box 4350  
Davenport, Iowa 52808

Mr. Richard Bax  
Station Manager  
Three First National Plaza  
Suite 5200  
Chicago, Illinois 60602

Mr. Nick Kalivianakis  
Plant Superintendent  
Quad Cities Nuclear Power Station  
22710 - 206th Avenue - North  
Cordova, Illinois 61242

Resident Inspector  
U. S. Nuclear Regulatory Commission  
22712 206th Avenue North  
Cordova, Illinois 61242

Chairman  
Rock Island County Board  
of Supervisors  
1504 3rd Avenue  
Rock Island County Office Bldg.  
Rock Island, Illinois 61201

Mr. Michael E. Parker, Chief  
Division of Engineering  
Illinois Department of Nuclear Safety  
1035 Outer Park Drive, 5th Floor  
Springfield, Illinois 62704

Regional Administrator, Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137