January 29, 1985

Docket No. 50-254

Mr. Dennis L. Farrar Director of Nuclear Licensing Commonwealth Edison Company Post Office Box 767 Chicago, Illinois 60690

Dear Mr. Farrar:

As we recently discussed by telephone, our Amendment No. 90 to DPR-29 for Quad Cities, Unit 1 contained an incorrect substitute page 3.2/4.2-17. The page as issued with our Amendment No. 90 did not reflect a change previously made with Amendment No. 89. The corrected substitute page is enclosed.

We regret any inconvenience caused by this error.

Sincerely,

Original signed by/

Roby B. Bevan, Project Manager Operating Reactors Branch #2 Division of Licensing

Enclosure: As stated

cc w/enclosure: See next page

DISTRIBUTION

Docket File
NRC PDR
Local PDR
ORB#2 Reading
DEisenhut

SNorris RBevan OELD LJHarmon ELJordan PMcKee TBarnhart (8) WJones DBrinkman ACRS (10) OPA, CMiles RDiggs Gray File Extra - 5 JPartlow

DL:ORB#2 SNorris:ajs RBevan 1 01/28/85 01/28/85



8502140314 850129 PDR ADDCK 05000254 PDR PDR Mr. Dennis L. Farrar Commonwealth Edison Company Ouad Cities Nuclear Power Station, Units 1 and 2

cc:

Mr. B. C. O'Brien President Iowa-Illinois Gas and Electric Company 206 East Second Avenue Davenport, Iowa 52801

Robert G. Fitzgibbons, Jr. Isham, Lincoln & Beale Three First National Plaza Suite 5200 Chicago, Illinois 60602

Mr. Nick Kalivianakis Plant Superintendent Ouad Cities Nuclear Power Station 22710 - 206th Avenue - North Cordova, Illinois 61242

Resident Inspector U. S. Nuclear Regulatory Commission 22712 206th Avenue North Cordova, Illinois 61242

Chairman Rock Island County Board of Supervisors Rock Island County Court House Rock Island, Illinois 61201 James G. Keppler Regional Administrator Region III Office U. S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, Illinois 60137

Susan N. Sekuler Assistant Attorney General Environmental Control Division 188 W. Randolph Street Suite 2315 Chicago, Illinois 60601

The Honorable Tom Corcoran United States House of Representatives Washington, D. C. 20515

Mr. Gary N. Wright
Nuclear Facility Safety
Illinois Department of
Nuclear Safety
1035 Outer Park Drive, 5th Floor
Springfield, Illinois 62704

QUAD-CITIES DPR-29

TABLE 4.2-1 (cont'd)

Inst Chai	trument •	Instrument Functional Test(2)	<u>Calibration</u> (2)	Instrument Check(2)
HPC	I Isolation			
1. 2. 3.	Steamline high flow Steamline area high temperature Low reactor pressure	(1) (9) (10) [,] Refueling outage (1) (10)	(9) (10) Refueling outage (10)	None None None
Rea	ctor Building Ventilation System I	solation and Standby	Treatment System Initiatio	n
1.	Refueling floor radiation monitors	(1)	Once/3 months	Once/day
Ste	am Jet Air Ejector Off-Gas Isolati	on		
1.	Off-gas radiation monitors	(1) (4)	Refueling outage	Once/day
Con	trol Room Ventilation System Isola	tion		
1. 2. 3. 4.	Reactor low water level Drywell high pressure Main steamline high flow Ventilation exhaust duct	(1) (1) (1) (1)	Once/3 months Once/3 months Once/3 months Once/3 months	Once/day None Once/day Once/day

- Notes:
 - Initially once per month until exposure hours (M as defined on Figure 4.1-1) are 2.0 X 10⁵; thereafter, according to Figure 4.1-1 with an interval not less than 1 month nor more than 3 months. The compilation of instrument failure rate data may include data obtained from other boiling water reactors for which the same design instrument operates in an environment similar to that of Quad Cities Units 1 and 2.
 - 2. Functional tests, calibrations, and instrument checks are not required when these instruments are not required to be operable or tripped.
 - 3. This instrumentation is excepted from the functional test definition. The function test shall consist of injecting a simulated electric signal into the measurement channel.
 - 4. This instrument channel is excepted from the functional test definitions and shall be calibrated using simulated electrical signals once every 3 months.
 - 5. Functional tests shall be performed before each startup with a required frequency not to exceed once per week. Calibrations shall be performed during each startup or during controlled shutdowns with a required frequency not to exceed once per week.
- 6. The positioning mechanism shall be calibrated every refueling outage.
- Logic system functional tests are performed as specified in the applicable section for these sytems.
- Functional tests shall include verification of operation of the degraded voltage. 5 minute timer and 7 second inherent timer.
- 9. Verification of the time delay setting of $3 \leq \tau \leq 10$ seconds shall be performed during each refueling outage.
- 10. Trip units are functionally tested monthly. A calibration of the trip unit is to be performed concurrent with the functional testing. Transmitters are calibrated once per operating cycle.

8502140316 850129 PDR ADDCK 05000254 P PDR

3.2/4.2-17

Amendment No. 88, 89, 90