

May 27, 1982

Docket Nos. 50-254
and 50-265

Mr. L. DelGeorge
Director of Nuclear Licensing
Commonwealth Edison Company
P. O. Box 767
Chicago, Illinois 60690

Dear Mr. DelGeorge:

The Commission has issued the enclosed Amendment Nos. 78 and 72 to Facility Operating License Nos. DPR-29 and DPR-30 for Quad Cities Nuclear Power Station, Units 1 and 2. These amendments are in response to your letter dated May 20, 1982.

The amendments change the Technical Specifications to extend from June 1, 1982 to July 1, 1982 the time allowed for continued operation of both units prior to completion of modifications to the RHR service water system. Although this requested extension of time is approved, a best effort should be made to complete the modification as soon after June 1, 1982 as possible.

Copies of the Safety Evaluation and Notice of Issuance are also enclosed.

Sincerely,

ORIGINAL SIGNED BY

Roby B. Bevan, Project Manager
Operating Reactors Branch #2
Division of Licensing

Enclosures:

1. Amendment No. 78 to DPR-29
2. Amendment No. 72 to DPR-30
3. Safety Evaluation
4. Notice

cc w/enclosures
See next page

8208060050 820527
PDR ADDCK 05000254
P PDR

DISTRIBUTION: Docket File NRC PDR ORB#2 Rdg D. Eisenhut R. Bevan
S. Norris OELD SECY I&E-2 D. Brinkman T. Barnhart-8
L. Schneider ACRS-10 C. Miles R. Diggs NSIC ASLAB
Gray Extra

OFFICE	DL:ORB#2	DL:ORB#2	DL:ORB#2	DL:AD:OR	OELD		
SURNAME	S. Norris	R. Bevan	M. G. Davis	T. Novak			
DATE	5/27/82	5/27/82	5/27/82	5/27/82	5/27/82		

OFFICIAL RECORD COPY

Mr. L. DelGeorge
Commonwealth Edison Company

cc:

Mr. D. R. Stichnoth
President
Iowa-Illinois Gas and
Electric Company
206 East Second Avenue
Davenport, Iowa 52801

Robert G. Fitzgibbons Jr.
Isham, Lincoln & Beale
Three First National Plaza
Suite 5200
Chicago, IL 60602

Mr. Nick Kalivianakas
Plant Superintendent
Quad Cities Nuclear Power Station
22710 - 206th Avenue - North
Cordova, Illinois 61242

Resident Inspector
U. S. Nuclear Regulatory Commission
22712 206th Avenue N.
Cordova, Illinois 61242

Moline Public Library
504 - 17th Street
Moline, Illinois 61265

Illinois Department of Nuclear Safety
1035 Outer Park Drive
5th Floor
Springfield, Illinois 62704

Mr. Marcel DeJaegher, Chairman
Rock Island County Board
of Supervisors
Rock Island County Court House
Rock Island, Illinois 61201

James G. Keppler
Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

U.S. Environmental Protection Agency
Region V Office
Regional Radiation Representative
230 South Dearborn Street
Chicago, Illinois 60604

Susan N. Sekuler
Assistant Attorney General
Environmental Control Division
188 W. Randolph Street
Suite 2315
Chicago, Illinois 60601

James L. Kelley, Chairman
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. Peter A. Morris
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. Richard F. Foster
P. O. Box 4263
Sunriver, Oregon 97701

The Honorable Tom Corcoran
United States House of Representatives
Washington, D.C. 20515

Quad-Cities Alliance for Safe
Energy and Survival
Mr. Robert Romic
1628 Grant Street
Bettendorf, Iowa 52722

Citizens for Safe Energy
ATTN: Mr. Robert Miller
P. O. Box 23
Hillsdale, Illinois 61257



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY
AND
IOWA ILLINOIS GAS AND ELECTRIC COMPANY

DOCKET NO. 50-254

QUAD CITIES STATION UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 78
License No. DPR-29

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Commonwealth Edison Company (the licensee) dated May 20, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 3.B of Facility License No. DPR-29 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 78, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

8208060060 820527
PDR ADOCK 05000254
P PDR

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 27, 1982

ATTACHMENT TO LICENSE AMENDMENT NO. 78

FACILITY OPERATING LICENSE NO. DPR-29

DOCKET NO. 50-254

Revise the Appendix "A" Technical Specifications as follows:

Remove

3.5/4.5-3

3.5/4.5-12

Replace

3.5/4.5-3

3.5/4.5-12

**QUAD-CITIES
DPR-29**

continued reactor operation is permissible only during the succeeding 7 days unless it is sooner made operable, provided that during such 7 days all active components of both core spray subsystems, the containment cooling mode of the RHR (including two RHR pumps), and the diesel generators required for operation of such components if no external source of power were available shall be operable.

6. If the requirements of Specification 3.5.A cannot be met, an orderly shutdown of the reactor shall be initiated, and the reactor shall be in the cold shutdown condition within 24 hours.

B. Containment Cooling Mode of the RHR System

- 1.a. Both loops of the containment cooling mode of the RHR system, as defined in the bases for Specification 3.5.B, shall be operable whenever irradiated fuel is in the reactor vessel and prior to reactor startup from a cold condition.
- 1.b. From the effective date of this amendment until July 1, 1982, the "A" loop of the containment cooling mode of the RHR system for each reactor may share the Unit 2 "A" and "B" RHR service water pumps using cross tie line 1/2-10124-16"-D. Consequently, the requirements of Specifications 3.5.B.2 and 3.5.B.3 will impose the corresponding surveillance testing of equipment associated with both reactors if the shared RHR service water pump or pumps, or the cross tie line, are made or found to be inoperable.
2. From and after the date that one of the RHR service water pumps is made or found to be inoperable for any reason, continued reactor operation is permissible only during the succeeding 30 days unless such pump is sooner made operable, provided that during such 30 days all other active components of the containment cooling mode of the RHR system are operable.

containment cooling mode of the RHR, and the diesel generators required for operation of such components if no external source of power were available shall be demonstrated to be operable immediately and daily thereafter.

B. Containment Cooling Mode of the RHR System

Surveillance of the containment cooling mode of the RHR system shall be performed as follows:

1. RHR service water subsystem testing:

<i>Item</i>	<i>Frequency</i>
a. Pump and valve operability	Once/3 months
b. Flow rate test - each RHR service water pump shall deliver at least 3500 gpm against a pressure of 198 psig	After pump maintenance and every 3 months
c. A logic system functional test	Each refueling outage

2. When it is determined that one RHR service water pump is inoperable, the remaining components of that loop and the other containment cooling loop of the RHR system shall be demonstrated to be operable immediately and daily thereafter.

Should the loss of one RHR pump occur, a nearly full complement of core and containment cooling equipment is available. Three RHR pumps in conjunction with the core spray subsystem will perform the core cooling function. Because of the availability of the majority of the core cooling equipment, which will be demonstrated to be operable, a 30-day repair period is justified. If the LPCI mode of the RHR system is not available, at least two RHR pumps must be available to fulfill the containment cooling function. The 7-day repair period is set on this basis.

B. RHR Service Water

The containment cooling mode of the RHR system is provided to remove heat energy from the containment in the event of a loss-of-coolant accident. For the flow specified, the containment long-term pressure is limited to less than 8 psig and is therefore more than ample to provide the required heat-removal capability (reference SAR Section 5.2.3.2).

The Containment Cooling mode of the RHR System consists of two loops. Each loop consists of 1 Heat Exchanger, 2 RHR Pumps, and the associated valves, piping, electrical equipment, and instrumentation. The "B" loop on each unit contains 2 RHR Service Water Pumps. During the period from November 24, 1981, to July 1, 1982, the "A" loop on each unit may utilize the "A" and "B" RHR Service Water Pumps from Unit 2 via a cross-tie line. After July 1, 1982, each "A" loop will contain 2 RHR Service Water Pumps.

Either set of equipment is capable of performing the containment cooling function. Loss of one RHR service water pump does not seriously jeopardize the containment cooling capability, as any one of the remaining three pumps can satisfy the cooling requirements. Since there is some redundancy left, a 30-day repair period is adequate. Loss of one loop of the containment cooling mode of the RHR system leaves one remaining system to perform the containment cooling function. The operable system is demonstrated to be operable each day when the above condition occurs. Based on the fact that when one loop of the containment cooling mode of the RHR system becomes inoperable, only one system remains, which is tested daily, a 7-day repair period was specified.

C. High-Pressure Coolant Injection

The high-pressure coolant injection subsystem is provided to adequately cool the core for all pipe breaks smaller than those for which the LPCI mode of the RHR system or core spray subsystems can protect the core.

The HPCI meets this requirement without the use of offsite electrical power. For the pipe breaks for which the HPCI is intended to function, the core never uncovers and is continuously cooled, thus no cladding damage occurs (reference SAR Section 6.2.5.3). The repair times for the limiting conditions of operation were set considering the use of the HPCI as part of the isolation cooling system.

D. Automatic Pressure Relief

The relief valves of the automatic pressure relief subsystem are a backup to the HPCI subsystem. They enable the core spray subsystem or LPCI mode of the RHR system to provide protection against the small pipe break in the event of HPCI failure by depressurizing the reactor vessel rapidly enough to actuate the core spray subsystems or LPCI mode of the RHR system. The core spray subsystem and/or the LPCI mode of the RHR system provide sufficient flow of coolant to limit fuel cladding temperatures to less than 2200°F, to assure that core geometry remains intact, to limit the core wide clad metal-water reaction to less than 1%, and to limit the calculated local metal-water reaction to less than 17%.

Loss of 1 of the relief valves affects the pressure relieving capability and, therefore, a 7 day repair period is specified. Loss of more than one relief valve significantly reduces the pressure relief capability, thus a 24-hour repair period is specified based on the HPCI system availability during this period.

E. RCIC

The RCIC system is provided to supply continuous makeup water to the reactor core when the reactor is isolated from the turbine and when the feedwater system is not available. Under these conditions the pumping capacity of the RCIC system is sufficient to maintain the water level above the core without any other water system in operation. If the water level in the reactor vessel decreases to the RCIC initiation level, the system automatically starts. The system may also be manually initiated at any time.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY
AND
IOWA ILLINOIS GAS AND ELECTRIC COMPANY

DOCKET NO. 50-265

QUAD CITIES STATION UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 72
License No. DPR-30

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Commonwealth Edison Company (the licensee) dated May 20, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 3.B of Facility License No. DPR-30 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 72, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 27, 1982

ATTACHMENT TO LICENSE AMENDMENT NO. 72

FACILITY OPERATING LICENSE NO. DPR-30

DOCKET NO. 50-265

Revise the Appendix "A" Technical Specifications as follows:

Remove

3.5/4.5-3

3.5/4.5-11

Replace

3.5/4.5-3

3.5/4.5-11

QUAD-CITIES
DPR-30

continued reactor operation is permissible only during the succeeding 7 days unless it is sooner made operable, provided that during such 7 days all active components of both core spray subsystems, the containment cooling mode of the RHR (including two RHR pumps), and the diesel generators required for operation of such components if no external source of power were available shall be operable.

6. If the requirements of Specification 3.5.A cannot be met, an orderly shutdown of the reactor shall be initiated, and the reactor shall be in the cold shutdown condition within 24 hours.

B. Containment Cooling Mode of the RHR System

containment cooling mode of the RHR, and the diesel generators required for operation of such components if no external source of power were available shall be demonstrated to be operable immediately and daily thereafter.

B. Containment Cooling Mode of the RHR System

Surveillance of the containment cooling mode of the RHR system shall be performed as follows:

1. RHR service water subsystem testing:

Item	Frequency
a. Pump and valve operability	Once/3 months
b. Flow rate test - each RHR service water pump shall deliver at least 3500 gpm against a pressure of 198 psig	After pump maintenance and every 3 months
c. A logic system functional test	Each refueling outage

2. When it is determined that one RHR service water pump is inoperable, the remaining components of that loop and the other containment cooling loop of the RHR system shall be demonstrated to be operable immediately and daily thereafter.

- 1.a. Both loops of the containment cooling mode of the RHR system, as defined in the bases for Specification 3.5.B, shall be operable whenever irradiated fuel is in the reactor vessel and prior to reactor startup from a cold condition.

- 1.b. From the effective date of this amendment until July 1, 1982, the "A" loop of the containment cooling mode of the RHR system for each reactor may share the Unit 2 "A" and "B" RHR service water pumps using cross tie line 1/2-10124-16"-D. Consequently, the requirements of Specifications 3.5.B.2 and 3.5.B.3 will impose the corresponding surveillance testing of equipment associated with both reactors if the shared RHR service water pump or pumps, or the cross tie line, are made or found to be inoperable.

2. From and after the date that one of the RHR service water pumps is made or found to be inoperable for any reason, continued reactor operation is permissible only during the succeeding 30 days unless such pump is sooner made operable, provided that during such 30 days all other active components of the containment cooling mode of the RHR system are operable.

3.5 LIMITING CONDITIONS FOR OPERATION BASES

A. Core Spray and LPCI Mode of the RHR System

This specification assures that adequate emergency cooling capability is available.

- Based on the loss-of-coolant analyses included in References 1 and 2 and in accordance with 10 CFR 50.46 and Appendix K, core cooling systems provide sufficient cooling to the core to dissipate the energy associated with the loss-of-coolant accident, to limit the calculated peak cladding temperature to less than 2200° F, to assure that core geometry remains intact, to limit the corewide cladding metal-water reaction to less than 1%, and to limit the calculated local metal-water reaction to less than 17%.

The allowable repair times are established so that the average risk rate for repair would be no greater than the basic risk rate. The method and concept are described in Reference 3. Using the results developed in this reference, the repair period is found to be less than half the test interval. This assumes that the core spray subsystems and LPCI constitute a one-out-of-two system; however, the combined effect of the two systems to limit excessive cladding temperature must also be considered. The test interval specified in Specification 4.5 was 3 months. Therefore, an allowable repair period which maintains the basic risk considering single failures should be less than 30 days, and this specification is within this period. For multiple failures, a shorter interval is specified; to improve the assurance that the remaining systems will function, a daily test is called for. Although it is recognized that the information given in Reference 3 provides a quantitative method to estimate allowable repair times, the lack of operating data to support the analytical approach prevents complete acceptance of this method at this time. Therefore, the times stated in the specific items were established with due regard to judgment.

Should one core spray subsystem become inoperable, the remaining core spray subsystem and the entire LPCI mode of the RHR system are available should the need for core cooling arise. To assure that the remaining core spray, the LPCI mode of the RHR system, and the diesel generators are available, they are demonstrated to be operable immediately. This demonstration includes a manual initiation of the pumps and associated valves and diesel generators. Based on judgments of the reliability of the remaining systems, i.e., the core spray and LPCI, a 7-day repair period was obtained.

Should the loss of one RHR pump occur, a nearly full complement of core and containment cooling equipment is available. Three RHR pumps in conjunction with the core spray subsystem will perform the core cooling function. Because of the availability of the majority of the core cooling equipment, which will be demonstrated to be operable, a 30-day repair period is justified. If the LPCI mode of the RHR system is not available, at least two RHR pumps must be available to fulfill the containment cooling function. The 7-day repair period is set on this basis.

B. RHR Service Water

The containment cooling mode of the RHR system is provided to remove heat energy from the containment in the event of a loss-of-coolant accident. For the flow specified, the containment long-term pressure is limited to less than 8 psig and is therefore more than ample to provide the required heat-removal capability (reference SAR Section 5.2.3.2).

The Containment Cooling mode of the RHR System consists of two loops. Each loop consists of 1 Heat Exchanger, 2 RHR Pumps, and the associated valves, piping, electrical equipment, and instrumentation. The "B" loop on each unit contains 2 RHR Service Water Pumps. During the period from November 24, 1981, to July 1, 1982, the "A" loop on each unit may utilize the "A" and "B" RHR Service Water Pumps from Unit 2 via a cross-tie line. After July 1, 1982, each "A" loop will contain 2 RHR Service Water Pumps.

Either set of equipment is capable of performing the containment cooling function. Loss of one RHR service water pump does not seriously jeopardize the containment cooling capability, as any one of the remaining three pumps can satisfy the cooling requirements. Since there is some redundancy left, a 30-day repair period is adequate. Loss of one loop of the containment cooling mode of the RHR system leaves one remaining system to perform the containment cooling function. The operable system is demonstrated to be operable each day when the above condition occurs.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
SUPPORTING AMENDMENT NO. 78 TO FACILITY OPERATING LICENSE NO. DPR-29

AMENDMENT NO. 72 TO FACILITY OPERATING LICENSE NO. DPR-30

COMMONWEALTH EDISON COMPANY

AND

IOWA-ILLINOIS GAS AND ELECTRIC COMPANY

QUAD CITIES STATION UNIT NOS. 1 AND 2

DOCKET NOS. 50-254 AND 50-265

Author: R. B. Bevan

Introduction

By letter dated May 20, 1982, Commonwealth Edison Company (CECo, the licensee) proposed an amendment to the Technical Specifications (TS) for Quad Cities Nuclear Power Station, Units 1 and 2. The amendment would extend from June 1, 1982 to July 1, 1982 the expiration date of a limited TS change that had previously been authorized by Amendments 75 and 68 dated December 18, 1981. The need for the limited TS change arose after a leak developed in a buried portion of the 16-inch residual heat removal (RHR) service water (SW) line for loop "A" of Unit 1. The amendments transmitted by our December 18, 1981 letter allowed the loop "A" RHR heat exchangers (HX) for each unit to be fed from the RHR-SW pumps for Unit 2 by way of a cross-tie already in place.

The CECo proposal dated May 20, 1982 would allow operation in this configuration to continue beyond June 1, 1982, the date currently given in the TS, to July 1, 1982, at which time the licensee expects to have completed the modification necessary to restore the original configuration.

Discussion and Evaluation

Modifications were performed as a result of the RHR-SW line leak to enable continued operation of Units 1 and 2 until the leaking RHR-SW line could be repaired or replaced. It was necessary also to change the TS in order to assure that operation in the modified configuration could be continued without increased safety risk. Our evaluation of the previously approved changes are contained in our Safety Evaluation dated December 18, 1981. At that time, approval was given to continue operation (with conditions described in the Safety Evaluation and modified TS) until June 1, 1982, after which the repairs would be complete, the system restored to its original configuration, and the original TS requirements would be restored. The period of time estimated as necessary to complete the work took account of the possible adverse effects of severe winter weather, the problems of procurement of properly qualified materials, and related matters.

Since that time the licensee has determined that a preferred action is a modification consisting of a complete above ground rerouting of the 16-inch service water line. The new line will be a safety-related and seismically qualified pipe, running from the turbine building condensate pit to the reactor building basement high pressure coolant injection (HPCI) room. Because of the complexity of this modification, and the tight work schedule, the licensee has determined that additional time beyond the previously estimated June 1, 1982, date, will be needed to complete the modification. The licensee estimates that the modification will be completed, except for final installation of seismic restraints, by June 6, 1982.

Continued operation of both units beyond June 1, 1982, until such time as the modification can be completed and qualified, will require a change to the TS. The change requested is to revise the June 1, 1982 date, authorized by the previously cited amendments, to July 1, 1982. From personal observations by the NRR project manager, and discussions with the licensee while on site visits, and from discussions with the Resident Inspectors at the site who have followed the work on a day-to-day basis, we have determined that a best effort has been made to complete the work by the June 1, 1982 date. The licensee will maintain all interim procedure changes previously adopted during the extended time period. All safety justifications discussed in the licensee's earlier proposal, and evaluated in our Safety Evaluation, dated December 18, 1981, still apply.

On the basis of the foregoing considerations, we conclude that extension of the completion date of the modifications to July 1, 1982 is acceptable.

Environmental Considerations

We have determined that these amendments do not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that these amendments involve an action which is insignificant from the standpoint of environmental impact, and pursuant to 10 CFR Section 51.5(d)(4) that an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of these amendments.

Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendments do not involve a significant increase in the probability or consequences of accidents previously considered and do not involve a significant decrease in a safety margin, the amendments do not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Dated: May 27, 1982

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-265

COMMONWEALTH EDISON COMPANY

AND

IOWA-ILLINOIS GAS AND ELECTRIC COMPANY

NOTICE OF ISSUANCE OF AMENDMENTS TO FACILITY
OPERATING LICENSES

The U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment Nos. 78 and 72 to Facility Operating License Nos. DPR-29 and DPR-30 issued to Commonwealth Edison Company and Iowa-Illinois Gas and Electric Company, which revised the Technical Specifications for operation of the Quad Cities Nuclear Power Station, Unit Nos. 1 and 2, located in Rock Island County, Illinois. The amendments are effective as of the date of issuance.

The amendments change the Technical Specifications to extend from June 1, 1982 to July 1, 1982 the time allowed for continued operation of both units prior to completion of modifications to the RHR service water system.

The application for the amendments complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendments. Prior public notice of these amendments was not required since the amendments do not involve a significant hazards consideration.

The Commission has determined that the issuance of these amendments will not result in any significant environmental impact and that pursuant to 10 CFR Section 51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of these amendments.

For further details with respect to this action, see (1) the application for amendments dated May 20, 1982 (2) Amendment No. 78 to License No. DPR-29 and Amendment No. 72 to License No. DPR-30; and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, NW., Washington, D.C., and at the Moline Public Library, 504 - 17th Street, Moline, Illinois. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 27th day of May 1982.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in dark ink, appearing to read 'D. B. Vassallo', with a long horizontal flourish extending to the right.

Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing