

MAY 5 1978

Docket No. 50-265

Commonwealth Edison Company
ATTN: Mr. C. Reed
Assistant Vice President
P. O. Box 767
Chicago, Illinois 60690

Gentlemen:

By letter dated March 22, 1978, we transmitted Amendment No. 44 to Facility Operating License No. DPR-30 for Quad Cities Unit No. 2. Through an administrative error an incorrect copy of page 6.2-1 was issued. Please correct your copy of the Technical Specifications by replacing page 6.2-1 with the attached revised page.

Sincerely,

Original signed by

George Lear, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Enclosure:
As stated

cc w/enclosure:
see next page

OFFICE →	ORB#3	ORB#3	ORB#3			
SURNAME →	SSheppard	RBevan:acr	GLear			
DATE →	5/3/78	5/3/78	5/5/78			

Commonwealth Edison Company

- 2 -

cc w/enclosures:

Mr. D. R. Stichnoth
President
Iowa-Illinois Gas and
Electric Company
206 East Second Avenue
Davenport, Iowa 52801

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: EIS COORDINATOR
230 South Dearborn Street
Chicago, Illinois 60604

Mr. John W. Rowe
Isham, Lincoln & Beale
Counselors at Law
One First National Plaza, 42nd Floor
Chicago, Illinois 60603

Mr. Nick Kalivianakas
Plant Superintendent
Quad-Cities Nuclear Power Station
22710 - 206th Avenue - North
Cordeva, Illinois 61242

Anthony Z. Roisman
Natural Resources Defense Council
917 15th Street, N. W.
Washington, D. C. 20005

Moline Public Library
504 - 17th Street
Moline, Illinois 61265

Illinois Department of Public Health
ATTN: Chief, Division of Nuclear
Safety
535 West Jefferson
Springfield, Illinois 62761

Mr. Marcel DeJaegher, Chairman
Rock Island County Board
of Supervisors
Rock Island County Court House
Rock Island, Illinois 61201

Chief, Energy Systems Analyses
Branch (AW-459)
Office of Radiation Programs
U. S. Environmental Protection Agency
Room 645, East Tower
401 M Street, S. W.
Washington, D. C. 20460

6.2 PLANT OPERATING PROCEDURES

- A. Detailed written procedures including applicable checkoff lists covering items listed below shall be prepared, approved, and adhered to:
1. Normal startup, operation, and shutdown of the reactor, and other systems and components involving nuclear safety of the facility.
 2. Refueling operations.
 3. Actions to be taken to correct specific and foreseen potential malfunctions of systems or components including responses to alarms, suspected primary system leaks, and abnormal reactivity changes.
 4. Emergency conditions involving potential or actual release of radioactivity -- "Generating Stations Emergency Plan" and station emergency and abnormal procedures.
 5. Instrumentation operation which could have an effect on the safety of the facility.
 6. Preventive and corrective maintenance operations which could have an effect on the safety of the facility.
 7. Surveillance and testing requirements.
 8. Tests and experiments.
 9. Procedure to ensure safe shutdown of the plant.
 10. Station Security Plan and implementation procedures.
 11. Fire Protection Program implementation.
- B. Radiation control procedures shall be maintained, made available to all station personnel, and adhered to. These procedures shall show permissible radiation exposure and shall be consistent with the requirements of 10 CFR 20. This radiation protection program shall be organized to meet the requirements of 10 CFR 20.
- C.
1. Procedures for items identified in Specification 6.2-A and any changes to such procedures shall be reviewed and approved by the Operating Engineer and the Technical Staff Supervisor in the areas of operation, fuel handling, or instrument maintenance, and by Maintenance Engineer and Technical Staff Supervisor in the areas of plant maintenance and plant inspection. Procedures for items identified in Specification 6.2-B and any changes to such procedures shall be reviewed and approved by the Technical Staff Supervisor and the Radiological Chemical Supervisor. At least one person approving each of the above procedures shall hold a valid senior operator's license. In addition, these procedures and changes thereto, must have authorization by the Station Superintendent before being implemented.
 2. Work and instruction type procedures which implement approved maintenance or modification procedures shall be approved and authorized by the Maintenance Engineer where the written authority has been provided by the Station Superintendent. The "Maintenance/Modification Procedure" utilized for safety-related work shall be so approved only if procedures referenced in the "Maintenance/Modification Procedure" have been approved as required by 6.2.A. Procedures which do not fall within the requirements of 6.2.A or 6.2.B may be approved by the Department Heads.
- D. Temporary changes to procedures 6.2.A and 6.2.B above may be made provided:
1. The intent of the original procedure is not altered.
 2. The change is approved by two members of the plant management staff, at least one of whom holds a Senior Reactor Operator's License on the unit affected.
 3. The change is documented, reviewed by the Onsite Review and Investigative Function, and approved by the Station Superintendent within 14 days of implementation.
- E. Drills of the emergency procedures described in Specification 6.2.A.4 shall be conducted quarterly. These drills will be planned so that during the course of the year, communication links are tested and outside agencies are contacted.