

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

OFFICE OF THE SECRETARY

October 23, 1975

Director
Office of the Federal Register
National Archives and Records Service
Washington, D. C. 20408

Dear Sir:

Enclosed for publication in the Federal Register are an original
and two certified copies of a document entitled:

COMMONWEALTH EDISON COMPANY, ET AL.

Docket No. 50-265

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

Publication of the above document at the earliest possible date would
be appreciated.

Sincerely,

Samuel J. Chilk
Secretary of the Commission

Enclosures:
Original and 2 certified
copies

bcc: ~~Central Files~~
Information Services
Legal Director
Office of Congressional Affairs
OGC
SECY Files



UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-265

COMMONWEALTH EDISON COMPANY

AND

IOWA-ILLINOIS GAS AND ELECTRIC COMPANY

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

Notice is hereby given that the U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 17 to Facility Operating License No. DPR-30, issued to the Commonwealth Edison Company (acting for itself and on behalf of the Iowa-Illinois Gas and Electric Company), which revised Technical Specifications for operation of the Quad Cities Station Unit 2 (the facility) located in Rock Island County, Illinois. The amendment is effective as of its date of issuance.


This amendment authorizes Commonwealth Edison to carry out work that has the potential to partially drain the reactor vessel with the suppression pool water volume less than 112,200 ft³, provided that a total of 112,200 ft³ of water is available for cooling, including the quantity of water contained in the refueling cavity and the spent fuel pool above the bottom of the spent fuel pool gate.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment is not required since the amendment does not involve a significant hazards consideration.

For further details with respect to this action, see (1) the application for amendment dated October 15, 1975, (2) Amendment No. 17 to License No. DPR-30, with Change No. 31, and (3) the Commission's concurrently issued related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. and at the Moline Public Library, 504 17th Street, Moline, Illinois 60625. A single copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Reactor Licensing.

Dated at Bethesda, Maryland, this 17th day of October, 1975.

FOR THE NUCLEAR REGULATORY COMMISSION


Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Reactor Licensing