



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
December 1, 1988

MEMORANDUM FOR: Sholly Coordinator

FROM: Janice A. Stevens, Project Manager
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE
OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE AND PROPOSED NO SIGNIFICANT HAZARDS
CONSIDERATION DETERMINATION AND OPPORTUNITY FOR A HEARING
(TAC 69550)

Illinois Power Company, Soyland Power Cooperative, Inc., Western Illinois
Power Cooperative, Inc., Docket No. 50-461, Clinton Power Station, Unit No. 1,
DeWitt County, Illinois

Date of amendment request: May 18, 1988

Description of amendment request: This proposed amendment would revise
Technical Specification Table 3.3.2-1 to add a note applicable to item 2.h.
The note would provide additional information regarding the channel
configuration for the Main Steam Line (MSL) Turbine Building Temperature -
High trip channels which provide for automatic isolation of the main steam
lines. This note would clarify the OPERABILITY requirements for the Main
Steam Line Turbine Building Temperature channels thus eliminating any
confusion regarding compliance with the Limiting Condition for Operation and
the associated ACTIONS. The intent of the existing Technical Specification
would remain unchanged.

Basis for proposed no significant hazards consideration determination: The
staff has evaluated this proposed amendment and determined that it involves no
significant hazards considerations. According to 10 CFR 50.92(c), a proposed

u.u.
DFol
1/0
CP-1

amendment to an operating license involves no significant hazards consideration if operation of the facility in accordance with the amendment would not:

- (1) Involve a significant increase in the probability or consequences of an accident previously evaluated; or
- (2) Create the possibility of a new or different kind of accident from any accident previously evaluated; or
- (3) Involve a significant reduction in a margin of safety.

The proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated because the proposed change is only a textual clarification to the operability requirements currently specified in the Technical Specifications for the Main Steam Line Turbine Building Temperature - High trip channels and does not impact the main steam line isolation trip function.

The proposed change does not create the possibility of a new or different kind of accident from any previously evaluated because the proposed change will not create any new modes of operation or new failure modes and does not impact plant design.

The proposed change does not involve a significant reduction in a margin of safety since the change does not involve any changes to setpoints or limits associated with any margin of safety assumed or required by a safety analysis.

For the reasons stated above, the staff believes this proposed amendment involves no significant hazards consideration.

Local Public Document Room location: Vespasian Warner Public Library, 120 West Johnson Street, Clinton, Illinois 61727

Sholly Coordinator

- 3 -

Attorney for licensee: Sheldon Zabel, Esq., Schiff, Hardin and Waite, 7200

Sears Tower, 233 Wacker Drive, Chicago, Illinois 60606

NRC Project Director: Daniel R. Muller

Janice A. Stevens

Janice A. Stevens, Project Manager
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

December 1, 1988

Sholly Coordinator

- 3 -

Attorney for licensee: Sheldon Zabel, Esq., Schiff, Hardin and Waite, 7200

Sears Tower, 233 Wacker Drive, Chicago, Illinois 60606

NRC Project Director: Daniel R. Muller

15/

Janice A. Stevens, Project Manager
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

DISTRIBUTION

- Docket file ✓
- NRC & Local PDRs
- JStevens
- LLuther
- GHolahan
- MVirgilio
- PDIII-2 r/f

gas

PDIII-2:PM
JStevens:dmj
12/1/88

PDIII-2:LA
LLuther *LL*
12/01/88

~~OGC-Rockville
1/ /88~~

PDIII-2:PD
DMuller
12/1/88

December 1, 1988

Sholly Coordinator

- 3 -

Attorney for licensee: Sheldon Zabel, Esq., Schiff, Hardin and Waite, 7200

Sears Tower, 233 Wacker Drive, Chicago, Illinois 60606

NRC Project Director: Daniel R. Muller

15/

Janice A. Stevens, Project Manager
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

DISTRIBUTION

Docket file
NRC & Local PDRs
JStevens
LLuther
GHolahan
MVirgilic
PDIII-2 r/f

gas

PDIII-2:PM
JStevens:dmj
12/1/88

PDIII-2:LA
LLuther LZ
12/1/88

~~OGC-Rockville
1/1/88~~

PDIII-2:PD
DMuller
12/1/88