

September 2, 1988

Docket No. 50-461

Mr. Frank Spangenberg  
Manager - Licensing and Safety  
Clinton Power Station  
Post Office Box 678  
Mail Code V920  
Clinton, Illinois 61727

DISTRIBUTION:

Docket File  
NRC & Local PDRs  
PDIII-2 R/f  
DCruthfield  
GHolahan  
LLuther  
JStevens  
OGC-Rockville  
DHagan  
EJordan

*B. GRIMES*

~~JPatterson~~  
TBarnhart (4)  
~~Wanda Jones~~  
EButcher  
ACRS (10)  
ARM/LFMB  
GPA/PA  
PDIII-2 Plant Files

Dear Mr. Spangenberg:

SUBJECT: TECHNICAL SPECIFICATION CHANGE REQUEST TO INCREASE THE TRIP SETPOINT AND ALLOWABLE VALUE FOR TURBINE BUILDING TEMPERATURE MONITORS (TAC NO. 67163)

Re: Clinton Power Station, Unit 1

The Commission has issued the enclosed Amendment No. 9 to the Facility Operating License No. NPF-62 for the Clinton Power Station, Unit No. 1. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated February 5, 1988, as supplemented July 27, 1988.

This amendment revises Technical Specification Table 3.3.2-2, item 2.h, concerning the Trip Setpoint and Allowable Value for Turbine Building Temperature Monitors. The current effective setpoint value represents a small operating margin and thus could result in an unwanted trip.

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

*151*

Janice A. Stevens, Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III,  
III, IV, V and Special Projects

Enclosures:

1. Amendment No. 9 to License No. NPF-62
2. Safety Evaluation

cc:  
See next page

PDIII-2:PM *gas*  
JStevens:bj  
8/29/88

PDIII-2:LA  
LLuther *LL*  
8/29/88

*yw*  
SPLB  
for WCraig  
8/29/88

OGC-Rock *Rob*  
8/31/88

*JFO*  
PDIII-2:PD  
DButler  
8/30/88



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

September 2, 1988

Docket No. 50-461

Mr. Frank Spangenberg  
Manager - Licensing and Safety  
Clinton Power Station  
Post Office Box 678  
Mail Code V920  
Clinton, Illinois 61727

Dear Mr. Spangenberg:

SUBJECT: TECHNICAL SPECIFICATION CHANGE REQUEST TO INCREASE THE TRIP SETPOINT  
AND ALLOWABLE VALUE FOR TURBINE BUILDING TEMPERATURE MONITORS  
(TAC NO. 67163)

Re: Clinton Power Station, Unit 1

The Commission has issued the enclosed Amendment No. 9 to the Facility Operating License No. NPF-62 for the Clinton Power Station, Unit No. 1. This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated February 5, 1988, as supplemented July 27, 1988.

This amendment revises Technical Specification Table 3.3.2-2, item 2.h, concerning the Trip Setpoint and Allowable Value for Turbine Building Temperature Monitors. The current effective setpoint value represents a small operating margin and thus could result in an unwanted trip.

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

*Janice A. Stevens*

Janice A. Stevens, Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III,  
III, IV, V and Special Projects

Enclosures:

1. Amendment No. 9 to License No. NPF-62
2. Safety Evaluation

cc:

See next page

Mr. Frank A. Spangenberg  
Illinois Power Company

cc:

Mr. D. P. Hall  
Vice President  
Clinton Power Station  
P. O. Box 678  
Clinton, Illinois, 61727

Mr. R. D. Freeman  
Manager-Nuclear Station Engineering Dept.  
Clinton Power Station  
P. O. Box 678  
Clinton, Illinois 61727

Sheldon Zabel, Esquire  
Schiff, Hardin & Waite  
7200 Sears Tower  
233 Wacker Drive  
Chicago, Illinois 60606

Resident Inspector  
U. S. Nuclear Regulatory Commission  
RR 3, Box 229 A  
Clinton, Illinois 61727

Clinton Power Station  
Unit 1

Mr. L. Larson  
Project Manager  
General Electric Company  
175 Curtner Avenue, N/C 395  
San Jose, California 95125

Regional Administrator, Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Chairman of DeWitt County  
c/o County Clerk's Office  
DeWitt County Courthouse  
Clinton, Illinois 61727

Illinois Department  
of Nuclear Safety  
Division of Engineering  
1035 Outer Park Drive, 5th Floor  
Springfield, Illinois, 62704

Mr. Donald Schopfer  
Project Manager  
Sargent & Lundy Engineers  
55 East Monroe Street  
Chicago, Illinois 60603



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

ILLINOIS POWER COMPANY, ET AL

DOCKET NO. 50-461

CLINTON POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 9  
License No. NPF-62

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by the Illinois Power Company\* (IP), Soyland Power Cooperative, Inc. and Western Illinois Power Cooperative, Inc. (the licensees) dated February 5, 1988, as supplemented July 27, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act; and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-62 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised


\*Illinois Power Company is authorized to act as agent for Soyland Power Cooperative, Inc. and Western Illinois Power Cooperative, Inc. and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

8809080199 880902  
PDR ADOCK 05000461  
P PDC

through Amendment No. 9, are hereby incorporated into this license. IP shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Daniel R. Muller, Director  
Project Directorate III-2  
Division of Reactor Projects - III,  
IV, V and Special Projects

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: September 2, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 9  
FACILITY OPERATING LICENSE NO. NPF-62

DOCKET NO. 50-461

Replace the following page of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by amendment number and contains vertical lines indicating the area of change.

Remove

3/4 3-21

Insert

3/4 3-21

TABLE 3.3.2-2 (Continued)  
CRVICS INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
1. <u>PRIMARY AND SECONDARY CONTAINMENT ISOLATION (Continued)</u>		
k. Containment Pressure - High	$\leq 2.62$ psid	$\leq 3.00$ psid
l. Main Steam Line Radiation - High	$\leq 3.0 \times$ full power background	$\leq 3.6 \times$ full power background
m. Fuel Building Exhaust Radiation - High	$\leq 10$ mR/hr	$\leq 17$ mR/hr
n. Manual Initiation	NA	NA
2. <u>MAIN STEAM LINE ISOLATION</u>		
a. Reactor Vessel Water Level - Low Low Low, Level 1	$\geq -145.5$ in.*	$\geq -147.7$ in.
b. Main Steam Line Radiation - High	$\leq 3.0 \times$ full power background	$\leq 3.6 \times$ full power background
c. Main Steam Line Pressure - Low	$\geq 849$ psig	$\geq 837$ psig
d. Main Steam Line Flow - High	$\leq 170$ psid**	$\leq 178$ psid**
e. Condenser Vacuum - Low	$\geq 8.5$ in. Hg vacuum	$\geq 7.6$ in. Hg vacuum
f. Main Steam Line Tunnel Temp. - High	$\leq 165^{\circ}\text{F}$	$\leq 176^{\circ}\text{F}$
g. Main Steam Line Tunnel $\Delta$ Temp. - High	$\leq 54.5^{\circ}\text{F}$	$\leq 60^{\circ}\text{F}$
h. Main Steam Line Turbine Bldg. Temp. - High		
(1) 1E31 - N559 A, B, C, D	$\leq 131.2^{\circ}\text{F}$	$\leq 138^{\circ}\text{F}$
1E31 - N560 A, B, C, D		
1E31 - N561 A, B, C, D		
1E31 - N562 A, B, C, D		
(2) 1E31 - N563 A, B, C, D	$\leq 143.2^{\circ}\text{F}$	$\leq 150^{\circ}\text{F}$
i. Manual Initiation	NA	NA
3. <u>REACTOR WATER CLEANUP SYSTEM ISOLATION</u>		
a. $\Delta$ Flow - High	$\leq 59$ gpm	$\leq 66.1$ gpm
b. $\Delta$ Flow Timer	$\geq 45$ sec.	$\leq 47$ sec.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
SUPPORTING AMENDMENT NO. 9 TO FACILITY OPERATING LICENSE NO. NPF-62

ILLINOIS POWER COMPANY, ET AL.

CLINTON POWER STATION, UNIT 1

DOCKET NO. 50-461

1.0 INTRODUCTION

By letter dated February 5, 1988, as supplemented July 27, 1988, the Illinois Power Company (IP), et al. (the licensees) requested an amendment to Facility Operating License No. NPF-62 for the Clinton Power Station, Unit 1. The proposed amendment consists of a change to Technical Specification Table 3.3.2-2, item 2.h, concerning the Trip Setpoint and Allowable Value for Turbine Building Temperature Monitors. The proposed change would increase the Trip Setpoint from less than or equal to 131.2°F to less than or equal to 143.2°F and the Allowable Value from less than or equal to 138°F to less than or equal to 150°F for Turbine Building Temperature Monitors 1E31-N563A, B, C, and D. The instrument setpoint calculations, performed in accordance with Regulatory Guide 1.105 "Instrument Setpoints", established the current setpoint of 131.2°F for these instruments. A maximum normal operating temperature of 122°F was assumed for the setpoint calculations. Operating experience to date has shown that the ambient temperature that typically exists in the area of the subject instruments is 120-125°F when the reactor is operating at 90-100% rated thermal power. Since Clinton has not yet operated at a sustained full reactor power level during summer conditions, the peak normal operating temperature in the applicable area may be higher. Based on the currently specified setpoint of 131.2°F and the drift allowance of plus or minus 6.8°F, the resulting effective setpoint is 124.4°F. The licensees stated that this effective setpoint value, which represents a very small operating margin, could result in an unwanted trip.

2.0 EVALUATION

The licensees stated that a maximum normal operating temperature of 122°F was assumed for the original setpoint calculations according to the design basis provided by the Architectural Engineer (AE) for Clinton. The current setpoint of 131.2°F for the 1E31-N563A, B, C and D instruments was established based on a maximum normal operating temperature of 122°F, a temperature increase of 16°F resulting from a steam leak equivalent to 25 gpm after two minutes, and a drift allowance of ±6.8°F. The AE indicated that radiological considerations were not included in the determination of this setpoint since it was not the bounding concern in

8809080201 880902  
PDR ADDCK 05000461  
P FDC



this situation and since radiation monitors are installed in the exhaust ductwork from the tunnel and in the common station vent to which the exhaust is directed.

The proposed setpoint of 143.2°F has the same analytical basis as the original setpoint with the exception that the new setpoint corresponds to a temperature increase of 28°F resulting from a steam leak equivalent to 25 gpm after five minutes (instead of two minutes). The licensees stated that the time limit for the assumed leakage rate was established by striking a balance between the minimum time needed before a leak can be detected without causing an inadvertent or unwanted isolation and the maximum time allowed for the leakage condition to be recognized. A leakage time of five minutes is still considered acceptable and consistent with this intent. The applied setpoint methodology, utilizing the actual temperature data, accounts for instrument inaccuracies and drift to ensure that the margin of safety is maintained.

The licensees also stated that the only safety-related components located in the vicinity of the Turbine Building Steam Tunnel in which ambient temperatures are monitored by temperature monitors 1E31-N563A, B, C, and D, are these four temperature monitors themselves. These four monitors are designed to measure ambient air temperatures from 0°F to 500°F. The results of this evaluation were that localized temperatures of 150°F cause no adverse environmental impact on safety-related systems, structures, or components.

Finally, by telephone conference on August 26, 1988, the licensees stated that the maximum temperature that will occur at the location where these temperature sensors are installed will be 250°F. In addition, by letter dated July 27, 1988 the licensees committed to add these sensors to the Clinton Power Station environmental qualification program. This commitment requires that a record of qualification, which includes a temperature profile of 250°F and a qualified life be established for each sensor, i.e., qualification must be in compliance with 10 CFR 50.49. This effort must be completed by no later than September 30, 1988.

### 3.0 ENVIRONMENTAL CONSIDERATION

This amendment involves a change in the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. We have determined that the amendment involves no significant increase in the amounts, and no significant changes in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding.

Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

#### 4.0 CONCLUSION

The proposed change to Technical Specification Table 3.3.2-2, Item 2.h, concerning the Trip Setpoint and Allowable Value for Turbine Building Temperature Monitors is acceptable since the margin of safety as defined in the technical bases is maintained and the equipment in the area is qualified for the environment to which it would be exposed.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Janice A. Stevens, NRR/PDIII-2

Dated: September 2, 1988