## ACTIONS (continued)

CONDITION		REQUIRED ACTION		COMPLETION TIME
C.	One exhaust to atmosphere isolation valve inoperable in MODE 1, 2, 3, or 4.	C. 1	Restore valve to OPERABLE status.	7 days
D.	One CREVS train inoperable for reasons other than Condition A, B, or C in MODE 1, 2, 3, or 4.	D. 1	Restore CREVS train to OPERABLE status.	7 days*
E.	Required Action and associated Completion Time of Condition A, B, C, or D not met in MODE 1, 2, 3, or 4.	E. 1 <u>AND</u>	Be in MODE 3.	6 hours
		E. 2	Be in MODE 5.	36 hours
F.	Required Action and associated Completion Time of Condition B not met during movement of irradiated fuel assemblies.	F. 1	Suspend movement of irradiated fuel assemblies.	Immediately

<sup>\*</sup> This Action is extended from 7 days to 18 days (for loss of the emergency power supply only) during the Unit 1 2002 Refueling Outage. This extension begins when the No. 1A Diesel Generator allowed outage time as specified in Technical Specification 3.8.1 expires. The extension ends when No. 1A Diesel Generator is declared OPERABLE on 4 kV Bus No. 11 under Technical Specification 3.8.1 or 18 days has expired, whichever is first.