

July 26, 1988

Docket No. 50-461

Mr. Frank Spangenberg  
Manager-Licensing and Safety  
Clinton Power Station  
Post Office Box 678  
Mail Code V920  
Clinton, Illinois 61727

DISTRIBUTION

Docket File  
NRC & Local PDRs  
PDIII-2 Rdg.  
DCrutchfield  
LLuther  
MGrotenhuis

OGC-Rockville  
DHagan  
ACRS (10)  
GPA/PA

Dear Mr. Spangenberg:

The Commission has filed the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing" with the Office of the Federal Register for publication. This notice relates to your request of February 5, 1988, to amend the Technical Specifications and Operating License NPF-62 for Clinton Power Station, Unit 1. This amendment consists of a proposed change to Technical Specification Table 3.3.7.5-1 in order to allow inoperability of primary containment isolation valve position indication when the valve/valve operator is electrically deactivated in the isolated position.

Sincerely,

Janice A. Stevens, Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III,  
IV, V and Special Projects

Enclosure:  
As stated

cc: See next page

PDIII-2:PM *JAS*  
JStevens:bj  
5/17/88

PDIII-2:LA  
Luther *JL*  
5/17/88

PDIII-2:PD  
LNorrholm  
5/18/88

*DF01*  
*11*

8808040007 880726  
PDR ADOCK 05000461  
P PDC

July 26, 1988

Docket No. 50-461

Mr. Frank Spangenberg  
Manager-Licensing and Safety  
Clinton Power Station  
Post Office Box 678  
Mail Code V920  
Clinton, Illinois 61727

DISTRIBUTION

Docket File  
NRC & Local PDRs  
PDIII-2 Rdg.  
DCrutchfield  
LLuther  
MGrotenhuis

OGC-Rockville  
DHagan  
ACRS (10)  
GPA/PA

Dear Mr. Spangenberg:

The Commission has filed the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing" with the Office of the Federal Register for publication. This notice relates to your request of February 5, 1988, to amend the Technical Specifications and Operating License NPF-62 for Clinton Power Station, Unit 1. This amendment consists of a proposed change to Technical Specification Table 3.3.7.5-1 in order to allow inoperability of primary containment isolation valve position indication when the valve/valve operator is electrically deactivated in the isolated position.

Sincerely,

Janice A. Stevens, Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III,  
IV, V and Special Projects

Enclosure:  
As stated

cc: See next page

PDIII-2:PM *JAS*  
JStevens:bs  
5/17/88

PDIII-2:LA  
Luther *JL*  
5/17/88

PDIII-2:PD  
LNorrholm  
5/18/88



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

July 26, 1988

Docket No. 50-461

Mr. Frank Spangenberg  
Manager-Licensing and Safety  
Clinton Power Station  
Post Office Box 678  
Mail Code V920  
Clinton, Illinois 61727

Dear Mr. Spangenberg:

The Commission has filed the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing" with the Office of the Federal Register for publication. This notice relates to your request of February 5, 1988, to amend the Technical Specifications and Operating License NPF-62 for Clinton Power Station, Unit 1. This amendment consists of a proposed change to Technical Specification Table 3.3.7.5-1 in order to allow inoperability of primary containment isolation valve position indication when the valve/valve operator is electrically deactivated in the isolated position.

Sincerely,

*Janice A. Stevens*

Janice A. Stevens, Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III,  
IV, V and Special Projects

Enclosure:  
As stated

cc: See next page

Mr. Frank A. Spangenberg  
Illinois Power Company

Clinton Power Station  
Unit 1

cc:

Mr. D. P. Hall  
Vice President  
Clinton Power Station  
P. O. Box 678  
Clinton, Illinois, 61727

Mr. R. D. Freeman  
Manager-Nuclear Station Engineering Dept.  
Clinton Power Station  
P. O. Box 678  
Clinton, Illinois 61727

Sheldon Zabel, Esquire  
Schiff, Hardin & Waite  
7200 Sears Tower  
233 Wacker Drive  
Chicago, Illinois 60606

Resident Inspector  
U. S. Nuclear Regulatory Commission  
RR 3, Box 229 A  
Clinton, Illinois 61727

Mr. L. Larson  
Project Manager  
General Electric Company  
175 Curtner Avenue, N/C 395  
San Jose, California 95125

Regional Administrator, Region III  
799 Roosevelt Road, Bldg. #4  
Glen Ellyn, Illinois 60137

Chairman of DeWitt County  
c/o County Clerk's Office  
DeWitt County Courthouse  
Clinton, Illinois 61727

Illinois Department  
of Nuclear Safety  
Division of Engineering  
1035 Outer Park Drive, 5th Floor  
Springfield, Illinois 62704

Mr. Donald Schopfer  
Project Manager  
Sargent & Lundy Engineers  
55 East Monroe Street  
Chicago, Illinois 60603

UNITED STATES NUCLEAR REGULATORY COMMISSION

ILLINOIS POWER COMPANY

DOCKET NO. 50-461

NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT

TO FACILITY OPERATING LICENSE AND

OPPORTUNITY FOR HEARING

The United States Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-62 issued to Illinois Power Company (the licensee), for operation of Clinton Power Station, Unit 1 located in DeWitt County, Illinois.

This amendment consists of the addition of a note to item 14 on Table 3.3.7.5-1 to allow inoperability of primary containment isolation valve position indication when the valve/valve operator is electrically deactivated in the isolated position. When any motor-operated containment isolation valve is electrically deactivated, its breaker is usually switched to the "OFF" position. Power is consequently lost to the position indication circuit and all position indication in the main control room is lost. ACTION 82 associated with item 14 of Table 3.3.7.5-1 will require a plant shutdown after seven days if all position indication to a primary containment isolation valve is lost.

Prior to issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

By June 27, 1988, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and

8808040008 880726  
PDR ADCK 05000461  
P PDC

who wishes to participate as a party in the proceeding must file a written request for hearing and a petition for leave to intervene. Requests for a hearing and petitions for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR §2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to fifteen (15)

days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter, and the bases for each contention set forth with reasonable specificity. Contentions shall be limited to matters within the scope of the amendment under consideration. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene shall be filed with the Secretary of the Commission, United States Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Branch, or may be delivered to the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. by the above date. Where petitions are filed during the last ten (10) days of the notice period, it is requested that the petitioner or representative for the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-800-325-6000 (in Missouri 1-800-342-6700). The Western Union operator should be given Datagram

Identification Number 3737 and the following message addressed to Leif J. Norrholm: petitioner's name and telephone number; date petition was mailed; plant name; and publication date and page number of this FEDERAL REGISTER NOTICE. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, and to Zeldon Zebel, Esquire, Schiff, Hardin and Waite, 7200 Sears Tower, 233 Wacker Drive, Chicago, Illinois 60606, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petition and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board, that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).


If a request for hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendment dated February 5, 1988, which is available for public inspection at

the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. 20555, and at the Vespasian Warner Public Library, 120 West Johnson Street, Clinton, Illinois 61727.

Dated at Rockville, Maryland this 18th day of May 1988.

FOR THE NUCLEAR REGULATORY COMMISSION



Leif J. Norrholm, Acting Director  
Project Directorate III-2  
Division of Reactor Projects - III,  
IV, V and Special Projects



