

April 11, 1988

Docket No. 50-461

DISTRIBUTION

<u>Docket File</u>	OGC-Rockville
NRC & Local PDRs	EJordan
PDIII-2 Rdg.	JPartlow
DCrutchfield	ACRS (10)
GHolahan	GPA/PA
LLuther	PDIII-2 Plant File
JStevens	

Mr. Frank Spangenberg
Manager - Licensing and Safety
Clinton Power Station
Post Office Box 678
Mail Code V920
Clinton, Illinois 60690

Dear Mr. Spangenberg:

By letter dated March 21, 1988, the Commission issued Amendment No. 2 to Facility Operating License No. NPF-62 for the Clinton Power Station, Unit No. 1. This amendment consisted of revisions to the Technical Specifications. Revised Technical Specification page 3/4 6-51 contained a typographical error; a corrected page is enclosed for incorporation into the Technical Specifications.

Sincerely,

Original Signed by/

Janice A. Stevens, Project Manager
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
As stated

cc: See next page

JAS
PDIII-2:JM
JStevens:bj
4/8/88

PDIII-2:LA
LLuther *JL*
4/11/88

~~OGC-Rockville
1/1/88~~

P.S. FOR
PDIII-2:PD
DMuller
4/11/88

BBO41B0464 BBO411
PDR ADOCK 05000461
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

April 11, 1988

Docket No. 50-461

Mr. Frank Spangenberg
Manager-Licensing and Safety
Clinton Power Station
Post Office Box 678
Mail Code V920
Clinton, Illinois 60690

Dear Mr. Spangenberg:

By letter dated March 21, 1988, the Commission issued Amendment No. 2 to Facility Operating License No. NPF-62 for the Clinton Power Station, Unit No. 1. This amendment consisted of revisions to the Technical Specifications. Revised Technical Specification page 3/4 6-51 contained a typographical error; a corrected page is enclosed for incorporation into the Technical Specifications.

Sincerely,

A handwritten signature in cursive script that reads "Janice A. Stevens".

Janice A. Stevens, Project Manager
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
As stated

cc: See next page

Mr. Frank A. Spangenberg, III
Illinois Power Company

cc:

Mr. D. P. Hall
Vice President
Clinton Power Station
P.O. Box 678
Clinton, Illinois 61727

Mr. R. D. Freeman
Manager-Nuclear Station Engineering Dpt.
Clinton Power Station
P.O. Box 678
Clinton, Illinois 61727

Sheldon Zabel, Esquire
Schiff, Hardin & Waite
7200 Sears Tower
233 Wacker Drive
Chicago, Illinois 60606

Resident Inspector
U.S. Nuclear Regulatory Commission
RR 3, Box 229 A
Clinton, Illinois 61727

Clinton Power Station
Unit 1

Mr. L. Larson
Project Manager
General Electric Company
175 Curtner Avenue, N/C 395
San Jose, California 95125

Regional Administrator, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Chairman of DeWitt County
c/o County Clerk's Office
DeWitt County Courthouse
Clinton, Illinois 61727

Illinois Department
of Nuclear Safety
Division of Engineering
1035 Outer Park Drive, 5th Floor
Springfield, Illinois 62704

Mr. Donald Schopfer
Project Manager
Sargent & Lundy Engineers
55 East Monroe Street
Chicago, Illinois 60603

CLINTON - UNIT 1

3/4 6-51

AMENDMENT NO. 2

TABLE 3.6.4-1 (Continued)
CONTAINMENT ISOLATION VALVES

<u>VALVE NUMBER</u>	<u>PENETRATION NUMBER</u>	<u>ISOLATION SIGNAL†</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>SECONDARY CONTAINMENT BYPASS PATH (YES/NO)</u>	<u>TEST PRESSURE (psig)*</u>
<u>Test Connections, Vents and Drains</u> ^(a) (Continued)						
64) Drywell Pressure 1CM076 1CM077	151 203	NA	1, 2, 3(a)	NA	No	9.0
65) Reactor Pressure 1CM072 1CM073	151	NA	1, 2, 3(a)	NA	No	9.0
66) Reactor Pressure 1CM074 1CM075	160	NA	1, 2, 3(a)	NA	No	9.0
67) Equipment Hatch 1CM099	1	NA	1, 2, 3(a)	NA	No	9.0
68) Suppression Pool Level 1E51 - F437A ^(h) 1E51 - F437B ^(h)	177	NA	1, 2, 3(a)	NA	No	9.0
69) Suppression Pool Level 1E22 - F381A ^(h) 1E22 - F381B ^(h) 1SM027A ^(h) 1SM027B ^(h)	179	NA	1, 2, 3(a)	NA	No	9.0
70) Suppression Pool Level 1SM026A ^(h) 1SM026B ^(h)	181	NA	1, 2, 3(a)	NA	No	9.0
71) Suppression Pool Level 1CM100A ^(h) 1CM100B ^(h)	183	NA	1, 2, 3(a)	NA	No.	9.0