

March 20, 1995

Distribution w/encl:

Docket File EAdensam  
PUBLIC JHannon  
PDIII-3 Reading File  
ACRS (4)  
OGC  
WAxelson, RIII

Mr. Richard F. Phares  
Director - Licensing  
Clinton Power Station  
P. O. Box 678  
Mail Code V920  
Clinton, IL 61727

SUBJECT: CLOSEOUT OF ITEMS RELATED TO AMENDMENT NO. 68 - CLINTON POWER STATION, UNIT NO. 1 (TAC NO. M91117)

Dear Mr. Phares:

Amendment No. 68, issued on December 24, 1992, modified the Clinton Power Station Technical Specifications (TSs) by deleting numerous component lists as recommended in NRC Generic Letter (GL) 91-08, "Removal of Component Lists from Technical Specifications," and the reactor vessel specimen withdrawal schedule as recommended in GL 91-01, "Removal of the Schedule for the Withdrawal of Reactor Vessel Material Specimens from Technical Specifications."

Our Safety Evaluation did not take actions with respect to two of the proposals included in your letter of February 7, 1992 (U-601884). Your letter proposed modifying Surveillance Requirement 4.6.1.7 associated with TS 3.6.1.7, "Primary Containment Average Air Temperature," and Surveillance Requirement 4.6.2.6 associated with TS 3.6.2.6, "Drywell Average Air Temperature." These changes would delete the method and list of instrument locations used to verify both the primary containment and drywell average air temperature. The staff deferred action on these items due to their generic implications and the concurrent development of NUREG-1434, "Improved BWR-6 Technical Specifications."

Both of these issues were subsequently resolved with the issuance of Amendment No. 95 on December 2, 1994. The methods for performing these surveillances were relocated to the TS Bases and the lists of instrument locations were relocated to plant procedures. These changes were made in accordance with the guidance in NUREG-1434. Therefore, the staff considers both of these issues to be resolved.

Sincerely, ORIGINAL SIGNED BY: Douglas V. Pickett

Douglas V. Pickett, Project Manager  
Project Directorate III-3  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

cc: See next page

DOCUMENT NAME: G:\CLINTON\AMEND68.FIX

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures  
"N" = No copy

OFFICE	LA:PDIII-3	C	PM:PDIII-3	(A)PD:PDIII-3
NAME	MRushbrock		DPickett	GMarcus GHM
DATE	03/20/95		03/20/95	03/20/95

OFFICIAL RECORD COPY

230141

9503240054 950320  
PDR ADDCK 05000461  
P PDR

NRC FILE CENTER COPY

DF01 10

Illinois Power Company

Clinton Power Station  
Unit No. 1

cc:

Mr. J. G. Cook  
Vice President  
Clinton Power Station  
Post Office Box 678  
Clinton, Illinois 61727

Illinois Department  
of Nuclear Safety  
Office of Nuclear Facility Safety  
1035 Outer Park Drive  
Springfield, Illinois 62704

Mr. J. A. Miller  
Manager Nuclear Station  
Engineering Department  
Clinton Power Station  
Post Office Box 678  
Clinton, Illinois 61727

Resident Inspector  
U.S. Nuclear Regulatory Commission  
RR#3, Box 229 A  
Clinton, Illinois 61727

Mr. R. T. Hill  
Licensing Services Manager  
General Electric Company  
175 Curtner Avenue, M/C 481  
San Jose, California 95125

Regional Administrator, Region III  
801 Warrenville Road  
Lisle, Illinois 60532-4351

Chairman of DeWitt County  
c/o County Clerk's Office  
DeWitt County Courthouse  
Clinton, Illinois 61727

Mr. Robert Neumann  
Office of Public Counsel  
State of Illinois Center  
100 W. Randolph, Suite 11-300  
Chicago, Illinois 60601

Mr. J. W. Blattner  
Project Manager  
Sargent & Lundy Engineers  
55 East Monroe Street  
Chicago, Illinois 60603