

**From:** Peter Tam  
**To:** INTERNet:dosaj@nimo.com; INTERNet:leonardm@nimo.com;  
internet:wolniakd@nimo.com  
**Date:** 4/5/02 3:18PM  
**Subject:** NMP1 Amendment Re. RETS (TAC MB2442)

John:

We are essentially done with reviewing your 10/19/01 amendment application. Our reviewer Audrey Hayes made a number of observations and would like to discuss with your people in a conference call:

**ODCM, Change #21**

1. You changed the word "or," (NUREG-1302 3.11.4.a) to "and" in the third sentence of proposed TS Section 3.6.15.d, page I 3.1-24 (Controls) of the proposed ODCM.
2. In the same section, you omitted NUREG-1302 3.11.4.a descriptive wording regarding the content of the special report.

**TS, Change 36**

1. Proposed TS 6.12.1.d.1: You proposed alternate wording (radiation monitoring and indicating device) for the NUREG-1433 wording (A radiation monitoring device that continuously displays radiation dose rates in the area.) You subsequently use "radiation monitoring and indicating device" throughout the remainder of the proposed TS.
2. Proposed TS 6.12.1.d.2: You proposed alternate wording (alarming dosimeter) for the NUREG-1433 wording (A radiation monitoring device that continuously integrates the radiation dose rates in the area and alarms when the device's dose alarm setpoint is reached...) You subsequently use "alarming dosimeter" throughout the remainder of the proposed TS.
3. Proposed TS 6.12.1.d.4(b): You omitted the NUREG-1433 7.7.1.4 (ii) wording "...and with the means to communicate with individuals in the area who are covered by such surveillance."
4. Proposed TS 6.12.2.a and TS 6.12.2.1.2: You omitted "continuously" with respect to NUREG-1433 5.7.2.a wording "...shall be provided with a locked or continuously guarded door or gate..."
5. Proposed TS 6.12.2.d.4: You omitted NUREG-1433 5.7.2.d.4 wording "...in the area."

Please call me to schedule a conference call. This e-mail only serves to communicate issues to be discussed in the conference call. **It does not convey a formal NRC staff position and does not formally request for additional information.** Disposition of the above issues will be discussed in the conference call.

Peter S. Tam, Senior Project Manager  
Project Directorate I-1  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

e-mail: pst@nrc.gov Tel.: 301-415-1451

**CC:** Audrey Hayes; Stephen Klementowicz

**Mail Envelope Properties**

(3CAE069A.501 : 10 : 20510)

**Subject:** NMP1 Amendment Re. RETS (TAC MB2442)

**Creation Date:** 4/5/02 3:18PM

**From:** Peter Tam

**Created By:** PST@nrc.gov

<b>Recipients</b>	<b>Action</b>	<b>Date &amp; Time</b>
nimo.com	Transferred	04/05/02 03:18PM
dosaj (INternet:dosaj@nimo.com)		
leonardm (INternet:leonardm@nimo.com)		
wolniakd (internet:wolniakd@nimo.com)		

nrc.gov		
owf2_po.OWFN_DO	Delivered	04/05/02 03:18PM
ACH2 CC (Audrey Hayes)	Opened	04/09/02 10:44AM
SXK CC (Stephen Klementowicz)	Opened	04/05/02 03:36PM

<b>Post Office</b>	<b>Delivered</b>	<b>Route</b>
nimo.com		INternet
owf2_po.OWFN_DO	04/05/02 03:18PM	nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	3928	04/05/02 03:18PM

**Options**

<b>Auto Delete:</b>	No
<b>Expiration Date:</b>	None
<b>Notify Recipients:</b>	Yes
<b>Priority:</b>	Standard
<b>Reply Requested:</b>	No
<b>Return Notification:</b>	None

<b>Concealed Subject:</b>	No
<b>Security:</b>	Standard

<b>To Be Delivered:</b>	Immediate
<b>Status Tracking:</b>	Delivered & Opened