

September 15, 1994

Clinton Power Station
ATTN: Mr. Richard F. Phares
Director - Licensing
Post Office Box 678
Mail Code V920
Clinton, Illinois 61727

DISTRIBUTION

Docket File
NRC & Local PDRs
PDIII-3 r/f
JRoe
JZwolinski
JHannon
MRushbrook
DPickett
OGC

GHill (2)
CGrimes
ACRS (10)
OPA
OC/LFDCBB
BClayton, RIII
EGreenman, RIII
DHagan

SUBJECT: REVISION TO AMENDMENT NO. 93 TO FACILITY OPERATING LICENSE NO.
NPF-62 - CLINTON POWER STATION, UNIT NO. 1 (TAC NO. M90037)

Dear Mr. Phares:

The U.S. Nuclear Regulatory Commission issued Amendment No. 93 to Facility Operating License No. NPF-62 for the Clinton Power Station, Unit No. 1 on September 2, 1994. The amendment modified Technical Specification Table 4.8.1.1.2-1, "Diesel Generator Test Schedule," such that the valid diesel generator failures experienced on August 3, 1993, June 7 and July 12, 1994, would not contribute towards accelerated testing of the Division 1 diesel generator.

As identified by your staff, we inadvertently introduced typographical errors on the amended table of the technical specifications. Enclosed for your use is the corrected Table 4.8.1.1.2-1. We have not reissued the Safety Evaluation issued with the original amendment.

We regret any inconvenience this may have caused.

Sincerely,

Original Signed By:
Douglas V. Pickett, Senior Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-461

Enclosure:
Technical Specification page 3/4 8-10

cc w/enclosure
see next page

OFFICE	LA:PDIII-3	PM:PDIII-3	D:PDIII-3
NAME	MRushbrook	DPickett	JHannon
DATE	9/15/94	9/15/94	9/15/94

FILENAME: G:\CLINTON\AMEND93.REV

9409210030 940915
PDR ADOCK 05000461
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

September 15, 1994

Clinton Power Station
ATTN: Mr. Richard F. Phares
Director - Licensing
Post Office Box 678
Mail Code V920
Clinton, Illinois 61727

SUBJECT: REVISION TO AMENDMENT NO. 93 TO FACILITY OPERATING LICENSE NO.
NPF-62 - CLINTON POWER STATION, UNIT NO. 1 (TAC NO. M90037)

Dear Mr. Phares:

The U.S. Nuclear Regulatory Commission issued Amendment No. 93 to Facility Operating License No. NPF-62 for the Clinton Power Station, Unit No. 1 on September 2, 1994. The amendment modified Technical Specification Table 4.8.1.1.2-1, "Diesel Generator Test Schedule," such that the valid diesel generator failures experienced on August 3, 1993, June 7 and July 12, 1994, would not contribute towards accelerated testing of the Division 1 diesel generator.

As identified by your staff, we inadvertently introduced typographical errors on the amended table of the technical specifications. Enclosed for your use is the corrected Table 4.8.1.1.2-1. We have not reissued the Safety Evaluation issued with the original amendment.

We regret any inconvenience this may have caused.

Sincerely,

A handwritten signature in cursive script that reads "Douglas V. Pickett".

Douglas V. Pickett, Senior Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-461

Enclosure:
Technical Specification page 3/4 8-10

cc w/enclosure
see next page

Mr. Richard F. Phares
Illinois Power Company

Clinton Power Station
Unit No. 1

cc:

Mr. John Cook
Vice President
Clinton Power Station
Post Office Box 678
Clinton, Illinois 61727

Illinois Department
of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Mr. J. A. Miller
Manager Nuclear Station
Engineering Department
Clinton Power Station
Post Office Box 678
Clinton, Illinois 61727

Resident Inspector
U.S. Nuclear Regulatory Commission
RR#3, Box 229 A
Clinton, Illinois 61727

Mr. R. T. Hill
Licensing Services Manager
General Electric Company
175 Curtner Avenue, M/C 481
San Jose, California 95125

Regional Administrator, Region III
801 Warrenville Road
Lisle, Illinois 60532-4351

Chairman of DeWitt County
c/o County Clerk's Office
DeWitt County Courthouse
Clinton, Illinois 61727

Mr. Robert Neumann
Office of Public Counsel
State of Illinois Center
100 W. Randolph, Suite 11-300
Chicago, Illinois 60601

Mr. J. W. Blattner
Project Manager
Sargent & Lundy Engineers
55 East Monroe Street
Chicago, Illinois 60603

TABLE 4.8.1.1.2-1

DIESEL GENERATOR TEST SCHEDULE

<u>NUMBER OF FAILURES IN LAST 20 VALID TESTS*</u>	<u>NUMBER OF FAILURES IN LAST 100 VALID TESTS*</u>	<u>TEST FREQUENCY</u>
≤ 1	≤ 4	At least once per 31 days
≥ 2	≥ 5	At least once per 7 days**

*Criteria for determining number of failures and number of valid tests shall be in accordance with Regulatory Position C.2.e of Regulatory Guide 1.108, but determined on a per diesel generator basis, except that the valid test failures of the Division 1 diesel generator identified on August 3, 1993; June 7, 1994; and July 12, 1994 may be excluded from the total number of failures used to determine the diesel generator test frequency.

For the purposes of determining the required test frequency, the previous test failure count may be reduced to zero if a complete diesel overhaul to like-new condition is completed, provided that the overhaul, including appropriate post-maintenance operation and testing, is specifically approved by the manufacturer and if acceptable reliability has been demonstrated. The reliability criterion shall be the successful completion of 14 consecutive tests in a single series. Ten of these tests shall be in accordance with the routine Surveillance Requirements 4.8.1.1.2.a.4 and 4.8.1.1.2.a.5 and four tests in accordance with the 184-day testing requirement of Surveillance Requirements 4.8.1.1.2.a.4 and 4.8.1.1.2.a.5. If this criterion is not satisfied during the first series of tests, any alternate criterion to be used to transvalue the failure count to zero requires NRC approval.

**This test frequency shall be maintained until seven consecutive failure free demands have been performed and the number of failures in the last 20 valid demands has been reduced to less than or equal to one.