

Docket File

UNCLASSIFIED

X

50-315/362
1 2

X

X

USAEC
A GIAMBUSSO
BETHESDA, MARYLAND

INDIANA & MICHIGAN ELECTRIC COMPANY
JOHN TILLINGHAST, VICE PRESIDENT, P. O. BOX 18
BOWLING GREEN STATION, NEW YORK, NEW YORK 1004

INFO: USAEC, REGION III, REGULATORY OPERATIONS

ON NOVEMBER 20, 1974 YOUR S. MILIOTI REQUESTED BY TELECON WITH OUR
R. BENEDICT TEMPORARY RELIEF FROM CERTAIN REQUIREMENTS OF THE
D. C. COOK NUCLEAR PLANT UNIT 1 TECHNICAL SPECIFICATIONS. THE
RELIEF REQUESTED WAS RELIEF FROM ACTION 20 OF TECHNICAL SPECIFICA-
TION 3/4.3.3 RADIATION MONITORING INSTRUMENTATION, DURING THE
CONDUCTING OF THE CONTAINMENT INTEGRATED LEAK RATE TEST. ACTION 20
REQUIRES THAT GRAB SAMPLES BE TAKEN EVERY 8 HOURS IF A PROCESS
MONITORING CHANNEL IS INOPERABLE. THESE CHANNELS WILL BE
INOPERABLE DURING THE LEAK RATE TEST BECAUSE THEY ISOLATE AT 3
PSIG. OBTAINING GRAB SAMPLES WOULD INTERFERE WITH CONDUCT OF THE
LEAK RATE TEST. THE REACTOR IS IN COLD SHUTDOWN MODE 5.

LB

OFFICE						
SURNAME						
DATE						

THE RELIEF REQUESTED WAS GRANTED BECAUSE THERE IS NO SIGNIFICANT HAZARDS CONSIDERATION INVOLVED AND THE PROPOSED CHANGE WOULD NOT ENDANGER THE HEALTH AND SAFETY OF THE PUBLIC. THE D. C. COOK UNIT 1 OPERATIONS SUPERVISOR, BURT SVENSSON, WAS NOTIFIED OF THE RELIEF BY R. BENEDICT BY TELECON ON NOVEMBER 20, 1974. THIS TELEGRAM CONFIRMS THAT ORAL AUTHORIZATION.

Original signed by
 S. A. Varga
 A. Giambusso, Deputy Director
 for Reactor Projects
 Directorate of Licensing

- DISTRIBUTION:
 A. Giambusso
 Docket File
 AEC PDR
 Local PDR
 R. Benedict
 K. Kniel
 V. Moore
 LWR 2-2 Reading

NOV 21 1974

OFFICE →	LWR 2-2	LWR 2-2	AD/LWR 2	OD:BE		
SURNAME →	RABenedict/as	KKniel	VAMoore	AGiambusso		
DATE →	11/21/74	11/21/74	11/21/74	11/21/74		