


Doc-Ket  
file

APR 20 1981

Docket Nos. 50-315  
and 50-316

Mr. John Dolan, Vice President  
Indiana and Michigan Electric Co.  
Post Office Box 18  
Bowling Green Station  
New York, New York 10004



Dear Mr. Dolan:

SUBJECT: ORDER FOR MODIFICATION OF LICENSES CONCERNING PRIMARY COOLANT  
SYSTEM PRESSURE ISOLATION VALVES

This letter transmits an Order for Modification of License which revises the Technical Specifications for Facility Operating License No. DPR-58 and DPR-74 for the D. C. Cook Nuclear Plant, Unit Nos. 1 and 2. The change is a result of the information you provided in response to our 10 CFR 50.54(f) letter of February 23, 1980, regarding primary coolant system pressure isolation valves. Based upon our review of your response, as well as other previously docketed information, we have concluded that a WASH-1400 Event V valve configuration exists at your facility and that corrective action as defined in the attached Order is necessary.

Attached to the Order for Modification of License is the Technical Evaluation Report (TER) which supports the Order; and the plant Technical Specifications which will ensure public health and safety over the operating life of your facility. We are aware that there may be editorial corrections to the attached TER. Please note that the Technical Specifications correctly delineate the requirements for your facility.

In addition to Event V valve configurations, we are continuing our efforts to review other configurations located at high pressure/low pressure system boundaries for their potential risk contribution to an intersystem LOCA. Therefore, further activity regarding the broader topic of intersystem LOCA's may be expected in the future.

cp  
3

8105040050

p

OFFICE							
SURNAME							
DATE							

A copy of the enclosed Order is being filed with the Office of the Federal Register for publication.

Sincerely,

Original signed by:

Original signed by:

Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

Enclosure:  
Order for Modification  
of Licenses

cc w/enclosure:  
See next page

DISTRIBUTION  
Docket File-2  
NRC PDR  
L PDR  
TERA-2  
NSIC  
ORB#1 Rdg  
HDenton  
ECase  
DEisenhut  
RPurple  
TNovak  
RTedesco  
GLainas  
CParrish  
SMiner  
OELD  
IE-3  
BJones-8  
ACRS-16  
OPA  
SECY  
RDiggs  
JHeltemes  
Gray File+4

NA  
4/14/81

OFFICE	ORB#1:DL	ORB#1:DL	ORB#1:DL	AD OR:DL	OELD	DL:
SURNAME	CParrish	SMiner;cf	SVarga	TNovak		DGEisenhut
DATE	3/2/81	3/2/81	3/2/81	4/1/81	2/ /81	4/20/81

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

Docket file-2

April 20, 1981

Docket Nos. 50-315  
and 50-316

Mr. John Dolan, Vice President  
Indiana and Michigan Electric Co.  
Post Office Box 18  
Bowling Green Station  
New York, New York 10004

Dear Mr. Dolan:

SUBJECT: ORDER FOR MODIFICATION OF LICENSES CONCERNING PRIMARY COOLANT  
SYSTEM PRESSURE ISOLATION VALVES

This letter transmits an Order for Modification of License which revises the Technical Specifications for Facility Operating License No. DPR-58 and DPR-74 for the D. C. Cook Nuclear Plant, Unit Nos. 1 and 2. The change is a result of the information you provided in response to our 10 CFR 50.54(f) letter of February 23, 1980, regarding primary coolant system pressure isolation valves. Based upon our review of your response, as well as other previously docketed information, we have concluded that a WASH-1400 Event V valve configuration exists at your facility and that corrective action as defined in the attached Order is necessary.


Attached to the Order for Modification of License is the Technical Evaluation Report (TER) which supports the Order; and the plant Technical Specifications which will ensure public health and safety over the operating life of your facility. We are aware that there may be editorial corrections to the attached TER. Please note that the Technical Specifications correctly delineate the requirements for your facility.

In addition to Event V valve configurations, we are continuing our efforts to review other configurations located at high pressure/low pressure system boundaries for their potential risk contribution to an intersystem LOCA. Therefore, further activity regarding the broader topic of intersystem LOCA's may be expected in the future.

- 2 -

A copy of the enclosed Order is being filed with the Office of the Federal Register for publication.

Sincerely,

  
Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

Enclosure:  
Order for Modification  
of Licenses

cc w/enclosure:  
See next page

Mr. John Dolan  
Indiana and Michigan Electric Company

cc: Mr. Robert W. Jurgensen  
Chief Nuclear Engineer  
American Electric Power  
Service Corporation  
2 Broadway  
New York, New York 10004

Gerald Charnoff, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

Citizens for a Better Environment  
59 East Van Buren Street  
Chicago, Illinois 60605

Maude Preston Palenske Memorial  
Library  
500 Market Street  
St. Joseph, Michigan 49085

Mr. D. Shaller, Plant Manager  
Donald C. Cook Nuclear Plant  
P. O. Box 458  
Bridgman, Michigan 49106

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
7700 Red Arrow Highway  
Stevensville, Michigan 49127

Mr. Wade Schuler, Supervisor  
Lake Township  
Baroda, Michigan 49101

Mr. William R. Rustem (2)  
Office of the Governor  
Room 1 - Capitol Building  
Lansing, Michigan 48913

Honorable James Bemnek, Mayor  
City of Bridgman, Michigan 49106

Director, Criteria and Standards Division  
Office of Radiation Programs (ANR-460)  
U. S. Environmental Protection Agency  
Washington, D. C. 20460

U. S. Environmental Protection Agency  
Federal Activities Branch  
Region V Office  
ATTN: EIS COORDINATOR  
230 South Dearborn Street  
Chicago, Illinois 60604

Maurice S. Reizen, M.D.  
Director  
Department of Public Health  
P. O. Box 30035  
Lansing, Michigan 48909

William J. Scanlon, Esquire  
2034 Pauline Boulevard  
Ann Arbor, Michigan 48103

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of	)	
Indiana and Michigan	)	
Electric Company	)	
(Donald C. Cook Nuclear	)	Docket Nos. 50-315, 50-316
Plant, Units 1 and 2)	)	
	)	
	)	

ORDER FOR MODIFICATION OF LICENSES

I

The Indiana and Michigan Electric Company (the licensee) holds Facility Operating License Nos. DPR-58 and DPR-74, which authorizes the licensee to operate the D. C. Cook Unit Nos. 1 and 2 at power levels not in excess of 3250 and 3391 megawatts thermal rated power respectively. The licenses were originally issued on October 24, 1974 and December 23, 1977 and both will expire on March 25, 2009. The facility, which is located at the licensee's site in Barrien County, Michigan, consists of two pressurized water reactors (PWR) used for the commercial generation of electricity.

II

The Reactor Safety Study (RSS), WASH-1400, identified in a PWR an inter-system loss of coolant accident (LOCA) which is a significant contributor to risk of core melt accidents (Event V). The design examined in the RSS contained in-series check valves isolating the high pressure Primary Coolant System (PCS) from the Low Pressure Injection System (LPIS) piping. The scenario which leads to the Event V accident is initiated by the failure of these check valves to function as a pressure isolation barrier. This causes an overpressurization and rupture of the LPIS low pressure piping which results in a LOCA that bypasses containment.

In order to better define the Event V concern, all light water reactor licensees were requested by letter dated February 23, 1980, to provide the following in accordance with 10 CFR 50.54(f):

1. Describe the valve configurations and indicate if an Event V isolation valve configuration exists within the Class I boundary of the high pressure piping connecting PCS piping to low pressure system piping; e.g., (1) two check valves in series, or (2) two check valves in series with a motor operated valve (MOV);
2. If either of the above Event V configurations exist, indicate whether continuous surveillance or periodic tests are being performed on such valves to ensure integrity. Also indicate whether valves have been known, or found, to lack integrity; and
3. If either of the above Event V configurations exist, indicate whether plant procedures should be revised or if plant modifications should be made to increase reliability.

In addition to the above, licensees were asked to perform individual check valve leak testing prior to plant startup after the next scheduled outage.

By letter dated March 24, 1980, the licensee responded to our February letter. Based upon the NRC review of this response as well as the review of previously docketed information for the facility, I have concluded in consonance with the attached Safety Evaluation (Attachment 1) that one or more valve configuration(s) of concern exist at the facility. The attached Technical Evaluation Report (TER) (Attachment 2) provides, in Section 4.0, a tabulation of the subject valves.

- 3 -

The staff's concern has been exacerbated due not only to the large number of plants which have an Event V configuration(s) but also because of recent unsatisfactory operating experience. Specifically, two plants have leak tested check valves with unsatisfactory results. At Davis-Besse, a pressure isolation check valve in the LPIS failed and the ensuing investigation found that valve internals had become disassembled. At the Sequoyah Nuclear Plant, two Residual Heat Removal (RHR) injection check valves and one RHR recirculation check valve failed because valves jammed open against valve over-travel limiters.

It is, therefore, apparent that when pressure isolation is provided by two in-series check valves and when failure of one valve in the pair can go undetected for a substantial length of time, verification of valve integrity is required. Since these valves are important to safety, they should be tested periodically to ensure low probability of gross failure. As a result, I have determined that periodic examination of check valves must be undertaken by the licensee as provided in Section III below to verify that each valve is seated properly and functioning as a pressure isolation device. Such testing will reduce the overall risk of an inter-system LOCA. The testing mandated by this Order may be accomplished by direct volumetric leakage measurement or by other equivalent means capable of demonstrating that leakage limits are not exceeded in accordance with Section 2.2 of the attached TER.



- 4 -

In view of the operating experiences described above and the potential consequences of check valve failure, I have determined that prompt action is necessary to increase the level of assurance that multiple pressure isolation barriers are in place and will remain intact. Therefore, the public health, safety and interest require that this modification of Facility Operating Licenses Nos. DPR-58 and DPR-74 be immediately effective.

## III

Accordingly, pursuant to Section 161i of the Atomic Energy Act of 1954, as amended, and the Commission's regulations in 10 CFR Parts 2 and 50, IT IS HEREBY ORDERED THAT EFFECTIVE IMMEDIATELY, Facility Operating Licenses Nos. DPR-58 and DPR-74 is modified by the addition of the following requirements:

1. Implement Technical Specifications (Attachment 3) which require periodic surveillance over the life of the plant and which specify limiting conditions for operation for PCS pressure isolation valves.
2. If check valves have not been (a) individually tested within 12 months preceding the date of the Order, and (b) found to comply with the leakage rate criteria set forth in the Technical Specifications described in Attachment 3, the MOV in each line shall be closed within 30 days of the effective date of this Order and quarterly Inservice Inspection (ISI) MOV cycling ceased until the check valve tests have been satisfactorily accomplished. (Prior to closing the MOV, procedures shall be implemented and operators trained to assure

that the MOV remains closed. Once closed, the MOV shall be tagged closed to further preclude inadvertent valve opening).

3. The MOV shall not be closed as indicated in paragraph 2 above unless a supporting safety evaluation has been prepared. If the MOV is in an emergency core cooling system (ECCS), the safety evaluation shall include a determination as to whether the requirements of 10 CFR 50.46 and Appendix K to 10 CFR Part 50 will continue to be satisfied with the MOV closed. If the MOV is not in an ECCS, the safety evaluation shall include a determination as to whether operation with the MOV closed presents an unreviewed safety question as defined in 10 CFR 50.59(a)(2). If the requirements of 10 CFR 50.46 and Appendix K have not been satisfied, or if an unreviewed safety question exists as defined in 10 CFR 50.59, then the facility shall be shut down within 30 days of the date of this Order and remain shutdown until check valves are satisfactorily tested in accordance with the Technical Specifications set forth in Attachment 3.
4. The records of the check valve tests required by this Order shall be made available for inspection by the NRC's Office of Inspection and Enforcement.

- 6 -

## IV

The licensee or any other person who has an interest affected by this Order may request a hearing on this Order within 25 days of its publication in the Federal Register. A request for hearing shall be submitted to the Secretary, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555. A copy of the request shall also be sent to the Executive Legal Director at the same address, and to Gerald Charnoff Esquire, Shaw, Pitman, Potts and Trowbridge, 1800 M Street N.W., Washington, D.C., 20036, attorney for the licensee. If a hearing is requested by a person other than the licensee, that person shall describe, in accordance with 10 CFR 2.714(a)(2), the manner in which his or her interest is affected by this Order. ANY REQUEST FOR A HEARING SHALL NOT STAY THE IMMEDIATE EFFECTIVENESS OF THIS ORDER.


If a hearing is requested by the licensee or other person who has an interest affected by this Order, the Commission will issue an order designating the time and place of any such hearing. If a hearing is held, the issues to be considered at such a hearing shall be:

- (a) Whether the licensee should be required to individually leak test check valves in accordance with the Technical Specifications set forth in Attachment 3 to this Order.
- (b) Whether the actions required by Paragraphs 2 and 3 of Section III of this Order must be taken if check valves have not been tested within 12 months preceding the date of this order.

- 7 -

Operation of the facility on terms consistent with this Order is not stayed by the pendency of any proceedings on this Order. In the event that a need for further action becomes apparent, either in the course of proceedings on this Order or any other time, the Director will take appropriate action.

FOR THE NUCLEAR REGULATORY COMMISSION

  
\_\_\_\_\_  
Darrell G. Eisenhower, Director  
Division of Licensing

Effective Date: April 20, 1981  
Bethesda, Maryland

## Attachments:

1. Safety Evaluation Report
2. Technical Evaluation Report
3. Technical Specifications



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON D C 20555

Attachment 1

SAFETY EVALUATION REPORT  
D. C. COOK NUCLEAR PLANT, UNIT NOS. 1 AND 2  
PRIMARY COOLANT SYSTEM PRESSURE ISOLATION VALVES  
(WASH-1400, EVENT V)

### 1.0 Introduction

The Reactor Safety Study (RSS), WASH-1400, identified in a PWR an intersystem loss of coolant accident (LOCA) which is a significant contributor to risk of core melt accidents (Event V). The design examined in the RSS contained in-series check valves isolating the high pressure Primary Coolant System (PCS) from the Low Pressure Injection System (LPIS) piping. The scenario which leads to the Event V accident is initiated by the failure of these check valves to function as a pressure isolation barrier. This causes an overpressurization and rupture of the LPIS low pressure piping which results in a LOCA that bypasses containment.

In order to better define the Event V concern, all light water reactor licensees were requested by 10 CFR 50.54(f) letter, dated February 23, 1980, to identify valve configurations of concern and prior valve test results, if any. By letter dated March 24, 1980, the licensee responded to our request and this information was subsequently transmitted to our contractor, the Franklin Research Center, for verification that the licensee had correctly identified the subject valve configurations.

### 2.0 Evaluation

In order to prepare the Technical Evaluation Report (TER) it was necessary that the contractor verify and evaluate the licensee's response to our February 1980 letter. The NRC acceptance criteria used by Franklin were based on WASH-1400 findings, probabilistic analyses and appropriate Standard Review Plan requirements. With respect to the verification of the licensee's response to our information request, the Franklin evaluation was based on FSAR information, ISI/IST site visit data, and other previously docketed information. The attached Franklin TER correctly identifies the subject valve configurations.

### 3.0 Conclusion

Based on our review of the Franklin TER, we find that the valve configurations of concern have been correctly identified. Since periodic testing of these PCS pressure isolation valves will reduce the probability of an intersystem LOCA we, therefore, conclude that the requirement to test these valves should be incorporated into the plant's Technical Specifications.

Dated: April 20, 1981

8105040062

## TECHNICAL EVALUATION REPORT

**PRIMARY COOLANT SYSTEM  
PRESSURE ISOLATION VALVES**

INDIANA & MICHIGAN ELECTRIC COMPANY  
D. C. COOK UNITS 1 AND 2

NRC DOCKET NO. 50-315, 50-316

NRC TAC NO. 12923, 12924

NRC CONTRACT NO. NRC-03-79-118

FRC PROJECT C5257

FRC TASK 256, 257

*Prepared by*

Franklin Research Center  
The Parkway at Twentieth Street  
Philadelphia, PA 19103

Author: P. N. Noell  
T. C. Stilwell  
FRC Group Leader: P. N. Noell

*Prepared for*

Nuclear Regulatory Commission  
Washington, D.C. 20555

Lead NRC Engineer: P. J. Polk

October 24, 1980

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

**Franklin Research Center**

A Division of The Franklin Institute

The Benjamin Franklin Parkway, Phila., Pa. 19103 (215) 448-1000

8105040072

## 1.0 INTRODUCTION

The NRC has determined that certain isolation valve configurations in systems connecting the high-pressure Primary Coolant System (PCS) to lower-pressure systems extending outside containment are potentially significant contributors to an intersystem loss-of-coolant accident (LOCA). Such configurations have been found to represent a significant factor in the risk computed for core melt accidents.

The sequence of events leading to the core melt is initiated by the concurrent failure of two in-series check valves to function as a pressure isolation barrier between the high-pressure PCS and a lower-pressure system extending beyond containment. This failure can cause an overpressurization and rupture of the low-pressure system, resulting in a LOCA that bypasses containment.

The NRC has determined that the probability of failure of these check valves as a pressure isolation barrier can be significantly reduced if the pressure at each valve is continuously monitored, or if each valve is periodically inspected by leakage testing, ultrasonic examination, or radiographic inspection. The NRC has established a program to provide increased assurance that such multiple isolation barriers are in place in all operating Light Water Reactor plants designated by DOR Generic Implementation Activity B-45.

In a generic letter of February 23, 1980, the NRC requested all licensees to identify the following valve configurations which may exist in any of their plant systems communicating with the PCS: 1) two check valves in series or 2) two check valves in series with a motor-operated valve (MOV).

For plants in which valve configurations of concern are found to exist, licensees were further requested to indicate: 1) whether, to ensure integrity of the various pressure isolation check valves, continuous surveillance or periodic testing was currently being conducted, 2) whether any check valves of concern were known to lack integrity, and 3) whether plant procedures should be revised or plant modifications be made to increase reliability.

Franklin Research Center (FRC) was requested by the NRC to provide technical assistance to NRC's B-45 activity by reviewing each licensee's submittal

against criteria provided by the NRC and by verifying the licensee's reported findings from plant system drawings. This report documents FRC's technical review.

## 2.0 CRITERIA

### 2.1 Identification Criteria

For a piping system to have a valve configuration of concern, the following five items must be fulfilled:

- 1) The high-pressure system must be connected to the Primary Coolant System;
- 2) there must be a high-pressure/low-pressure interface present in the line;
- 3) this same piping must eventually lead outside containment;
- 4) the line must have one of the valve configurations shown in Figure 1; and
- 5) the pipe line must have a diameter greater than 1 inch.




Figure 1. Valve Configurations Designated by the NRC To Be Included in This Technical Evaluation



## 2.2 Periodic Testing Criteria

For licensees whose plants have valve configurations of concern and choose to institute periodic valve leakage testing, the NRC has established criteria for frequency of testing, test conditions, and acceptable leakage rates. These criteria may be summarized as follows:

### 2.2.1 Frequency of Testing

Periodic hydrostatic leakage testing\* on each check valve shall be accomplished every time the plant is placed in the cold shutdown condition for refueling, each time the plant is placed in a cold shutdown condition for 72 hours if testing has not been accomplished in the preceding 9 months, each time any check valve may have moved from the fully closed position (i.e., any time the differential pressure across the valve is less than 100 psig), and prior to returning the valve to service after maintenance, repair, or replacement work is performed.

### 2.2.2 Hydrostatic Pressure Criteria

Leakage tests involving pressure differentials lower than function pressure differentials are permitted in those types of valves in which service pressure will tend to diminish the overall leakage channel opening, as by pressing the disk into or onto the seat with greater force. Gate valves, check valves, and globe-type valves, having function pressure differential applied over the seat, are examples of valve applications satisfying this requirement. When leakage tests are made in such cases using pressures lower than function maximum pressure differential, the observed leakage shall be adjusted to function maximum pressure differential value. This adjustment shall be made by calculation appropriate to the test media and the ratio between test and function pressure differential, assuming leakage to be directly proportional to the pressure differential to the one-half power.

### 2.2.3 Acceptable Leakage Rates:

- Leakage rates less than or equal to 1.0 gpm are considered acceptable.
- Leakage rates greater than 1.0 gpm but less than or equal to 5.0 gpm are considered acceptable if the latest measured rate has not exceeded the rate determined by the previous test by an amount

\*To satisfy ALARA requirements, leakage may be measured indirectly (as from the performance of pressure indicators) if accomplished in accordance with approved procedures and supported by computations showing that the method is capable of demonstrating valve compliance with the leakage criteria.

that reduces the margin between the measured leakage rate and the maximum permissible rate of 5.0 gpm by 50% or greater.

- Leakage rates greater than 1.0 gpm but less than or equal to 5.0 gpm are considered unacceptable if the latest measured rate exceeded the rate determined by the previous test by an amount that reduces the margin between measured leakage rate and the maximum permissible rate of 5.0 gpm by 50% or greater.
- Leakage rates greater than 5.0 gpm are considered unacceptable.

### 3.0 TECHNICAL EVALUATION

#### 3.1 Licensee's Response to the Generic Letter

In response to the NRC's generic letter [Ref. 1], the Indiana & Michigan Electric Company (IME) stated [Ref. 2] that, "We have reviewed the systems that use check valves to perform a pressure isolation function within the Class 1 boundary of the high pressure isolation function within the piping to low-pressure piping that could potentially allow a LOCA to bypass the containment and found that neither of the valve configurations described in Mr. Eisenhut's letter exist at Cook Plant."

Since no valve configurations of concern were described by the licensee, no valve performance surveillance techniques were mentioned. Nevertheless, a valve configuration of concern was discovered in the Low-Head Safety Injection System by FRC.

It is FRC's understanding that, with IME's concurrence, the NRC will direct IME to change its Plant Technical Specifications as necessary to ensure that periodic leakage testing (or equivalent testing) is conducted in accordance with the criteria of Section 2.2.

#### 3.2 FRC Review of Licensee's Response

FRC has reviewed the licensee's response against the plant-specific Piping and Instrumentation Diagrams (P&IDs) [Ref. 3] that might have the valve configurations of concern.

FRC has also reviewed the efficacy of instituting periodic testing for the check valves involved in this particular application with respect to the re-

duction of the probability of an intersystem LOCA in the Low-Head Safety Injection System pipe lines.

In its review of the P&IDs [Ref. 3] for Donald C. Cook Units 1 and 2, FRC found the following piping system to be of concern:

The valve configuration of concern for D. C. Cook Units 1 and 2 exist in the Low-Head Safety Injection System cold leg branches leading to the PCS Loops 2 and 3. These cold leg branches contain a dual check valve in-series configuration with both branches joining to a common motor-operated valve (MOV). The high-pressure/low-pressure interface exists on the upstream side of the single MOV. The valves comprising the configuration of concern are itemized below for D. C. Cook Units 1 and 2.

#### Low-Head Safety Injection System

##### Loop 2, cold leg

high-pressure check valve, SI-170L2  
high-pressure check valve, RH133  
high-pressure MOV, ICM111, normally closed (n.c.)

##### Loop 3, cold leg

high-pressure check valve, SI-170L3  
high-pressure check valve, RH134  
high-pressure MOV, ICM111, n.c.

In accordance with the criteria of Section 2.0, FRC found no other valve configurations of concern existing in this plant.

FRC reviewed the effectiveness of instituting periodic leakage testing of the check valves in these lines as a means of reducing the probability of an intersystem LOCA occurring. FRC found that introducing a program of check valve leakage testing in accordance with the criteria summarized in Section 2.0 will be an effective measure in substantially reducing the probability of an intersystem LOCA occurring in these lines, and a means of increasing the probability that these lines will be able to perform their safety-related functions. It is also a step toward achieving a corresponding reduction in the plant probability of an intersystem LOCA in Donald C. Cook Units 1 and 2.

#### 4.0 CONCLUSION

Based on the previously docketed information and drawings made available for FRC review, FRC found that the cold-leg branches for PCS loops 2 and 3 of the Low-head Safety Injection System in D. C. Cook Units 1 and 2 contain a valve configuration of concern (identified in Figure 1). Thus, if the licensee's review of the valving configuration contained in the cold-leg branches of the Low-Head Safety Injection System confirms FRC's finding, then the valve configurations of concern existing in D. C. Cook Units 1 and 2 incorporate the valves listed in Table 1.0.

If IME modifies the Plant Technical Specifications for Donald C. Cook Units 1 and 2 to incorporate periodic testing (as delineated in Section 2.2) for the check valves itemized in Table 1.0, then FRC considers this an acceptable means of achieving plant compliance with the NRC staff objectives of Reference 1.

Table 1.0

##### Primary Coolant System Pressure Isolation Valves

<u>System</u>	<u>Check Valve No.</u>	<u>Allowable Leakage*</u>
Low-Head Safety Injection	Units 1 and 2	
Loop 2, cold leg	SI-170L2 RH133	
Loop 3, cold leg	SI-170L3 RH134	

\*To be provided by the licensee at a future date in accordance with Section 2.2.3.

#### 5.0 REFERENCES

1. Generic NRC letter, dated 2/23/80, from Mr. D. G. Eisenhut, Department of Operating Reactors (DOR), to Mr. J. E. Dolan, Indiana & Michigan Electric Company (IME).

2. Indiana & Michigan Electric Company's response to NRC's letter, dated 3/24/80, from Mr. J. E. Dolan (IME) to Mr. D. G. Eisenhut (DOR).
3. List of examined P&IDs:  
American Electric Power Service Corporation Drawings of Donald C. Cook Units 1 and 2:
  - 1-2-5115A-21
  - 1-2-5128-8, Sh. 1 of 2
  - 1-2-5128A-16, Sh. 2 of 2
  - 1-2-5129-16, Sh. 1 of 2
  - 1-2-5129A-13, Sh. 2 of 2
  - 1-2-5131-12
  - 1-2-5141-12, Sh. 1 of 3
  - 1-2-5141A-16, Sh. 2 of 3
  - 1-2-5141B-10, Sh. 3 of 3
  - 1-2-5142-16
  - 1-2-5143-20

TECHNICAL SPECIFICATION CHANGES - UNIT NO. 1Remove Pages

3/4 4-16

3/4 4-17

-----

-----

B3/4 4-4

Insert Pages

3/4 4-16

3/4 4-17

3/4 4-17a

3/4 4-17b

B3/4 4-4

8105040084

## REACTOR COOLANT SYSTEM

### OPERATIONAL LEAKAGE

#### LIMITING CONDITION FOR OPERATION

---

3.4.6.2 Reactor Coolant System leakage shall be limited to:

- a. No PRESSURE BOUNDARY LEAKAGE,
- b. 1 GPM UNIDENTIFIED LEAKAGE,
- c. 1 GPM total primary-to-secondary leakage through all steam generators and 500 gallons per day through any one steam generator,
- d. 10 GPM IDENTIFIED LEAKAGE from the Reactor Coolant System, and
- e. 52 GPM CONTROLLED LEAKAGE.
- f. 1 GPM leakage from any reactor coolant system pressure isolation valve specified in Table 3.4-0.

APPLICABILITY: MODES 1, 2, 3 and 4

#### ACTION:

- a. With any PRESSURE BOUNDARY LEAKAGE, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With any Reactor Coolant System leakage greater than any one of the above limits, excluding PRESSURE BOUNDARY LEAKAGE, reduce the leakage rate to within limits within 4 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- c. With any reactor coolant system pressure isolation valve(s) leakage greater than the above limit, except when:
  1. The leakage is less than or equal to 5.0 gpm, and
  2. The most recent measured leakage does not exceed the previous measured leakage\* by an amount that reduces the

\*To satisfy ALARA requirements, measured leakage may be measured indirectly (as from the performance of pressure indicators) if accomplished in accordance with approved procedures and supported by computations showing that the method is capable of demonstrating valve compliance with the leakage criteria.

## REACTOR COOLANT SYSTEM

### LIMITING CONDITION FOR OPERATION (Continued)

margin between the most recent measured leakage and the maximum limit of 5.0 gpm by 50% or more,

declare the leaking valve\* inoperable and isolate the high pressure portion of the affected system from the low pressure portion by the use of a combination of at least two closed valves, one of which may be the OPERABLE check valve and the other a closed de-energized motor operated valve. Verify the isolated condition of the closed de-energized motor operated valve at least once per 24 hours, or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

### SURVEILLANCE REQUIREMENTS

4.4.6.2.1 Reactor Coolant System leakages shall be demonstrated to be within each of the above limits by;

- a. Monitoring the containment atmosphere particulate radioactivity monitor at least once per 12 hours.
- b. Monitoring the containment sump inventory and discharge at least once per 12 hours.
- c. Monitoring the CONTROLLED LEAKAGE to the reactor coolant pump seals at least once per 31 days,
- d. Performance of a Reactor Coolant System water inventory balance at least once per 72 hours during steady state operation, and
- e. Monitoring the reactor head flange leakoff system at least once per 24 hours.

4.4.6.2.2 Each reactor coolant system pressure isolation valve specified in Table 3.4-0 shall be demonstrated OPERABLE verifying leakage to be within its limit prior to entering MODE 3:

- a. After each refueling outage;
- b. Whenever the plant has been in COLD SHUTDOWN for 72 hours or more and if leakage testing has not been performed in the previous 9 months;

\*No Report required (6.9.1) unless the valve has been declared inoperable.



REACTOR COOLANT SYSTEM

SURVEILLANCE REQUIREMENTS (Continued)

- c. Prior to returning the valve to service following maintenance, repair or replacement work on the valve.

TABLE 3.4-0

REACTOR COOLANT SYSTEM PRESSURE ISOLATION VALVES

<u>VALVE NUMBER</u>	<u>FUNCTION</u> <sup>(a)</sup>
SI-170L2 RH133	Low Head Safety Injection Loop 2, cold leg
SI-170L3 RH134	Loop 3, cold leg

<sup>(a)</sup> Minimum test differential pressure shall not be below 150 psid.

## REACTOR COOLANT SYSTEM

### BASES

The 10 GPM IDENTIFIED LEAKAGE limitation provides allowance for a limited amount of leakage from known sources whose presence will not interfere with the detection of UNIDENTIFIED LEAKAGE by the leakage detection systems.

The CONTROLLED LEAKAGE limitation restricts operation when the total flow supplied to the reactor coolant pump seals exceeds 52 GPM. This limitation ensures that in the event of a LOCA, the safety injection flow will not be less than assumed in the accident analyses.

The total steam generator tube leakage limit of 1 GPM for all steam generators not isolated from the RCS ensures that the dosage contribution from the tube leakage will be limited to a small fraction of Part 100 limits in the event of either a steam generator tube rupture or steam line break. The 1 GPM limit is consistent with the assumptions used in the analysis of these accidents. The 500 gpd leakage limit per steam generator ensures that steam generator tube integrity is maintained in the event of a main steam line rupture as under LOCA conditions.

PRESSURE BOUNDARY LEAKAGE of any magnitude is unacceptable since it may be indicative of an impending gross failure of the pressure boundary. Should PRESSURE BOUNDARY LEAKAGE occur through a component which can be isolated from the balance of the Reactor Coolant System, plant operation may continue provided the leaking component is promptly isolated from the Reactor Coolant System since isolation removes the source of potential failure.

The Surveillance Requirements for RCS Pressure Isolation Valves provide added assurance of valve integrity thereby reducing the probability of gross valve failure and consequent intersystem LOCA. Leakage from the RCS Pressure Isolation Valves is IDENTIFIED LEAKAGE and will be considered as a portion of the allowed limit.

### 3/4.4.7 CHEMISTRY

The limitations on Reactor Coolant System chemistry ensure that corrosion of the Reactor Coolant System is minimized and reduces the potential for Reactor Coolant System leakage or failure due to stress corrosion. Maintaining the chemistry within the Steady State Limits provides adequate corrosion protection to ensure the structural integrity of the Reactor Coolant System over the life of the plant. The associated effects of exceeding the oxygen, chloride and fluoride limits are time and temperature dependent. Corrosion studies show that operation may be continued with contaminant concentration levels in excess of the Steady State Limits, up to the Transient Limits, for the specified limited time intervals without having a significant effect on the structural integrity of the Reactor Coolant System. The time interval permitting continued operation within the restrictions of the Transient Limits provides time for taking corrective actions to restore the contaminant concentrations to within the Steady State Limits.

TECHNICAL SPECIFICATION CHANGES - UNIT NO. 2

Remove Pages

3/4 4-15

3/4 4-16

-----

-----

B3/4 4-4

Insert Pages

3/4 4-15

3/4 4-16

3/4 4-16a

3/4 4-16b

B3/4 4-4

## REACTOR COOLANT SYSTEM

### OPERATIONAL LEAKAGE

#### LIMITING CONDITION FOR OPERATION

3.4.6.2 Reactor Coolant System leakage shall be limited to:

- a. No PRESSURE BOUNDARY LEAKAGE,
- b. 1 GPM UNIDENTIFIED LEAKAGE,
- c. 1 GPM total primary-to-secondary leakage through all steam generators and 500 gallons per day through any one steam generator,
- d. 10 GPM IDENTIFIED LEAKAGE from the Reactor Coolant System, and
- e. 52 GPM CONTROLLED LEAKAGE.
- f. 1 GPM leakage from any reactor coolant system pressure isolation valve specified in Table 3.4-0.

APPLICABILITY: MODES 1, 2, 3 and 4

#### ACTION:

- a. With any PRESSURE BOUNDARY LEAKAGE, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With any Reactor Coolant System leakage greater than any one of the above limits, excluding PRESSURE BOUNDARY LEAKAGE, reduce the leakage rate to within limits within 4 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- c. With any reactor coolant system pressure isolation valve(s) leakage greater than the above limit, except when:
  1. The leakage is less than or equal to 5.0 gpm, and
  2. The most recent measured leakage does not exceed the previous measured leakage\* by an amount that reduces the

\*To satisfy ALARA requirements, measured leakage may be measured indirectly (as from the performance of pressure indicators) if accomplished in accordance with approved procedures and supported by computations showing that the method is capable of demonstrating valve compliance with the leakage criteria.

## REACTOR COOLANT SYSTEM

### LIMITING CONDITION FOR OPERATION (Continued)

margin between the most recent measured leakage and the maximum limit of 5.0 gpm by 50% or more,

declare the leaking valve\* inoperable and isolate the high pressure portion of the affected system from the low pressure portion by the use of at least two closed valves, one of which may be the OPERABLE check valve and the other a closed de-energized motor operated valve. Verify the isolated condition of the closed de-energized motor operated valve at least once per 24 hours, or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

### SURVEILLANCE REQUIREMENTS

4.4.6.2.1 Reactor Coolant System leakages shall be demonstrated to be within each of the above limits by;

- a. Monitoring the containment atmosphere particulate radioactivity monitor at least once per 12 hours.
- b. Monitoring the containment sump inventory and discharge at least once per 12 hours.
- c. Monitoring the CONTROLLED LEAKAGE to the reactor coolant pump seals at least once per 31 days,
- d. Performance of a Reactor Coolant System water inventory balance at least once per 72 hours during steady state operation, and
- e. Monitoring the reactor head flange leakoff system at least once per 24 hours.

4.4.6.2.2 Each reactor coolant system pressure isolation valve specified in Table 3.4-0 shall be demonstrated OPERABLE pursuant to Specification 4.0.5, except that in lieu of any leakage testing required by Specification 4.0.5, each valve shall be demonstrated OPERABLE by verifying leakage to be within its limit prior to entering MODE 3:

- a. After each refueling outage;
- b. Whenever the plant has been in COLD SHUTDOWN for 72 hours or more and if leakage testing has not been performed in the previous 9 months;

\*No Report required (6.9.1) unless the valve has been declared inoperable.

REACTOR COOLANT SYSTEM

SURVEILLANCE REQUIREMENTS (Continued)

- c. Prior to returning the valve to service following maintenance, repair or replacement work on the valve.

TABLE 3.4-0

REACTOR COOLANT SYSTEM PRESSURE ISOLATION VALVES

<u>VALVE NUMBER</u>	<u>FUNCTION</u> <sup>(a)</sup>
SI-170L2 RH133	Low-Head Safety Injection Loop 2, cold leg
SI-170L3 RH134	Loop 3, cold leg

<sup>(a)</sup> Minimum test differential pressure shall not be below 150 psid.



## REACTOR COOLANT SYSTEM

### RASES

The 10 GPM IDENTIFIED LEAKAGE limitation provides allowance for a limited amount of leakage from known sources whose presence will not interfere with the detection of UNIDENTIFIED LEAKAGE by the leakage detection systems.

The CONTROLLED LEAKAGE limitation restricts operation when the total flow supplied to the reactor coolant pump seals exceeds 52 GPM. This limitation ensures that in the event of a LOCA, the safety injection flow will not be less than assumed in the accident analyses.

The total steam generator tube leakage limit of 1 GPM for all steam generators not isolated from the RCS ensures that the dosage contribution from the tube leakage will be limited to a small fraction of Part 100 limits in the event of either a steam generator tube rupture or steam line break. The 1 GPM limit is consistent with the assumptions used in the analysis of these accidents. The 500 gpd leakage limit per steam generator ensures that steam generator tube integrity is maintained in the event of a main steam line rupture as under LOCA conditions.

PRESSURE BOUNDARY LEAKAGE of any magnitude is unacceptable since it may be indicative of an impending gross failure of the pressure boundary. Should PRESSURE BOUNDARY LEAKAGE occur through a component which can be isolated from the balance of the Reactor Coolant System, plant operation may continue provided the leaking component is promptly isolated from the Reactor Coolant System since isolation removes the source of potential failure.

The Surveillance Requirements for RCS Pressure Isolation Valves provide added assurance of valve integrity thereby reducing the probability of gross valve failure and consequent intersystem LOCA. Leakage from the RCS Pressure Isolation Valves is IDENTIFIED LEAKAGE and will be considered as a portion of the allowed limit.

### 3/4.4.7 CHEMISTRY

The limitations on Reactor Coolant System chemistry ensure that corrosion of the Reactor Coolant System is minimized and reduces the potential for Reactor Coolant System leakage or failure due to stress corrosion. Maintaining the chemistry within the Steady State Limits provides adequate corrosion protection to ensure the structural integrity of the Reactor Coolant System over the life of the plant. The associated effects of exceeding the oxygen, chloride and fluoride limits are time and temperature dependent. Corrosion studies show that operation may be continued with contaminant concentration levels in excess of the Steady State Limits, up to the Transient Limits, for the specified limited time intervals without having a significant effect on the structural integrity of the Reactor Coolant System. The time interval permitting continued operation within the restrictions of the Transient Limits provides time for taking corrective actions to restore the contaminant concentrations to within the Steady State Limits.