

DISTRIBUTION
 cket File
 NRC PDR
 Local PDR
 ORB#1 Rdg
 D. Eisenhut
 C. Parrish
 R. Cilimberg
 OELD
 SECY
 OI&E
 T. Barnhart (4)
 L. Schneider
 D. Brinkman
 ACRS (10)
 OPA
 R. Diggs
 NSIC
 ASLAB

JUN 08 1982

Docket Nos. 50-315
 and 50-316

Mr. John Dolan, Vice President
 Indiana and Michigan Electric Company
 Post Office Box 18
 Bowling Green Station
 New York, New York 10004

Dear Mr. Dolan:

Our letter dated March 4, 1982, transmitted to you Amendment No. 38 to Facility Operating License No. DPR-74 for the D. C. Cook Nuclear Plant, Unit No. 2, which included Revised Technical Specifications. Through an administrative error pages 3/4 2-3 and 3/4 2-17 contained errors. Enclosed are Revised Technical Specifications pages 3/4 2-3 and 3/4 2-17 for your use.

By letter dated May 6, 1982, we issued Amendment Nos. 54 and 40 to Facility Operating License Nos. DPR-58 and DPR-74 for the D. C. Cook Units 1 and 2, respectively. As a result of a typographical error, incorrect Docket Nos. were referenced in the transmittal letter. The correct Docket Nos. should be 50-315 and 50-316. Please change your copy of these amendments to reflect this correction.

Sincerely,

ORIGINAL SIGNED

Ray Cilimberg, Project Manager
 Operating Reactors Branch #1
 Division of Licensing

Enclosures:
 Revised Technical Specification
 pages 3/4 2-3 and 3 /4 2-17

cc w/enclosures:
 See next page

8206150453 820608
 PDR ADDCK 05000315
 P PDR

cp 6/7/82

OFFICE	DL:ORB#1	DL:ORB#1	DL:ORB#1				
SURNAME	C.Parrish:pr	R.Cilimberg	S.Valla				
DATE	6/14/82	6/7/82	5/8/82				

Mr. John Dolan
Indiana and Michigan Electric Company

cc: Mr. Robert W. Jurgensen
Chief Nuclear Engineer
American Electric Power
Service Corporation
2 Broadway
New York, New York 10004

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Maude Preston Palenske Memorial
Library
500 Market Street
St. Joseph, Michigan 49085

W. G. Smith, Jr., Plant Manager
Donald C. Cook Nuclear Plant
P. O. Box 458
Bridgman, Michigan 49106

U. S. Nuclear Regulatory Commission
Resident Inspectors Office
7700 Red Arrow Highway
Stevensville, Michigan 49127

Mr. Wade Schuler, Supervisor
Lake Township
Baroda, Michigan 49101

Mr. William R. Rustem (2)
Office of the Governor
Room 1 - Capitol Building
Lansing, Michigan 48913

Honorable James Bemeneck, Mayor
City of Bridgman, Michigan 49106

Regional Radiation Representative
EPA Region V
230 South Dearborn Street
Chicago, Illinois 60604

Maurice S. Reizen, M.D.
Director
Department of Public Health
P.O. Box 30035
Lansing, Michigan 48109

William J. Scanlon, Esquire
2034 Pauline Boulevard
Ann Arbor, Michigan 48103

The Honorable Tom Corcoran
United States House of Representatives
Washington, D. C. 20515

James G. Keppler
Regional Administrator - Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

POWER DISTRIBUTION LIMITS

SURVEILLANCE REQUIREMENTS (Continued)

4.2.1.2 The indicated AFD shall be considered outside of its $\pm 5\%$ target band when at least 2 of 4 or 2 of 3 OPERABLE excore channels are indicating the AFD to be outside the target band. Penalty deviation outside of the $\pm 5\%$ target band shall be accumulated on a time basis of:

- a. A penalty deviation for each one minute of POWER OPERATION outside of the target band at THERMAL POWER levels equal to or above 50% of RATED THERMAL POWER, and
- b. A penalty deviation of one half minute for each one minute of POWER OPERATION outside of the target band at THERMAL POWER levels between 15% and 50% of RATED THERMAL POWER.

4.2.1.3 The target axial flux difference of each OPERABLE excore channel shall be determined in conjunction with the measurement of $F_A(Z)$ as defined in Specification 4.2.2.2.c. The provisions of Specification 4.0.4 are not applicable.

B206150454 B20608
PDR ADDCK 05000315
P PDR

POWER DISTRIBUTION LIMITS

AXIAL POWER DISTRIBUTION

LIMITING CONDITION FOR OPERATION

3.2.6 The axial power distribution shall be limited by the following relationship:

$$[F_j(Z)]_s = \frac{[1.99] [K(Z)]}{(\bar{R}_j)(P_L) (1.03) (1 + \sigma_j)(1.07)}$$

Where:

- $F_j(Z)$ is the normalized axial power distribution from thimble j at core elevation Z .
- P_L is the fraction of RATED THERMAL POWER.
- $K(Z)$ is the function obtained from Figure 3.2-2 for a given core height location.
- \bar{R}_j , for thimble j , is determined from at least $n=6$ in-core flux maps covering the full configuration of permissible rod patterns above 100% or APL (whichever is less) of RATED THERMAL POWER in accordance with:

$$\bar{R}_j = \frac{1}{n} \sum_{i=1}^n R_{ij}$$

Where:

$$R_{ij} = \frac{F_{Q_i}^{Meas}}{[F_{ij}(Z)]_{Max}}$$

and $[F_{ij}(Z)]_{Max}$ is the maximum value of the normalized axial distribution at elevation Z from thimble j in map i which had a measured peaking factor without uncertainties or densification allowance of F_Q^{Meas} .